

BESS dossier DE-P008

Page 1 of 2 · Summary

Result: candidate (passes all 4 screening rules), borderline: see below.

Key facts	
Location (point inside the parcel, WGS84)	49.47685, 8.73972
Area	6.00 ha (60,048 m ²)
Land use	grassland
Nearest substation of 110 kV or more	S2, 380 kV, 2,997 m
Share inside protected areas	0.0 %

Screening rules

Rule	Value	Pass
Area at least 20,000 m ²	60,048 m ²	yes
Land use arable, grassland or brownfield	grassland	yes
Within 3,000 m of a substation of 110 kV or more	S2, 380 kV, 2,997 m	yes
At most 5 % inside protected areas	0.0 %	yes

Borderline: the substation distance (2,997 m) is within the combined positional uncertainty (± 7.5 m) of the 3,000 m limit; verify with surveyed data.

Data version 1 · CRS EPSG:3035 · Check READ_ME_FIRST.txt in the dossiers folder before use

BESS dossier DE-P008: evidence and sources

Page 2 of 2

Inputs this result is based on

Input	Feature(s) used	Source date	Positional uncertainty
Parcel	P008	2026-06-30	±2.5 m
Nearest substation of 110 kV or more	S2 (380 kV)	2026-05-15	±5 m
Protected areas overlapping the parcel	none	–	–

Datasets used (DE)

Dataset	Features	Source dates	Max. uncertainty
parcel	13	2026-06-30	±2.5 m
substation	5	2026-05-15	±5 m
protected_area	2	2026-01-31	±10 m

Method

- Grid distance: shortest distance from the parcel to the nearest substation of 110 kV or more.
- Protected share: overlapping protected areas are merged first, so no area is counted twice.
- Borderline: the substation distance (2,997 m) is within the combined positional uncertainty (±7.5 m) of the 3,000 m limit; verify with surveyed data.
- All geometry is compared in EPSG:3035 (equal-area, metres); each source was delivered in its own CRS and transformed once, on promotion.
- Only data the data steward accepted and that meets the data contract (CRS, units, source date, uncertainty) is used; nothing missing is filled in.

Limitations

Preliminary prospecting material. Figures, eco-point estimates and site suitability are indicative and based on available source data and commercial screening assumptions. The 8 eco-points/m2 factor is the current commercial baseline, not certified compensation. Ownership, planning, grid capacity, environmental eligibility and transferability remain subject to project-specific verification. No permit, reservation or construction readiness is represented.