
11:aclNW(internet,jump_server,tcp,445):1
12:malicious(internet):1
13:attackerLocated(internet):1
10:RULE 0 (Direct network reachability via permissible ACL policy):0
9:netAccess(internet,internet,jump_server,tcp,445):0
14:vulHost(jump_server,cve_2022_26809,rpc_service,remoteExploit,privEscalation):1
15:networkService(jump_server,rpc_service,tcp,445,admin):1
8:RULE 2 (Remote code execution via vulnerable network service):0
20:sameCredentials(jump_server,keba_pda_1):1
7:execCode(jump_server,admin):0
6:sameCredentials(jump_server,vdc01):1
26:aclNW(jump_server,plc_l1_1,tcp,502):1
25:networkService(plc_l1_1,modbus_service,tcp,502,root):1
19:RULE 3 (Lateral movement across hosts via shared administrative credentials):0
5:RULE 3 (Lateral movement across hosts via shared administrative credentials):0
24:RULE 5 (Unauthorized industrial command injection into PLC over unauthenticated Modbus/TCP):0
17:sameCredentials(keba_pda_1,vdc01):1
18:execCode(keba_pda_1,admin):0
23:unauthorizedControl(plc_l1_1):0
16:RULE 3 (Lateral movement across hosts via shared administrative credentials):0
22:RULE 6 (Unauthorized control of industrial controller yields root execution privilege):0
4:execCode(vdc01,admin):0
3:isDomainController(vdc01,danieli_domain):1
21:execCode(plc_l1_1,root):0
2:RULE 4 (Complete domain takeover via Domain Controller administrative compromise):0
1:domainCompromise(danieli_domain):0