

Copy Of the Fire Safety Certificate issued by Fire Safety Officer, Rajkot



rfo-sfps-rajkot@gujarat.gov.in



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFORAJ/2024/00093959

Date: 03/12/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFORAJ/2024/00093959/R1

Building Occupancy/Category: Educational (non-residential)

To,

Rasiklal Mohanbhai Vaishnani

Smt. K.P.Dedania Education & Charitable Trust JAVAHAR SOCIETY, PORBANDAR ROAD UPLETA UPLETA UPLETA Rajkot 360490

Fire Region: Rajkot RFO

Mobile No: 9033085908 Email ID: nandish83@yahoo.com

We have received Application No. **2024/00098425** dated 03/12/2024 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise **Smt. K.P.Dedania Education & Charitable Trust** (name of the Building/ Project), as per below mentioned details:

1. TP Number: 0
2. FP Number: 0
3. Survey Number: 0
4. Village Name: UPLETA
5. Name of Block(s): SMT. K.P.DEDANIA EDUCATION& CHARITABLE TRUST

The building/premise was inspected on **03/12/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **03/12/2024**
2. Six monthly inspection was done on **03/12/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **03/12/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated:



Digitally Verified

Digitally verified by: Dipak J Madlani
Fire Safety Officer - General (FSO-G)
2021/001198
#Error
Date: 03/12/2024
Time: 11:15 AM



FSCA/O/RFORAJ/2024/00093959/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

H. S. Dekinadich

**Managing Trustee / President,
Smt. K. P. Dedania Education and
Charitable Trust - UPLETA
Reg. No. E / 11090 / Rajkot**

Nashar

**Principal
Miracle Global School
Upleta - 360 490.**