

CE DOCUMENT EST LA PROPRIETE DE KEMONE. IL EST REMIS A TITRE CONFIDENTIEL ET NE PEUT ETRE NI COPIE NI COMMUNIQUE A DES TIERS SANS AUTORISATION EXPRESSE DE KEMONE.
THIS CONFIDENTIAL DOCUMENT IS THE PROPERTY OF KEMONE. IT SHALL NOT BE DISCLOSED REPRODUCED OR USED WITHOUT THE PRIOR WRITTEN CONSENT OF THIS COMPANY.

CLIENT CUSTOMER		LIEU D'INSTALLATION PLANT LOCATION		REV	
FONCTION SERVICE		PURGED WATER STRIPPING COLUMN BOTTOM PUMP(6)		QUANTITE NECESSAIRE N° OF UNITS 1	
ENTRAINE PAR DRIVEN BY		ELECTRICAL MOTOR		SERVICE OPERATION ☐ CONTINU CONTINUOUS ☒ DISCONTINU DISCONTINUOUS	
NOM DU PROJET PROJECT NAME		TYPE TYPE		CENTRIFUGAL	
REFERENCE OFFRE CONSTRUCTEUR MFR PROPOSAL N°					
1 CONDITIONS OPERATOIRES OPERATING CONDITIONS				CARACTERISTIQUES PERFORMANCES	
2 LIQUID LIQUID water + traces of VCM (5) DEBIT Nominal 3.35 DEBIT Maxi. 4.2 m3/h				COURBE DE PROPOSITION N° PROPOSAL CURVE N°	
3 PRESS. REFOULEMENT (2)(3) 3.98 kg/cm²g				NPSH REQUIS (EAU) REQ'D NPSH (WATER) m	
4 PRESSION/TEMP. DE REF. 108°C PRESS. ASPIRATION (2)(3) 0.7 kg/cm²g				NBRE D'ETAGES No OF STAGES Tr/min RPM	
5 MASSE VOL. A PT 941 kg/m³ PRESS. DIFFERENTIELLE(1)(2) 3.28 kg/cm²				RENDT (4) P. ABS 2.7 (4) kW	
6 TENSION DE VAPEUR A T 1.33 kg/cm²a HAUTEUR MANO. (1)(2) 35 m. liq.				PUISS. MAX. ABS. ROUE. PROPOSEE MAX. BHP WITH RATED IMPELLER kW	
7 VISCOSITE A PT 0.3 cP NPSH DISPONIBLE (2) 3.9 m. liq.				H. MANO. MAX. POUR ROUE PROPOSEE MAX. HEAD WITH RATED IMPELLER m. liq.	
8 CORROSION/EROSION DUE A (5)				DEBIT CONT. MINI (PAR CONSTR.) MIN CONTINUOUS FLOW (BY MFR) m3/h	
9 TYPE ET MATERIAUX DE CONSTRUCTION CONSTRUCTION AND MATERIALS				SENS DE ROTATION FACE ACCOUP. ROTATION (VIEWED FROM CPLG END)	
10 SUPPORTAGE CORPS CASING MOUNTING ☐ AXIAL CENTERLINE ☒ P. SUR CORPS FOOT ☐ P. SUR PALIER BRACKET ☐ VERTICAL VERTICAL				EAU DE REFROIDISSEMENT COOLING WATER	
11 JOINT SPLIT ☐ HORIZONTAL AXIAL ☒ VERTICAL RADIAL ☐				SUR DBLE ENVEL. G.M. TO MECHAN. SEAL JACKET m3/h	
12 TYPE TYPE ☒ VOLUTE SIMPLE SINGLE VOLUTE ☐ VOLUTE DOUBLE DOUBLE VOLUTE ☐ AVEC DIFFUSEUR DIFFUSER				SUR DBLE ENVEL. P.E. TO STUFFING BOX JACKET m3/h	
13 BOSSAGES TAPPED OPENINGS EVENT VENT PURGE DRAIN MANO. P. GAUGE				SUR FOND DE POMPE. TO REAR CASING JACKET m3/h	
14 TUBULURES NOZZLES D.N. SIZE PN OU ASA PN OR ASA FACE DE BRIDE FACING POSITION POSITION				SUR PALIER TO BEARING HOUSING m3/h	
15 ASPIRATION SUCTION (7) 300 # RF HORIZONTAL				DEBIT D'EAU TOTAL TOTAL WATER REQ'D m3/h	
16 REFOULEMENT DISCHARGE (7) 300 # RF VERTICAL				EAU LANTERNE P.E. WATER TO LANTERN RING	
17 DIAMETER DE LA ROUE IMPELLER DIAMETER MAX MAX				RECHAUFFAGE HEATING JACKET	
18 PALIER BEARING SOCLE BASE				CIRCUIT EAU DE REFROID. SEAL COOLING	
19 ACCOUPLET MARQUE COUPLING MFR TYPE TYPE MONTE PAR FITTED BY Manufacturer				SUIVANT API 610 FIG. PLAN ACC. TO API 610 FIG. PLAN	
20 PROTECTEUR D'ACCOUPLEMENT COUPLING GUARD Anti-sparking ☐ BOULONS DE FONDATION BASEPLATE BOLTS				AUXILIAIRES FOURNIS AVEC LA POMPE DEVICE SUPPLIED WITH PUMP	
21 PRESSE-ETOUPE (P.E.) PACKING TYPE AND SIZE				CIRCUIT D'ARROSAGE G.M. PIPING FOR SEALS	
22 GARNITURE MECANIQUE (G.M.) MECHANICAL SEAL MFR Single seal-Plan 32 (8) TYPE TYPE				SUIVANT API 610 FIG. PLAN ACC. TO API 610 FIG. PLAN	
23 G.M. DIAM. ET CARACTERISTIQUES M.S. SIZE AND CHARACTERISTICS				INSTRUMENT SUR POT G.M. ALARMS AND SAFETY FOR SEAL DEVICES	
24 GARNITURES MECANQUES MECHANICAL SEALS					
25 REMARQUES REMARKS (1) VALUE STATED FOR DESIGN FLOWRATE					
26 (2) NPSHA INDICATED IS FROM PUMP CENTERLINE WHICH IS AT 800 mm ELEVATION FROM GRADE.					
27 (3) ESTIMATED DISCHARGE DESIGN PRESSURE (CORRESPONDING TO SHUT-OFF PRESSURE) IS 16 kg/cm² g. VENDOR SHALL LIMIT RISE TO SHUT-OFF SO AS NOT TO EXCEED THE DISCHARGE DESIGN PRESSURE. DESIGN TEMPERATURE: 240°C. DESIGN SUCTION PRESSURE : 11 kg/cm2 g.					
28 (4) ESTIMATED SHAFT POWER. TO BE CONFIRMED BY PUMP VENDOR. MOTOR SHALL BE ENERGY-EFFICIENT : - CEI60034-30, class IE2 or IE3, or equivalent. TO BE CONFIRMED BY ELECTRICAL DISCIPLINE IN MDS.					
29 (5) PUMPED FLUID IS MAINLY WATER WITH TRACES OF VCM AND HCl.					
30 (6) PUMP TO BE INSULATED FOR HOT INSULATION.					
31 (7) TO BE CONFIRMED BY PUMP VENDOR					
POMPE CENTRIFUGE CENTRIFUGAL PUMP		REPERE - ITEM MP-PP031-P300228		PAGE 2 / 3	DATE 22/06/2024 06/03/2025
				REV. 00 01	

CE DOCUMENT EST LA PROPRIETE DE KEMONE. IL EST REMIS A TITRE CONFIDENTIEL ET NE PEUT ETRE NI COPIE NI COMMUNIQUE A DES TIERS SANS AUTORISATION EXPRESSE DE KEMONE. THIS CONFIDENTIAL DOCUMENT IS THE PROPERTY OF KEMONE. IT SHALL NOT BE DISCLOSED REPRODUCED OR USED WITHOUT THE PRIOR WRITTEN CONSENT OF THIS COMPANY.

CLIENT CUSTOMER		LIEU D'INSTALLATION PLANT LOCATION		REV	
FONCTION SERVICE		PURGED WATER STRIPPING COLUMN BOTTOM PUMP		QUANTITE NECESSAIRE N° OF UNITS 1	
ENTRAINE PAR DRIVEN BY		ELECTRICAL MOTOR		SERVICE OPERATION ☐ CONTINU CONTINUOUS ☒ DISCONTINU DISCONTINUOUS	
NOM DU PROJET PROJECT NAME		TYPE TYPE		CENTRIFUGAL	
REFERENCE OFFRE CONSTRUCTEUR MFR PROPOSAL N°					
31 MATERIAUX POMPE MATERIALS PUMP		GARNITURE MECANIQUE (1) MECHANICAL SEAL		ESAIS CHEZ CONSTRUCTEUR SHOP TESTS	
32 ROUE IMPELLER		CS		PERFORMANCEE PERFORMANCE	
33 CORPS INNER CASE		CS		NPSH NPSH	
34 CHEMISE (P.E.) SLEEVE (PACKED)		RESSORT/SOUFFLET SPRING/BELLOWS		DEMONTAGE DISMANTLING	
35 CHEMISE (G.M.) SLEEVE (M.S.)		AUTRES PIECES OTHERS		PROCES-VERBAL TEST RECORD	
36 BAGUE D'USURE WEAR RINGS		GRAIN FIXE COTE EXT. STAT. SEAL EXT. SIDE		EPREUVE HYDRAU. HYDRAUL. TESTS	
37 ARBRE SHAFT		GRAIN TOURN. C. EXT. ROT. SEAL EXT. SIDE		P/T MAX. ADMISSIBLE P/T MAX. ALLOWABLE	
38 JOINTS DE CORPS CASING GASKET		JOINTS GASKETS & O RINGS		POIDS POMPE WEIGHT PUMP	
39		POT RESERVOIR		LIEU DES ESSAIS TESTS LOCATION	
40		LIQUIDE TAMPON BUFFING LIQUID			
41 MOTEUR FOURNI PAR MOTOR SUPPLIED BY		ENTRAINEMENT DRIVERS		CARACTERISTIQUES REELLES MFR FINAL DATA (AS BUILT)	
42 MARQUE MFR		TYPE		DIAM. REEL ROUE ACTUAL IMPELLER DIAMETER	
43 kW Tr/min kW RPM		Carc. Frame		COUBE D'ESSAI N° TEST CURVE N°	
44 PROTECTION PROTECTION		IP55		PLAN D'ENSEMBLE N° OUTLINE DRWG N°	
45 ANTIDFLAGRANT EXPLOSION PROOF		EExd IIB T4 (4)		PLAN EN COUPE N° SECTIONAL DRWG N°	
46 VOLTS/PHASES/Hz VOLTS/PHASES/Hz		415/3/50		PLAN DE LA GARNITURE N° SEALING SYSTEM DRWG N°	
47 PALIER BRGS		bearing LUB. LUB.		N° DE LA SERIE DE LA POMPE PUMP SERIAL N°	
48 INTENSITE A CHARGE MAXI CURRENT AT MAX LOADING					
49 MONTE PAR MOUNTED BY		POIDS WT		kg	
50 REMARQUES REMARKS					
51					
52 (1) SINGLE MECHANICAL SEAL					
53 (2) MDMT : 5 °C					
54 (3) PUMPING FLUID WILL CONTAIN AVERAGE PVC CONCENTRATION OF 40 mg/l WITH AVERAGE PARTICLE SIZE OF 25 µm. MAXIMUM PARTICLE SIZE IS 200 µm.					
55 (4) MOTOR TYPE BASED ON HAZARDOUS AREA CLASSIFICATION TO BE CONFIRMED BY ELECTRICAL AND HSE DISCIPLINE IN MECHANICAL DATASHEET.					
56 NOTES CONTINUED FROM PAGE 2/3...					
57 (8) SEAL PLAN AND FLUSHING LIQUID REQUIREMENT FOR PUMP TO BE CONFIRMED BY MECHANICAL DISCIPLINE IN MDS BASED ON VENDOR REQUIREMENT.					
58					
59					
60					
POMPE CENTRIFUGE CENTRIFUGAL PUMP		REPERE - ITEM MP-PP031-P300228		PAGE 3 / 3	
				DATE 22/06/2024	
				06/03/2025	
				REV. 00	
				01	