



भारतीय मानक ब्यूरो

(उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय, भारत सरकार)

BUREAU OF INDIAN STANDARDS

(Ministry of Consumer Affairs, Food & Public Distribution, Govt. of India)

राजकोट शाखा कार्यालय / Rajkot Branch Office

एफ. पी. नं. 364/P. वॉर्ड नं. 13, क्रिस्टल मॉल के सामने, भारत पेट्रोल पंप के बगल में, कालावड रोड, राजकोट-३६०००५, गुजरात.
F.P. No. 364/P, Ward No. 13, Opp. Crystal Mall, Near Bharat Petrol Pump, Kalawad Road, RAJKOT - 360005. Gujarat.
Phone : 0281-2563980, 2563981, 2563982, 2563983 E-mail : rjbo@bis.gov.in / rjbo-2@bis.gov.in Web : www.bis.gov.in

PUBLIC ALERT FOR PRODUCT RECALL

This is to bring to the notice of the general public that the manufacturer with details as given below has been advised for product recall in view of the non-conformities observed in the product w.r.t. the requirements stipulated in relevant Indian Standard and the non-conformities have an impact on public health/safety:

Manufacture Name and Address	M/S LORENO INDUSTRIES PLOT NO. 26, UMIYA IND. ZONE-4, OPP. UMIYA STEEL,,GONDAL HIGHWAY, RIBDA, RAJKOT - 360311
BIS Product Certification Licence No.	CM/L- 7600155612
Name of the Product	POLYVINYL CHLORIDE INSULATED UNSHEATHED AND SHEATHED CABLES CORDS WITH RIGID AND FLEXIBLE CONDUCTOR FOR RATED VOLTAGES UP TO AND INCLUDING 1100 V
Indian Standard No.	IS 694 : 2010
Grade/Type/Variety/Class/Size/Rating	1C x 1.5 SQ.MM, CLASS 2
Non-conforming parameter	FAILING IN THE REQUIREMENT OF HVDC TEST.
Clause No. of the Indian Standard	10.1 of IS 694 : 2010
Type of Risk	Electrical Hazards
Brand Name	LORENO
Batch/Control Unit (C.U.)/Lot No.	LI014
Date of Manufacturing	18-08-2022


14/06/2023
Scientist E & Head
(Rajkot Branch Office - I)
Bureau of Indian Standards
Date of order:

Use "BIS CARE" App to check the authenticity of Standard Mark () products.