




भारतीय मानक ब्यूरो
BUREAU OF INDIAN STANDARDS
देहरादून शाखा कार्यालय
DEHRADUN BRANCH OFFICE

Address: UCF Sadan, Ground Floor,
Block- D, Deep Nagar Road,
Vishnu Vihar,
Dehradun - 248001
Phones : 0135-2665129
E-Mail: dhbo@bis.gov.in
Web: <http://www.bis.org.in>
GST No. 05AAATB0431G1ZH

Annexure-VI

PUBLIC ALERT FOR PRODUCT RECALL	
This is to bring to the notice of the general public that the manufacturer with details as given below has been advised for product recall in view of the non-conformities observed in the product w.r.t. the requirements stipulated in relevant Indian Standard and the non-conformities have an impact on public health/ safety:	
Manufacturer Name and Address	M/s SURBHI TELELINK (P) LTD. Ram Ghat Road, Near Mahan Milk Station, Paonta Sahib, SIRMAUR, Himachal Pradesh - 173025
BIS Product Certification Licence No.	9606081
Name of the Product	POLYVINYL CHLORIDE INSULATED UNSHEATHED AND SHEATHED CABLES CORDS WITH RIGID AND FLEXIBLE CONDUCTOR FOR RATED VOLTAGES UP TO AND INCLUDING 1100 V
Indian Standard No.	IS 694 : 2010
Grade/Type/Variety/Class/Size/Rating	Single core, 1.5sq.mm, Flexible copper conductor, Cat-FR
Non-conforming parameter	High Voltage (DC) water immersion test & Insulation thickness test
Clause No. of the Indian Standard	Cl. 10.1 and Cl. 5.3
Type of risk	Electrical Shock, Insulation breakdown Low performance in the moisture as cable not suitable for water immersion.
Brand Name	Surbhi
Batch/Control Unit (C.U.)/Lot No.	Lot No.: 8042023
Date of Manufacturing	04/2023
 Head (Dehradun Branch Office) Bureau of Indian Standards Date of order: 18.07.2023	
Use "BIS CARE" App to check the authenticity of Standard Mark (S) products.	

सुधीर बिश्नोई
Sudheer Bishnoi
बि. एफ. (परि. निदेशक) एवं प्रमुख / Sc. F (Sr. Director) & Head
भारतीय मानक ब्यूरो / Bureau of India Standards
देहरादून शाखा कार्यालय / Dehradun Branch Office
यू.सी.एफ. सदन, ग्राउंड फ्लोर, ब्लॉक 'डी' विष्णु विहार
U.C.F. Sadan, Ground Floor, Block 'D' Vishnu Vihar
देहरादून-248001 (उत्तराखण्ड) / Dehradun-248001 (Uttarakhand)