

Public alert for product recall on account of non-conformity of product

The manufacturers with details as given below have been advised for product recall in view of the non-conformities observed in the product w.r.t. the requirements stipulated in relevant Indian Standard and the non-conformities have an impact on public health/safety:

Sr. No.	Manufacturer details			Product details			Date of order	Product recall details
	Name	Address	CM/L No.	Product	Indian Standard No.	Brand Name		
1.	FIZON PIPES & CABLES LLP	Plot No.G- 2504+2505/B, Kranti Gate, Road H, GIDC Metoda, Kalawad Road, Rajkot-360021, Rajkot,360021	CM/L- 7600146510	Polyvinyl Chloride Insulated Unsheathed And Sheathed Cables Cords With Rigid And Flexible Conductor	IS 694 : 2010	FIZON	13/09/2023	<u>Fails in requirement of HVDC test</u>
				For Rated Voltages Up To And Including 1100 V				

