

BUREAU OF INDIAN STANDARDS

(Ministry of Consumer Affairs, Product and Public Distribution Government of India)

Chennai Branch Office

CIT CAMPUS IV CROSS ROAD TARAMANAI CHENNAI-600113

E-Mail: cnbo1@bis.gov.in Contact No: 044 22541442, 22541216

Website: www.bis.gov.in, manakonline.in

PUBLIC ALERT FOR PRODUCT RECALL

This is to bring to the notice of the general public that the manufacturer with details as given below has advised for product recall in view of the non-conformities observed in the product w.r.t the requirements stipulated in relevant Indian Standard and the non-conformities have an impact on public safety:

Manufacturer Name & Addrees	M/s TEKMAK CABLES INDIA (P) LTD
BIS Product Certification Licence No.	L-6807278
Name of the Products	POLYVINYL CHLORIDE INSULATED UNSHEATHED AND SHEATHED CABLES CORDS WITH RIGID AND FLEXIBLE CONDUCTOR FOR RATED VOLTAGES UP TO AND INCLUDING 1100 V
Indian Standard No.	IS 694:2010
Brand Name	TEKMAK
Grade/Type/Variety/Class/Size/Rating	Single core 4 sq mm PVC insulated unsheathedflexible cable for working voltage upto and including 1100 V. Insulation type-A, Copper Conductor class 5 cable category 01 cable Code Y.
Batch/Lot/C.U.No.	170821
Date of Manufacturing	17.08.2021

(G.BHAVANI)
SCIENTIST –E & HEAD
CHENNAI BRANCH OFFICE-I
BUREAU OF INDIAN STANDARDS

Date of Order: 12/11/2021

Use “BIS CARE” App to check the authenticity of Standard Mark () Products.