

Post Foundation Details

Foundation & anchorage drawings for fencing post systems

DOCUMENT NO. KM-CAD-002	UNITS mm unless noted	CONCRETE C20/25
----------------------------	--------------------------	--------------------

1. Foundation Schedule — Rigid Panel Fencing

Fence Height	Post	Wind Zone	Hole Ø	Depth	Projection
1.03 m	60×40×1.5	W1–W2	200	500	+80
1.73 m	60×40×1.5	W1–W2	240	600	+80
2.43 m	80×60×2.0	W1–W2	260	800	+80
2.43 m	80×60×2.0	W3+	300	1,000	+80

2. Detail Notes

- Clearance post-to-hole wall ≥ 50 mm all around; concrete vibrated in 200 mm layers.
- Base of hole: 50 mm blinding. Expansive clay soils: engage engineer — may require Ø300 oversized foot.
- Gate posts: one size larger hole + depth than schedule; double gate center: depth +200 mm.
- Alternative anchorage: M16 chemical anchor into C25 slab, embedment 110 mm, torque 60 N·m.

3. Sketch — Typical Post in Concrete



Values for standard 2.5 m post spacing. Closer spacing or cantilevered gates: refer to KM-DS-002 load data and verify locally.