

## HOME RETROFIT SPECIFICATIONS MANUAL

# GAS TANKLESS WATER HEATER COMPLETE MEASURE CHECKLIST

All work must meet Energy Trust of Oregon specifications. **This checklist serves as a reference guide only.** Please refer to the current Specifications Manual for additional information and clarification. Specific reference sections are noted in italics.

<input type="checkbox"/>	A functioning UL-listed carbon monoxide alarm is installed in the home on every floor with a bedroom and according to manufacturer's specifications. <i>IN 1.2</i>
<input type="checkbox"/>	Unit has a permanent label identifying make, model and serial number. <i>IN 1.14</i>
<input type="checkbox"/>	Unit is installed in a non-hazardous location maintaining proper clearance and does not compromise the structural integrity of the building. <i>IN 1.14 and IN 1.15</i>
<input type="checkbox"/>	Water temperature is set no higher than 120°F. <i>WH 1.0</i>
<input type="checkbox"/>	Intake air for all sealed combustion tankless water heaters shall come from outside the conditioned space. <i>WH 4.0</i>
<input type="checkbox"/>	Unit is installed in accordance with manufacturer's specifications and jurisdictional codes. <i>IN 1.14</i>

Print Name:	Signature:	Date:
-------------	------------	-------