

**UNIVERSITY OF PATRAS - SCHOOL OF ENGINEERING**  
DEPARTMENT OF ELECTRICAL AND COMPUTER ENGINEERING



DIVISION: SYSTEMS AND AUTOMATIC CONTROL

## THESIS

of the student of the Department of Electrical and Computer Engineering of the School  
of Engineering of the University of Patras

ALEXIOS KARADIMOS OF LOUKAS

STUDENT NUMBER: 1046820

Subject

---

# Robotic surgical tool manipulator - Recognition, control and manipulation of laparoscopic tools

---

Supervisor

Associate Professor Dr. Evangelos Dermatas

Co-Supervisor

Professor Dr. Anthony Tzes

**Thesis Number:**

Patras, 2022



# ΠΙΣΤΟΠΟΙΗΣΗ

Πιστοποιείται ότι η διπλωματική εργασία με θέμα

**Robotic surgical tool manipulator - Recognition, control and  
manipulation of laparoscopic tools**

του φοιτητή του Τμήματος Ηλεκτρολόγων Μηχανικών και Τεχνολογίας  
Υπολογιστών

Alexios Karadimos of Loukas

(A.M.: 1046820)

παρουσιάστηκε δημόσια και εξετάστηκε στο τμήμα Ηλεκτρολόγων Μηχανικών και  
Τεχνολογίας Υπολογιστών στις

\_\_\_/\_\_\_/\_\_\_

Ο Επιβλέπων

Ο Διευθυντής του Τομέα

Evangelos Dermatas  
*Associate Professor Dr.*

Kazakos Demosthenes  
*Assistant Professor Dr.*



# CERTIFICATION

It is certified that the Thesis with Subject

**Robotic surgical tool manipulator - Recognition, control and  
manipulation of laparoscopic tools**

of the student of the Department of Electrical and Computer Engineering

Alexios Karadimos of Loukas

(R.N.: 1046820)

Was presented publicly and defended at the Department of Electrical and  
Computer Engineering at

\_\_\_\_/\_\_\_\_/\_\_\_\_

The supervisor

The Director of the Division

Evangelos Dermatas  
*Associate Professor Dr.*

Kazakos Demosthenes  
*Assistant Professor Dr.*



## Thesis details

Subject: **Robotic surgical tool manipulator - Recognition, control and manipulation of laparoscopic tools**

Student: **Alexios Karadimos of Loukas**

Supervising Team:

**Associate Professor Dr. Evangelos Dermatas, University of Patras**  
**Professor Dr. Anthony Tzes, NYU Abu Dhabi**

Thesis research period:



## **Abstract**

This thesis studies all the stages involved in the recognition, control and manipulation of laparoscopic tools in an end-to-end approach with more emphasis given to the pivot trajectories and the RCM constrained motion planning. The first step was to study the forward and inverse kinematics of the KUKA iiwa14 industrial robot arm (with the position-orientation decoupling technique for 6dof robots, leaving the extra degree of freedom to be specified by other constraints) as well as kinematics of the Barrett hand gripper in order to calculate grasps. Since MIS robotics is very constrained in nature, the next step was to study the RCM constraint for the pivot motions, the elbow-up constraint to avoid collisions as well as the workspace constraints and singularities. When designing robot applications it is important to study the robot's workspace, and for this reason, this thesis also studies the surgical task space and how this is transformed to the robot's taskspace and the joint space. The manipulability of the robot was also studied and also a suitable environment layout so that all trajectories were well reachable. A lot of emphasis was given in calculating various geometric paths for the robot to follow inside the surgical task. The equations for circular, circular arc, line segment, helical, cubic spline, b-spline, higher-order polynomial and trapezoid and s-curve velocity profile trajectories are studied in detail in order to generate pivot motions with a wide variety. All experiments were conducted using the ROS framework and popular tools and libraries like Gazebo, RViz and MoveIt using the RRTConnect path planning algorithm. The experiments were evaluated with measurements of time, position accuracy and RCM distance deviation. This thesis also briefly studies a simple recognition of a laparoscopic tool and the estimation of its position and orientation using computer vision as well as the calculation of 3 points on the surgical tool where the gripper's fingers will be placed in order to grasp the object with a satisfactory force closure. Finally this thesis studies some control system schemes like for example the RCM tracking and pivot motion control.



## Περίληψη

Η παρούσα διπλωματική εξετάζει όλα τα στάδια που εμπλέκονται στην αναγνώριση, τον έλεγχο και τον χειρισμό των λαπαροσκοπικών εργαλείων με μια ολιστική προσέγγιση αλλά με μεγαλύτερη έμφαση να δίνεται στις τροχιές περιστροφής γύρω από σημείο και στον προγραμματισμό περιορισμένης κίνησης RCM. Το πρώτο βήμα ήταν να μελετηθεί το ευθύ και αντίστροφο κινηματικό πρόβλημα του βιομηχανικού ρομποτικού βραχίονα KUKA iiwa14 (με την τεχνική αποσύνδεσης θέσης- προσανατολισμού για ρομπότ 6 βαθμών ελευθερίας, αφήνοντας τον επιπλέον βαθμό ελευθερίας να καθοριστεί από άλλους περιορισμούς) καθώς και η κινηματική της αρπάγης Barrett ώστε να υπολογιστούν λαβές του χειρουργικού εργαλείου. Δεδομένου ότι η ρομποτική MIS επιβάλλει πολλούς περιορισμούς, το επόμενο βήμα ήταν να μελετηθεί ο περιορισμός RCM για τις κινήσεις περιστροφής (pivot), ο περιορισμός στον οποίο ο αγκώνας του ρομπότ πρέπει να είναι προς τα πάνω για την αποφυγή συγκρούσεων καθώς και οι περιορισμοί και τα σημεία ενικότητας του χώρου εργασίας. Κατά το σχεδιασμό εφαρμογών ρομπότ είναι σημαντικό να μελετηθεί ο χώρος εργασίας του ρομπότ και για το λόγο αυτό, αυτή στη διπλωματική αυτή μελετάται επιπλέον ο χώρος χειρουργικών εργασιών και πώς αυτός μετατρέπεται στον χώρο εργασιών του ρομπότ και στον χώρο αρθρώσεών του. Μελετήθηκε επίσης ο δείκτης επιδεξιότητας του ρομπότ και η κατάλληλη διάταξη του ρομπότ σε σχεση με το περιβάλλον του έτσι ώστε όλες οι τροχιές να είναι καλά προσβάσιμες και να μπορουν να εκτελεστούν με ευκολία. Δόθηκε μεγάλη έμφαση στον υπολογισμό διαφόρων γεωμετρικών μονοπατιών που έπρεπε να ακολουθήσει το ρομπότ μέσα στο χώρο χειρουργικής εργασίας. Οι εξισώσεις για τροχιές κύκλου, κυκλικού τόξου, ευθύγραμμου τρίγματος, έλικα, κυβικού spline, b-spline, πολυωνύμιων υψηλότερης τάξης και τροχιές με προφίλ ταχύτητας τραπεζοειδές και καμπύλης-ς, μελετώνται λεπτομερώς, προκειμένου να δημιουργηθούν χειρουργικές ρομποτικές κινήσεις με μεγάλη ποικιλία. Όλα τα πειράματα υλοποιήθηκαν χρησιμοποιώντας το περιβάλλον ROS και δημιοφιλή εργαλεία και βιβλιοθήκες όπως τα Gazebo, RViz και MoveIt χρησιμοποιώντας τον αλγόριθμο σχεδιασμού διαδρομής RRTConnect. Τα πειράματα αξιολογήθηκαν με μετρήσεις χρόνου, ακρίβειας θέσης και απόκλισης απόστασης RCM. Στη διπλωματική αυτή μελετάται επίσης εν συντομίᾳ η απλή αναγνώριση ενός λαπαροσκοπικού εργαλείου και η εκτίμηση της θέσης και του προσανατολισμού του με χρήση υπολογιστικής όρασης καθώς και ο υπολογισμός 3 σημείων πάνω στο χειρουργικό εργαλείο όπου θα τοποθετηθούν τα δάχτυλα της αρπάγης για να πάσει το αντικείμενο με μία ικανοποιητική λαβή. Τέλος, σε αυτή τη διπλωματική μελετώνται ορισμένα συστήματα ελέγχου όπως για παράδειγμα ενός συστήματος για την παρακολούθηση RCM και τον έλεγχο κίνησης περιστροφής.



## **Acknowledgements**

The subject of this thesis, is a subject that I have been passionate about for many years and from the beginning of my university studies. For this reason I would like to thank my supervisors for giving me the opportunity to dive deep into this fascinating subject. I would also like to thank my friends and family for their huge support and for pushing me during the pandemic to conquer my academic goals.



# Contents

|   |           |
|---|-----------|
| <b>Contents</b>   | <b>15</b> |
| <b>1 Introduction</b>   | <b>19</b> |
| 1.1 Surgical robotics . . . . .                                 | 19        |
| 1.1.1 Historical Overview of Surgical robotics . . . . .        | 19        |
| 1.1.2 Surgical Robotics Procedure . . . . .                     | 20        |
| 1.1.3 Advantages & Disadvantages of Surgical robotics . . . . . | 22        |
| 1.2 Problem statement . . . . .                                 | 23        |
| 1.3 Bibliography Overview . . . . .                             | 23        |
| 1.4 Methodology & Approach . . . . .                            | 24        |
| <b>2 Robotic arm Kinematic Analysis</b>                         | <b>27</b> |
| 2.1 Robotic arm, DH parameters & Forward Kinematics . . . . .   | 27        |
| 2.1.1 End-effector to tool-tip transformations . . . . .        | 29        |
| 2.2 Inverse Kinematics . . . . .                                | 30        |
| 2.2.1 Decoupling Technique . . . . .                            | 31        |
| 2.2.2 Solutions for 7DoF numerically . . . . .                  | 32        |
| 2.2.3 Constraints & Singularity points . . . . .                | 34        |
| 2.2.3.1 Workspace constraints & Singularity points . . . . .    | 34        |
| 2.2.3.2 Remote Center of Motion constraint . . . . .            | 35        |
| 2.2.3.3 Elbow-up constraint . . . . .                           | 37        |
| <b>3 Grasping</b>   | <b>41</b> |
| 3.1 Gripper & Forward Kinematics . . . . .                      | 41        |
| 3.2 Gripper Inverse Kinematics . . . . .                        | 42        |
| 3.3 Force closure . . . . .                                     | 44        |
| <b>4 Scene and object recognition with Computer Vision</b>      | <b>47</b> |
| 4.1 Laparoscopic tool detection . . . . .                       | 47        |
| 4.2 Stereoscopic vision . . . . .                               | 49        |
| 4.3 Calculation of tool position and orientation . . . . .      | 49        |
| 4.4 Calculation of grasping points . . . . .                    | 50        |
| 4.5 Trocar detection & Estimation of fulcrum point . . . . .    | 52        |
| <b>5 Path Planning</b>  | <b>53</b> |
| 5.1 Sampling methods . . . . .                                  | 53        |
| 5.1.1 RRT Algorithms . . . . .                                  | 53        |
| 5.1.2 PRM Algorithms . . . . .                                  | 54        |
| 5.2 Pick and place algorithm . . . . .                          | 55        |

---

|  |           |
|--|-----------|
| 5.3 Task space analysis . . . . .  | 56        |
| <b>6 Trajectory Planning - Laparoscopic tool manipulation</b>                  | <b>61</b> |
| 6.1 Tool pose & the Fulcrum Effect . . . . .                                   | 61        |
| 6.2 Trajectory planning in cartesian coordinates . . . . .                     | 64        |
| 6.2.1 Circular trajectory of tool tip . . . . .                                | 64        |
| 6.2.2 Circular arc trajectory of tool tip . . . . .                            | 66        |
| 6.2.3 Helical trajectory of tool tip . . . . .                                 | 66        |
| 6.2.4 Line segment trajectory of tool tip . . . . .                            | 67        |
| 6.2.5 Cubic Spline trajectory of tool tip . . . . .                            | 68        |
| 6.2.6 B-Spline trajectory of tool tip . . . . .                                | 72        |
| 6.3 Trajectory planning in joint angles space . . . . .                        | 74        |
| 6.3.1 Polynomials of 5th order . . . . .                                       | 74        |
| 6.3.2 Planning with velocity profiles . . . . .                                | 76        |
| 6.3.2.1 Trapezoid velocity profile - LSPB . . . . .                            | 76        |
| 6.3.2.2 S-Curve velocity profile . . . . .                                     | 78        |
| 6.3.2.3 Comparison of velocity profiles . . . . .                              | 80        |
| <b>7 System Control</b>  | <b>83</b> |
| 7.1 RCM Tracking . . . . .   | 83        |
| 7.2 Visual Servoing . . . . .  | 86        |
| 7.2.1 Position based servoing . . . . .  | 87        |
| 7.2.2 Image based servoing . . . . .   | 87        |
| 7.3 Firm grasping algorithm & Force control . . . . .                          | 89        |
| <b>8 ROS framework</b>   | <b>91</b> |
| 8.1 Introduction to the ROS framework . . . . .                                | 91        |
| 8.2 Gazebo simulation environment . . . . .                                    | 92        |
| 8.3 Visualization with RViz . . . . .  | 94        |
| 8.4 Motion Planning with Moveit . . . . .                                      | 95        |
| 8.5 Tools, Packages and Libraries . . . . .                                    | 97        |
| <b>9 Experiments and Results</b>   | <b>99</b> |
| 9.1 Robot Planner 1: Simple MoveIt planning . . . . .                          | 99        |
| 9.2 Robot Planner 2: Simulation layout and reachability experiments . . . . .  | 102       |
| 9.3 Robot Planner 3: Trajectory planning . . . . .                             | 106       |
| 9.3.1 Line segment trajectories in task space . . . . .                        | 108       |
| 9.3.2 Circular trajectories in task space . . . . .                            | 113       |
| 9.3.3 Cubic Spline trajectories in task space . . . . .                        | 113       |
| 9.3.4 B-Spline trajectories in task space . . . . .                            | 115       |
| 9.3.5 Polynomial trajectories in joint space . . . . .                         | 116       |
| 9.3.6 Trajectories in joint space with trapezoidal velocity profile . . . . .  | 117       |
| 9.3.7 Trajectories in joint space with s-curve velocity profile . . . . .      | 119       |
| 9.3.8 Helical trajectories in task space . . . . .                             | 120       |
| 9.4 Robot Planner 4: Simple cube pick-and-place experiment . . . . .           | 121       |
| 9.5 Robot Planner 5: Visual servoing . . . . .                                 | 124       |
| 9.6 Robot Planner 6: RCM alignment error in insertion and retraction . . . . . | 125       |
| 9.7 Robot Planner 7: State machine - End-to-end running . . . . .              | 127       |

|   |            |
|---|------------|
| <b>10 Conclusions and Future Work</b>             | <b>131</b> |
| 10.1 Conclusions . . . . .                        | 131        |
| 10.2 Future Work . . . . .                        | 134        |
| <b>Appendices</b>                                 | <b>137</b> |
| .1 Software and Documentation . . . . .           | 139        |
| .2 Mathematics . . . . .                          | 139        |
| .2.1 Euler angles to Quaternions . . . . .        | 139        |
| .2.2 Cartesian to spherical coordinates . . . . . | 140        |
| .2.3 Spherical to cartesian coordinates . . . . . | 140        |
| <b>Nomenclature</b>                               | <b>141</b> |
| <b>List of Figures</b>                            | <b>143</b> |
| List of Listings . . . . .                        | 147        |
| <b>List of Algorithms</b>                         | <b>151</b> |
| <b>List of Tables</b>                             | <b>153</b> |
| <b>Bibliography</b>                               | <b>155</b> |



# Chapter 1

## Introduction

### 1.1 Surgical robotics

#### 1.1.1 Historical Overview of Surgical robotics

Surgical robotics is a field of Surgery where the surgeon operates on the patient via a computer, specialised equipment and robotic arms, to which the surgical tools needed for the operation are attached. According to surgical bibliography, robotics and laparoscopic procedures are used in general surgery, cardiothoracic surgeries, colon surgeries, gynecology, neurosurgery and orthopedics.

Robotic mechanisms were first introduced in Medicine, in 1987 with the first laparoscopic surgery of a cholecystectomy. Since then numerous laparoscopic operations have been performed and there has been a lot of improvements and innovations in this field. Such surgical operations are characterised as **minimally invasive**, because the surgical incisions made at the patient are very small and thus the probability of infection of the patient during or after the operation are very small, the hospitalization time is reduced (which means mean better and more efficient use of hospital resources) and the overall recovery of the patient is significantly faster and less painful.

However, traditional laparoscopic mechanisms have some downsides as well. First of all, the surgeon should operate in a mirrored-way, meaning that they should move at the opposite direction from what they saw at the screen (this effect is also known as the **fulcrum effect**), in order to reach the desired point of operation. Earlier laparoscopic tools had less degrees of freedom, which means less flexibility in motion control. Moreover these systems provided limited touch sensibility and feedback to the doctor they were very susceptible to the surgeon's micro movements and tremble.

The first application of robotics in Surgery appears in 1985, when Kwoh et al. [64] used a **PUMA 560**, a standard industrial robotic arm, to perform a neurosurgical biopsy, where the biopsy needle was inserted in the brain and guided with the help of Computed Tomography. This successful application was followed by the **PROBOT** surgical robot [50], which was developed at the Imperial College and used in a prostatectomy operation. Another example of an early surgery robot was the **ROBODOC** system [12] developed by Integrated Surgical Supplies in Sacramento California, which was the first to be used in orthopedics for a hip replacement surgery and was also the first to be approved by the FDA (Food & Drug Administration, organization responsible for medical devices, drugs

etc.).



Figure 1.1: The PUMA 560 robotic arm, which was the first to be used in surgery robotics in 1985

Some other important surgery robots are listed below:

- **AESOP®Endoscope Positioner:** A voice controlled endoscopic system
- **HERMES®Control Center**
- **daVinci Surgical System®:** One of the most popular surgery robots and most used in hospitals. It is a master-slave system, which means that the operation commands are sent uni-directionally from the master console, which is controlled by the surgeon, and are executed by the robot. It also comes with a high definition 3D video feed and advanced manipulator system, one for each hand, called EndoWrist®. It is officially approved by the FDA for laparoscopic surgeries.
- **SOCRATES Robotic Telecollaboration System**
- **Raven-II [30]:** An open platform for collaborative research on surgical robotics.
- **Monarch™Platform** by Auris Health Inc., an endoscopic system for robotic-assisted bronchoscopy

### 1.1.2 Surgical Robotics Procedure

The robotic surgery procedure starts with total anesthesia of the patient. Then the surgeon makes small incisions at the anatomical region of interest, where the procedure will take place. Through these small incisions special tubes, called trocars, are mounted, through which the laparoscopic tools are inserted. After the patient is prepared and after the patient cart, which carries the robotic arms, is successfully positioned and calibrated,

<sup>1</sup><https://www.aurishealth.com/patients/robotic-bronchoscopy-patient-about-monarch-platform>



Figure 1.2: DaVinci Xi, ©2020 Intuitive Surgical, Inc. Patient Cart with the robotic arms that control the surgical tools



Figure 1.3: The Monarch<sup>TM</sup> Platform endoscopic system <sup>1</sup>

the surgeon sits on a console, from where they control the robot via special sensitive joysticks. The surgeon has vision access (often in 3D) to the surgical site via a small endoscopic camera and the video is displayed on the console. In some cases, the surgeon gets force feedback from the joysticks via haptic mechanisms. Haptic force feedback is very important for the doctor in order to have a better sense of the anatomy and the surgical site, and it has gained a lot of interest in the research community.

<sup>2</sup><https://www.intuitive.com/en-us/about-us/press/press-resources>



Figure 1.4: DaVinci Xi ©2020 Intuitive Surgical, Inc. Surgeon Console <sup>2</sup>

### 1.1.3 Advantages & Disadvantages of Surgical robotics

Surgical robotics have a huge impact in Medicine and Healthcare in general. Some of the advantages are the following:

- **Minimally Invasive Procedures** which means
  - Smaller incisions
  - Less blood loss
  - Reduced risk of inpatient infection
  - Less pain
  - Faster patient recovery
- **Increased precision** and reduced human errors
  - Smooth and precise movements
  - Detection and correction of errors caused by hand tremble
- **No fulcrum effect** and intuitive manipulation of surgical tools
- **Haptic feedback.** This technology uses small mechanical forces and vibrations to give the user the sense of touch or force. Force feedback gives the ability to the surgeon to understand the mechanical properties of the tissue they operate on, such as resistance and elasticity, and thus distinguish between healthy from unhealthy tissue
- **Teleoperation** (currently in the same room only): the surgeon operates while they sit on a special **ergonomic** console, which makes the long procedures more comfortable and efficient.

## 1.2 Problem statement

The goal of this thesis is to design the kinematic models and algorithms necessary for a robotic arm to detect, pick and manipulate a laparoscopic surgical tool. To achieve these goals the robotic arm must successfully do the following:

- Use computer vision to detect the scene and laparoscopic tools and with the help of stereoscopic vision, calculate the position and orientation of the center of mass of each tool, with respect to the universal reference frame
- Calculate the contact points on the tool, on which the fingers of the gripper will be placed, so that there is a firm grasp (force closure)
- Calculate the path from the tools' table to the surgical site table
- Calculate the trajectory that needs to be executed when the tool is inserted in the trocar. This is a special type of trajectory, because the motion is constrained and is known in the bibliography as a **Remote Center of Motion** (RCM) control. The constraint is that, at each time one point of the inserted tool must coincide with the RCM point (this point will also be referenced in this thesis as the center of the trocar, or the fulcrum reference frame point).

## 1.3 Bibliography Overview

Surgery robotics, in terms of robot mechanics, can be divided into two categories, specialized surgical robots and generic robotic arms that are programmed for surgical tasks. The specialized surgical robots have specific mechanisms which ensure that the RCM constraint is satisfied mechanically. These robots are easier to control but are only suitable for very specific operations and are usually big in size, with complicated structures that require more maintenance.

A new methodology to do Minimally Invasive Surgical operations is by using industrial robots which are programmable to respect the RCM constraint. This methodology is studied in [49], where a controller is designed to minimize the deviation from the RCM point using kinematics with the dual quaternion framework. A similar approach is studied in [5], where a controller is designed for an active wrist robot to mimic the passive wrist mechanism, which means not exerting pressure on the abdominal wall and respecting the RCM constraint while executing the trajectory with smaller error. This thesis also follows a similar approach, the laparoscopic tool is attached on an active wrist end-effector of a popular non-surgical industrial robot (KUKA lwr iiwa14) and the RCM constraint is satisfied programmatically, i.e. with non specialized mechanisms or a passive wrist.

Minimizing the RCM error is important in order to execute precise trajectories but also to minimize the force exerted to the patient. In paper [4], this deviation error is studied more thoroughly and is used to study the force interaction model of the surgical tool (endoscopic camera) and the abdominal wall. The force that is exerted can be calculated from the fulcrum displacement and the abdominal wall elasticity constant which can be estimated experimentally.

The trajectories that a laparoscopic tool must follow, pivot around the RCM constraint point. This point is also known in the bibliography as the fulcrum point, pivot point, trocar point, incision point. To design a trajectory, this point is assumed to be known, which is generally not the case and the fulcrum point is usually estimated. In [18] an algorithm is proposed that estimates the position of the trocar during a robot-assisted endoscopic surgery. The trocar position is estimated with the Least Square Algorithm which is used to calculate the intersection of surgical tool axes measured from a given number of consecutive robot configurations. A different approach of estimating the Fulcrum point is presented in [28], where the fulcrum point is estimated using an Extended Kalman Filter which uses a stochastic measurement and prediction model and it is able to produce better results even if the measurements are noisy.

When designing a control system for the robot, capable of executing the pivot motions, there are two approaches. The first approach is to directly design a control system whose control parameters adapt to the errors (direct adaptive control) and the second approach is to first estimate the fulcrum parameters or assume they are known and then apply a usual control system (indirect adaptive control). An example of the second approach is studied in [51], where a geometrical estimator is used to estimate the outside penetration of the surgical tool, which is then used in a PI controller and a trajectory generator.

## 1.4 Methodology & Approach

Robotics and especially surgery robotics is a multi-disciplinary field and a robot has many subsystems. A very important approach to successfully design a robotic arm to execute a surgery task is to subdivide the task in multiple smaller submodules and design, implement and test each submodule separately and then combine them together for end-to-end testing.




Figure 1.5: Motion planning pipeline

### Tools & Software used in this thesis:

- Matlab & Matlab toolboxes: ROS Toolbox, Robotics Toolbox

- ROS Framework
- MoveIt
- Gazebo simulator
- VREP simulator
- OpenCV

### Methodology of conducting this thesis:

- Mathematical calculations for Kinematics and Motion planning
- Mathematics validation with Matlab
- Quick prototyping and testing with Matlab and/or VREP
- Implementation in ROS frameworks, by splitting the end-to-end robotic operation in smaller experiments and tasks




Figure 1.6: Kanban view of backlog tasks to organize all features, requirements and tasks needed to complete this thesis. The tool used to keep track of all tasks is Airtable

To quickly test out ideas on how to build the robot's environment and the simulation layout, as well as some simple trajectories, the CoppeliaSim simulator software was used (also known previously as VREP). CoppeliaSim allowed to do quick prototyping using the intuitive drag-and-drop interface and the embedded scripts, before implementing the actual simulation in ROS which is more complex and time-consuming (but also more feature-rich).




Figure 1.7: Quick Prototyping using the VREP (CoppeliaSim) simulation environment

## Chapter 2

# Robotic arm Kinematic Analysis

### 2.1 Robotic arm, DH parameters & Forward Kinematics

The Forward Kinematics problem seeks to specify the way in which the robot's links are connected together. In other words, we want to specify the transformations between every pair of consecutive robot links. It is known that the forward kinematics of a robot can be calculated given only four parameters for each link. These parameters are known in robotics as the **Denavit-Hartenberg** (DH) parameters. Two of these parameters describe the link itself and the other two describe the link's relation to the neighboring link.

- The **length**  $L_i$  of the  $i$ -th link is equal to the distance between the axes  $z_i$  and  $z_{i+1}$
- The **twist angle**  $\alpha_i$  of the  $i$ -th link, is the angle between the axes  $z_i$  and  $z_{i+1}$
- The **rotation angle**  $\theta_i$  of the link  $\{i\}$  with respect to the  $\{i - 1\}$  link, is the angle between the axes  $x_{i-1}$  and  $x_i$
- The **distance**  $d_i$  of the link  $\{i\}$  with respect to the  $\{i - 1\}$  link, is the distance between the axes  $x_{i-1}$  and  $x_i$

| i | $\theta_i$ (rad) | $L_{i-1}$ (m) | $d_i$ (m) | $\alpha_{i-1}$ (rad) |
|---|------------------|---------------|-----------|----------------------|
| 1 | $\theta_1$       | 0             | 0.36      | 0                    |
| 2 | $\theta_2$       | 0             | 0         | $-\pi/2$             |
| 3 | $\theta_3$       | 0             | 0.36      | $\pi/2$              |
| 4 | $\theta_4$       | 0             | 0         | $\pi/2$              |
| 5 | $\theta_5$       | 0             | 0.4       | $-\pi/2$             |
| 6 | $\theta_6$       | 0             | 0         | $-\pi/2$             |
| 7 | $\theta_7$       | 0             | 0         | $\pi/2$              |

The goal of the forward kinematics problem is to find the transformation of the reference frame of the end-effector with respect to the universal reference frame. To achieve that, we must first calculate the transformations between each pair of joints. To simplify each such transformation, i.e. the transformation from a frame  $\{i - 1\}$  to a frame  $\{i\}$ , we consider 3 intermediary reference frames  $\{A\}$ ,  $\{B\}$  and  $\{C\}$ . Then the transformations between the two joints is given by

$${}^{i-1}T_i = {}^{i-1}T_C \cdot {}^C T_B \cdot {}^B T_A \cdot {}^A T_i \quad (2.1.0.1)$$




Figure 2.1: Joint reference frames of the KUKA iiwa14 robot

The matrix  ${}^A T_i$  expresses the translation of the coordinate system  $\{i\}$  with respect to  $\{A\}$  by a distance  $d_i$  along the axis  $z_i$

$${}^A T_i = \begin{bmatrix} 1 & 0 & 0 & 0 \\ 0 & 1 & 0 & 0 \\ 0 & 0 & 1 & d_i \\ 0 & 0 & 0 & 1 \end{bmatrix} \quad (2.1.0.2)$$

The matrix  ${}^B T_A$  expresses the rotation of the coordinate system  $\{A\}$  with respect to  $\{B\}$  by an angle  $\theta_i$  around the axis  $z_i$

$${}^B T_A = \begin{bmatrix} c\theta_i & -s\theta_i & 0 & 0 \\ s\theta_i & c\theta_i & 0 & 0 \\ 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \end{bmatrix} \quad (2.1.0.3)$$

The matrix  ${}^C T_B$  expresses the translation of the coordinate system  $\{B\}$  with respect to  $\{C\}$  by a distance  $L_{i-1}$  along the axis  $x_{i-1}$

$${}^C T_B = \begin{bmatrix} 1 & 0 & 0 & L_{i-1} \\ 0 & 1 & 0 & 0 \\ 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \end{bmatrix} \quad (2.1.0.4)$$

The matrix  ${}^{i-1}T_C$  expresses the rotation of the coordinate system  $\{C\}$  with respect to  $\{i-1\}$  by an angle  $a_{i-1}$  around the axis  $x_{i-1}$

$${}^{i-1}T_C = \begin{bmatrix} 1 & 0 & 0 & L_{i-1} \\ 0 & ca_{i-1} & -sa_{i-1} & 0 \\ 0 & sa_{i-1} & ca_{i-1} & 0 \\ 0 & 0 & 0 & 1 \end{bmatrix} \quad (2.1.0.5)$$

Using the DH parameters of the above table and the product of the above 4 matrices, one can calculate the transformation matrix between two consecutive links, and is calculated as the following

$${}^{i-1}T_i = \begin{bmatrix} c\theta_i & -s\theta_i & 0 & L_{i-1} \\ s\theta_i ca_{i-1} & c\theta_i ca_{i-1} & -sa_{i-1} & -sa_{i-1}d_i \\ s\theta_i sa_{i-1} & c\theta_i sa_{i-1} & ca_{i-1} & ca_{i-1}d_i \\ 0 & 0 & 0 & 1 \end{bmatrix} \quad (2.1.0.6)$$

When all the neighboring transformations are calculated, then one can calculate the total transformation  ${}^0T_N$ , which represents the position and the orientation of the local coordinate system of the end-effector with respect to the global coordinate system of the robot's base. The orientation is the upper-left 3x3 matrix and the position is given by the fourth column of the matrix  ${}^0T_N$ .

$${}^0T_N = {}^0T_1 \cdot {}^1T_0 \cdots {}^{N-1}T_N \quad (2.1.0.7)$$

All transformations  ${}^{i-1}T_i$  are members of a special set of matrices (Lie Group), called **Special Euclidean Group**

$${}^{i-1}T_i \in SE(3) = \left\{ \begin{bmatrix} R & \mathbf{p} \\ \mathbf{0} & 1 \end{bmatrix} : R \in SO(3), \mathbf{p} \in \mathbb{R}^3 \right\}$$

where  $SO(3)$  is another Lie Group called **Special Orthogonal Group**

$$SO(3) = \left\{ R \in \mathbb{R}^{3 \times 3} : R^{-1} = R^\top, \det(R) = 1 \right\}$$

The properties of  $SE(3)$  and  $SO(3)$  are very useful in all the calculations of various transformations because it can reduce the amount of matrix operations and also speeds up the calculation of inverse matrices.

### 2.1.1 End-effector to tool-tip transformations

$${}^7T_{TCP} = \begin{bmatrix} 1 & 0 & 0 & 0 \\ 0 & 1 & 0 & 0 \\ 0 & 0 & 1 & 0.094 \\ 0 & 0 & 0 & 1 \end{bmatrix}$$




Figure 2.2: Approximation of the KUKA iiwa14 workspace, calculated with Forward Kinematics by randomly sampling the value ranges of the joints.




Figure 2.3: Reference frames of last link  $\{7\}$ , end-effector  $\{TCP\}$ , surgical tool base (center of mass)  $\{B\}$  and tool-tip frame  $\{T\}$

$${}^{TCP}T_B = \begin{bmatrix} 1 & 0 & 0 & 0.05 \\ 0 & 0 & -1 & 0 \\ 0 & 1 & 0 & 0 \\ 0 & 0 & 0 & 1 \end{bmatrix}$$

$${}^BT_T = \begin{bmatrix} 1 & 0 & 0 & -0.01 \\ 0 & 1 & 0 & 0.022 \\ 0 & 0 & 1 & 0.455 \\ 0 & 0 & 0 & 1 \end{bmatrix}$$

## 2.2 Inverse Kinematics

The Inverse Kinematics problem is one of the most important problems a roboticist must solve to design trajectories and control the robot's motion to do useful tasks. The IK problem seeks to find those joint values that make the robot's end effector to be at

a specific desired position and orientation or equivalently the input to this problem is the desired pose (position and orientation of the end-effector) and the output are the solutions for the joints. For a robot of six degrees of freedom, i.e. six actuators that move independently and are positioned in such a way so that their axes are not aligned, the solutions to the I.K. problem are typically 8. For robots with more actuators than the 6 degrees of freedom of motion in 3D space (3 for position and 3 for orientation), like the robot of this thesis which has 7 degrees of freedom, the I.K. problem has infinite solutions for a given pose, which means that an additional constraint is required to find a specific solution. This extra degree of freedom is very useful in finding kinematic solutions that are optimal under some circumstances and are also useful in avoiding **singularity points** where the robot loses some degrees of freedom.

### 2.2.1 Decoupling Technique

In this section the inverse kinematics problem is solved for only the 6 out of the 7 total degrees of freedom. The third joint is not used in this analysis and its angle is set to zero  $\theta_3 = 0$ . The rest of the joints form a special kind of kinematic chain that can be solved using the decoupling technique. In this technique the Inverse kinematics problem is split to 2 separate subproblems, one for the position and one for the orientation of the end-effector. This technique can be applied in this case because the axes of the 3 last joints intersect at the same point and they form an Euler wrist.

To solve for the joints' angles, the transformation matrix  ${}^0T_7$  of the end-effector with respect to the robot's base is required. Usually the transformation  ${}^U T_{tcp}$  is known, which is the pose of Tool's center point (TCP) with respect to the Universal Coordinate Frame  $\{U\}$  from which the required  ${}^0T_7$  can be calculated

$${}^U T_{tcp} = {}^U T_0 \ {}^0 T_7 \ {}^7 T_{tcp} \quad (2.2.1.1)$$

$${}^0 T_7 = {}^U T_0^{-1} \ {}^U T_{tcp} \ {}^7 T_{tcp}^{-1} \quad (2.2.1.2)$$

$${}^0 T_7 = \begin{bmatrix} R_t & \mathbf{p}_t \\ 0 & 1 \end{bmatrix} \quad (2.2.1.3)$$

where  ${}^U T_0$ ,  ${}^7 T_{tcp}$  are translation transformations by a constant distance and  $R_t$ ,  $\mathbf{p}_t$  are the target's orientation and position respectively.

$${}^0 \mathbf{p}_5 = {}^0 T_4 {}^4 \mathbf{p}_5 = \begin{bmatrix} p_x \\ p_y \\ p_z \end{bmatrix} \quad (2.2.1.4)$$

$$\theta_1 = \begin{cases} \text{atan2}(p_y, p_x) \\ \pi - \text{atan2}(p_y, p_x) \end{cases} \quad (2.2.1.5)$$

$$\varphi = \text{acos} \left( \frac{d_3^2 + \|{}^1 \mathbf{p}_5\|^2 - d_5^2}{2d_3 \|{}^1 \mathbf{p}_5\|} \right) \quad (2.2.1.6)$$

$$\theta_2 = \text{atan2} \left( \sqrt{p_x^2 + p_y^2}, {}^1 p_{5z} \right) \pm \varphi \quad (2.2.1.7)$$




Figure 2.4: Calculation of angles \$\theta\_2, \theta\_4\$

$$c_4 = \frac{\|{}^1p_5\|^2 - d_3^2 - d_5^2}{2d_3d_5}$$

$$\theta_4 = \text{atan2}\left(\pm\sqrt{1 - c_4^2}, c_4\right) \quad (2.2.1.8)$$

Once \$\theta\_1, \theta\_2, \theta\_3, \theta\_4\$ are known, the orientation matrix of the wrist can be calculated as following

$$R_{target} = \begin{bmatrix} i_x & j_x & k_x \\ i_y & j_y & k_y \\ i_z & j_z & k_z \end{bmatrix}$$

$$\theta_6 = \text{atan2}\left(\pm\sqrt{1 - k_y^2}, k_y\right) \quad (2.2.1.9)$$

$$\theta_7 = \text{atan2}(-j_y, i_y)$$

$$\theta_5 = \text{atan2}(-k_z, k_x)$$

## 2.2.2 Solutions for 7DoF numerically

To solve numerically for the joint angles, we use a relationship between the derivative of the spatial coordinates and the joint derivatives. These two vectors are related by a matrix known as the **Jacobian** and is given by the following equation

$$\dot{\mathbf{x}} = J(\mathbf{q})\dot{\mathbf{q}} \quad (2.2.2.1)$$

where




Figure 2.5: The first 4 out of 8 solutions of the Inverse Kinematics problem, using the decoupling technique

$$J(\mathbf{q}) = \begin{bmatrix} \frac{\partial \mathbf{f}_1(\mathbf{q})}{\partial q_1} & \dots & \frac{\partial \mathbf{f}_1(\mathbf{q})}{\partial q_7} \\ \vdots & \ddots & \vdots \\ \frac{\partial \mathbf{f}_6(\mathbf{q})}{\partial q_1} & \dots & \frac{\partial \mathbf{f}_6(\mathbf{q})}{\partial q_7} \end{bmatrix} \quad (2.2.2.2)$$

and the functions  $\mathbf{f}_i(\mathbf{q})$  are calculated using the robot's forward kinematics.

$J(\mathbf{q})$  is non rectangular and thus non-invertible, due to the extra degree of freedom. Instead of the inverse of the Jacobian the pseudoinverse is calculated which by the equation

$$J^\dagger = J^\top (JJ^\top)^{-1} \quad (2.2.2.3)$$

---

**Algorithm 1:** Newton-Raphson numerical method

---

```

initialize  $\mathbf{q}^0 \in \mathbb{R}^7$  with an initial guess, given a desired position and orientation
 $\mathbf{x}_d \in \mathbb{R}^6$ ;
set error  $e = \mathbf{x}_d - f(\mathbf{q}^i)$ ;
set error tolerance  $\varepsilon$  with some small value;
while  $e \geq \varepsilon$  do
| set  $\mathbf{q}^{i+1} = \mathbf{q}^i + J^\dagger(\mathbf{q})e$ ;
|  $i \leftarrow i + 1$ ;
end
```

---

If the numerical method has more than one solutions, then the method will converge to the one which is closest to the initial guess or it will not converge at all, if the initial error is too big. One way to get some approximate initial guesses is if we use a solution from the previous section (which solves for 6 dof) and use these solutions as input to this numerical method.

The numerical calculation of the inverse kinematics can also be calculated using the geometric Jacobian, given by the following equation

$$\begin{aligned}
J_v &= J_v(\mathbf{q}) = [J_{v1}, J_{v2}, \dots, J_{v7}] \in \mathbb{R}^{6 \times 7} \\
J_i &= \begin{bmatrix} {}^0\mathbf{z}_i \times ({}^0\mathbf{p}_8 - {}^0\mathbf{p}_i) \\ {}^0\mathbf{z}_i \end{bmatrix}
\end{aligned} \quad (2.2.2.4)$$

### 2.2.3 Constraints & Singularity points

#### 2.2.3.1 Workspace constraints & Singularity points

When studying the kinematics of a robotic arm it is very crucial to also study the singularity points, which must be known before path planning in order to be avoided as much as possible. From a mathematical point of view, singularity points are points or set of points where the kinematics equations are not defined, e.g. when dividing by a quantity that becomes zero or is very close to zero or when the determinant of the robot's Jacobian approaches zero (as shown in figure 5.2), or even when the inverse kinematics solutions are infinite.

From a more empirical point of view, singularity points are those points that reduce the kinematic capability of the robot. An example of that are points where the end-effector cannot move at all or it cannot move in some directions. An other example of singularity points, are those in which small displacements/velocities in the taskspace require very large displacements/velocities in the joint space and sometimes with velocities much higher than the rated values of the actuators.




Figure 2.6: KUKA iiwa LBR14 workspace dimensions

Singularity points:

- When  $p_x^2 + p_y^2 = 0$  then the end-effector lies on the z-axis and  $\theta_1$  is not defined
- Similar to the above singularity, when the axes  $z_1, z_7$  coincide, then  $\theta_1, \theta_7$  can no longer be defined
- When  $\sin(\theta_6) = 0$  then the angles  $\theta_5, \theta_7$  are not defined. According to the robot's manual and the equations of inverse kinematics above, there are an infinite number of combinations of  $\theta_5, \theta_7$  to get the same position on the end-effector.
- Similar to the above singularity, when the shoulder is fully extended,  $\theta_1$  and  $\theta_3$  are not defined (there are infinite combinations for the same result)

Other kinematic singularities that are explained in more details KUKA Sunrise.OS 1.11 manual are the following:

- Extended position  $\theta_4 = 0$ : motion is blocked in the direction of  $z_3$  and  $z_5$  axes
- When  $\theta_4 = \frac{\pi}{2}$  and  $\theta_6 = 0$  the motion parallel to  $z_6$  or  $z_2$  is blocked
- When  $\theta_2 = 0$  and  $\theta_3 = \pm\frac{\pi}{2}$  the motion is blocked in the direction of the robot or parallel to axes  $z_2, z_5$
- When  $\theta_5 = \frac{\pi}{2}$  and  $\theta_6 = 0$  the motion parallel to axis  $z_6$  is blocked

### 2.2.3.2 Remote Center of Motion constraint

The most common characteristic in the kinematics of all Minimally Invasive Surgery robotics platforms is the Remote Center of Motion (RCM) constraint. The RCM point, also known in the bibliography as fulcrum point, trocar point, incision point and/or insertion point, is a virtual point in space around which the robot is constrained to rotate (pivot). The RCM constraint means that at all times one point along the axis of the surgical tool must coincide with the RCM point. This constraint reduces the number of degrees of freedom from 6 (position and orientation in Cartesian 3D space) to only 4:

1. **insertion** and **retraction**: translation along the  $\hat{\mathbf{r}}$  vector of the spherical coordinate system of the Fulcrum Reference frame
2. **roll**, also known as pan: rotation around the  $\hat{\mathbf{z}}$  unit vector by an angle  $\phi$
3. **pitch**, also known as tilt: rotation around the  $\hat{\mathbf{y}}$  unit vector by an angle  $\theta$
4. **yaw**, also known as spin: rotation around the  $\hat{\mathbf{x}}$  unit vector by an angle  $\psi$




Figure 2.7: Illustration of pivoting motion of surgical laparoscopic tool around RCM point (also known as fulcrum or trocar point). Due to the RCM constraint, the tool has only 4 degrees of freedom.

The RCM constraint does not have a direct implication in the solutions of the inverse kinematics solution, because it only reduces the taskspace to a very specific subspace and a very specific set of robot positions and orientations.

To satisfy the RCM constraint many MIS robots have special mechanical structures that make it easier for the laparoscopic tools to pivot around the fulcrum point. The most common examples of these types of mechanisms are parallelograms, spherical linkages and circular tracking arcs, all of which have usually 2 RCM degrees of freedom which are either decoupled or coupled. Other types of RCM mechanisms are isocenters, synchronous belt transmission, parallel manipulators, passive RCMs and compliant mechanisms. All these structures are more thoroughly described in article [43]. In the simulation setup of this thesis there is no special RCM mechanism to satisfy the RCM constraint. A typical industrial robot arm is used and the RCM constraint is satisfied by calculating at each time the correct pose the robot must have which is used as input to the Inverse Kinematics problem. To achieve this, the RCM point must be known beforehand (or be estimated) and then all RCM poses are calculated using a spherical

coordinate system, whose origin of axes is the RCM point.

### 2.2.3.3 Elbow-up constraint

The inverse kinematic problem usually outputs 8 different solutions, all of which satisfy the same target position and orientation for the end-effector, but with different arm configurations (see figures 2.4 and 2.8). These solutions offer more flexibility to each case, and a different solution is chosen based on the conditions (e.g. previous robot pose) and requirements (e.g. collision avoidance). In this thesis, there are 2 distinct use cases in terms of choosing a specific robot configuration picking the surgical tools from one table, which does not impose any constraint and the insertion and pivoting of the surgical tool at the mounting dock, which imposes the RCM constraint (see 2.2.3.2) and a constraint to of collision avoidance between the robot arm and the mounting dock. In the latter use case, in order to satisfy the collision avoidance, all path planning kinematic solutions must be in a elbow-up configuration at all times.

Observing the screenshots at 2.8, there are 2 ways to mathematically describe the elbow-up constraint (see figure 2.9 below), either using distance between the robot base and the 3rd link or by using the relative angle of the base link and the 3rd link. From the iiwa14 specifications, the following calculations are done using  $d_1 = 360\text{mm}$  and  $d_3 = 420\text{mm}$ .

The distance constraint is

$$d_{min} \leq d \leq d_{max} \quad (2.2.3.1)$$

where

$$d_{min} = \sqrt{d_1^2 + d_3^2} = 553\text{mm} \quad \text{and} \quad d_{max} = d_1 + d_3 = 780\text{mm}$$

The distance-based description of the elbow-up constraint is not very convenient, because it can not be easily forward-transformed to a description that uses the robot's forward kinematic transformations and reference frames, but it can be easily used after the inverse kinematics solution to check which solutions satisfy this distance constraint. The angle-based description can sometimes be more convenient because it directly describes the orientation that the 3rd reference frame must have, with respect to the reference frame of the base. Thus for each orientation angle (pitch, yaw, roll) the following constraint must be satisfied.

$$-\frac{\pi}{2} \leq \theta \leq \frac{\pi}{2} \quad (2.2.3.2)$$

When the inverse kinematics problem is solved, then some of the solutions may be rejected from the elbow-up constraint after the following calculations. For each solution the forward kinematics up to the 3rd joint must be calculated. Note that although the forward kinematics from the universal frame to the end-effector should be the same for all solutions, the same does not hold for the forward kinematic transformations of the intermediate links.

$${}^U T_{tcp} = {}^U T_0 \ {}^0 T_3 \ {}^3 T_{tcp} \quad (2.2.3.3)$$




Figure 2.8: Top: elbow-down solution, bottom: elbow-up solution

$${}^0T_3 = {}^U T_0^{-1} {}^U T_{tcp} {}^3 T_{tcp}^{-1} \quad (2.2.3.4)$$

Let the calculated  ${}^0T_3$  have the following form

$${}^0T_3 = \begin{bmatrix} {}^0R_3 & {}^0\mathbf{p}_3 \\ 0 & 1 \end{bmatrix} \quad (2.2.3.5)$$

then the distance that must satisfy the inequality 2.2.3.1 is

$$d = \|{}^0\mathbf{p}_3\| \quad (2.2.3.6)$$

In a similar way, the angle version of the elbow-up constraint can be used to check if a solution is accepted. Let the orientation matrix  ${}^0R_3$  of the calculated pose  ${}^0T_3$  have the




Figure 2.9: Elbow-up constraint description with relative distance or angle between links with lengths  $d_1$  and  $d_3$

following form

$${}^0 R_3 = [{}^0 \hat{\mathbf{x}}_3 \quad {}^0 \hat{\mathbf{y}}_3 \quad {}^0 \hat{\mathbf{z}}_3] \quad (2.2.3.7)$$

then the angle that must satisfy the inequality 2.2.3.2 is

$$\theta = \arccos \left( \frac{{}^0 \hat{\mathbf{z}}_3 \cdot {}^0 \hat{\mathbf{z}}}{{}^0 \hat{\mathbf{z}}_3 \| {}^0 \hat{\mathbf{z}} \|} \right) \quad (2.2.3.8)$$

where  ${}^0 \hat{\mathbf{z}}$  is the unit vector of the z-axis of the frame  $\{0\}$  with respect to itself, i.e.  ${}^0 \hat{\mathbf{z}} = [0, 0, 1]^T$



# Chapter 3

## Grasping

### 3.1 Gripper & Forward Kinematics




Figure 3.1: Barrett Hand gripper (model BH8-282) dimensions

| i       | $\theta_i$ (rad)      | $L_{i-1}$ (m) | $d_i$ (m) | $\alpha_{i-1}$ (rad) |
|---------|-----------------------|---------------|-----------|----------------------|
| 1 (J11) | $\theta_{11} - \pi/2$ | 0.025         | 0.0034    | 0                    |
| 2 (J12) | $\theta_{12} + 0.04$  | 0.05          | 0         | $\pi/2$              |
| 3 (J13) | $\theta_{13} + 0.69$  | 0.07          | 0         | 0                    |

| i       | $\theta_i$ (rad)      | $L_{i-1}$ (m) | $d_i$ (m) | $\alpha_{i-1}$ (rad) |
|---------|-----------------------|---------------|-----------|----------------------|
| 1 (J21) | $\theta_{21} - \pi/2$ | 0.025         | 0.0034    | 0                    |
| 2 (J22) | $\theta_{22} + 0.04$  | 0.05          | 0         | $\pi/2$              |
| 3 (J23) | $\theta_{23} + 0.69$  | 0.07          | 0         | 0                    |




Figure 3.2: Coordinates systems for forward kinematics for a generalized finger of the gripper

| i       | $\theta_i$ (rad)     | $L_{i-1}$ (m) | $d_i$ (m) | $\alpha_{i-1}$ (rad) |
|---------|----------------------|---------------|-----------|----------------------|
| 1       | $\pi/2$              | 0             | 0.0034    | 0                    |
| 2 (J32) | $\theta_{32} + 0.04$ | 0.05          | 0         | $\pi/2$              |
| 3 (J33) | $\theta_{33} + 0.69$ | 0.07          | 0         | 0                    |

### 3.2 Gripper Inverse Kinematics

The following Inverse Kinematics analysis refers to one finger of the Barrett Hand gripper, which has 3 revolute joints. Finger 3 has only 2 revolute joints for which the angle solutions are the same with the solutions of the last 2 joints of the other fingers.




Figure 3.3: Top view of one of the 3 fingers of the gripper with 3 joints (RRR kinematic chain)

Let

$$\mathbf{p} = \begin{bmatrix} p_x \\ p_y \\ p_z \end{bmatrix}$$

be the position of the grasp point for one finger. The first angle can easily be calculated using the top view of the figure 3.3 from the following equation

$$\varphi_1 = \text{atan2}(p_y, p_x) \quad (3.2.0.1)$$




Figure 3.4: Side view of one of the 3 fingers of the gripper with 3 joints (RRR kinematic chain)

$$BD = L_3 \cos(\varphi_3 + \frac{2\pi}{9}) \quad (3.2.0.2)$$

$$BC = L_3 \sin(\varphi_3 + \frac{2\pi}{9}) \quad (3.2.0.3)$$

$$p_{xy} = \sqrt{p_x^2 + p_y^2} \quad (3.2.0.4)$$

Next, we calculate the third angle based on the law of cosines applied on the triangle  $ACD$  (see figure 3.4)

$$\cos\left(\pi - \varphi_3 - \frac{2\pi}{9}\right) = \frac{L_2^2 + L_3^2 - p^2}{2L_2L_3} \quad (3.2.0.5)$$

$$\cos\left(\varphi_3 + \frac{2\pi}{9}\right) = \frac{p^2 - L_2^2 - L_3^2}{2L_2L_3} \quad (3.2.0.6)$$

$$\varphi_3 = \text{atan2}\left[\pm\sqrt{1 - \left(\frac{p^2 - L_2^2 - L_3^2}{2L_2L_3}\right)^2}, \frac{p^2 - L_2^2 - L_3^2}{2L_2L_3}\right] - \frac{2\pi}{9} \quad (3.2.0.7)$$

In a more general case, the first argument of the *atan2* function in the expression of  $\varphi_3$  could also be negative, but in this case this second solution is rejected, because due to mechanical constraints, this angle can't be negative. After having calculated  $\varphi_3$  we can calculate  $\varphi_2$

$$\tan(\psi + \varphi_2) = \frac{p_z}{\sqrt{p_x^2 + p_y^2}} \quad (3.2.0.8)$$

$$\psi + \varphi_2 = \text{atan2}\left(p_z, \sqrt{p_x^2 + p_y^2}\right) \quad (3.2.0.9)$$

$$\tan(\psi) = \frac{L_3 \sin\left(\varphi_3 + \frac{\pi}{4}\right)}{L_2 + L_3 \cos\left(\varphi_3 + \frac{\pi}{4}\right)} \quad (3.2.0.10)$$

$$\varphi_2 = \text{atan2}\left(p_z, \sqrt{p_x^2 + p_y^2}\right) - \text{atan2}\left[L_3 \sin\left(\varphi_3 + \frac{2\pi}{9}\right), L_2 + L_3 \cos\left(\varphi_3 + \frac{2\pi}{9}\right)\right] \quad (3.2.0.11)$$

### 3.3 Force closure

In order to achieve a firm grasp of the surgical tool, the gripper fingers must be positioned in such a way around the object so that there is **force closure**. According to the **Nguyen** theorem, a planar object that is constrained by 2 points, is in force closure if the line which connects the two constraint points lies inside both friction cones of these points. A simplistic explanation of a friction cone is that it is a set of forces that result the contact point to be in friction and all other forces outside of the cone will result in sliding.

For the three dimensional case, a spatial body which is constrained by 3 contact points. These 3 contact points have friction and they define a unique plane  $S$  and also the 3D friction cone of each point intersects the plane  $S$  in a 2D cone. Then the spatial body is in force closure if and only if the plane  $S$  is in a planar force closure group.

To check for force closure, one must know the contact points and the direction of the forces that are applied there. In the Gazebo simulator program that was used in this thesis, the information of the contact between a gripper's finger and an object is easily available as shown in listing 3.2. However this kind of information is much harder to acquire in real scenarios. The Barrett gripper that is used in this thesis comes with arrays of tactile sensors in each surface of the gripper and there are methodologies to use these spatially distributed sensors to approximate the intensity as well as and most importantly the direction of the forces [45].

Listing 3.1: Example ROS message with collision/contact information between one finger of the gripper and one surgical tool

```

header:
  seq: 327978
  stamp:
    secs: 564
    nsecs: 468000000
  frame_id: "world"
states:
-
  info: "Debug: geom:surgical_tool4::surgical_tool_link::collision ..."
  collision1_name: "surgical_tool4::surgical_tool_link::collision"
  collision2_name: "robot::bh_finger_33_link::bh_finger_33_link_collision"
  wrenches:

```

```

-
  force:
    x: -1.42463913929e-91
    y: 1.47711790023e-91
    z: -1.58225043603e-91
  torque:
    x: 5.44545932609e-93
    y: -3.73283810062e-93
    z: -8.38783555513e-93
total_wrench:
  force:
    x: -1.42463913929e-91
    y: 1.47711790023e-91
    z: -1.58225043603e-91
  torque:
    x: 5.44545932609e-93
    y: -3.73283810062e-93
    z: -8.38783555513e-93
contact_positions:
-
  x: -0.00130886196029
  y: -0.587570558845
  z: 1.0584908858
contact_normals:
-
  x: 0.041868681791
  y: -0.00620219851863
  z: -0.999103871586
depths: [4.625789111756262e-07]

```

Listing 3.2: Example values from the Barrett Hand tactile array. Units N/cm<sup>2</sup> message type: bhand\_controller/TactArray [https://github.com/RobotnikAutomation/barrett\\_hand/tree/kinetic-devel/bhand\\_controller](https://github.com/RobotnikAutomation/barrett_hand/tree/kinetic-devel/bhand_controller)

```

header:
seq: 15277
stamp:
  secs: 1408685936
  nsecs: 928946018
frame_id: ""
finger1: [
  0.09000000357627869, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0,
  0.0, 0.0, 0.0, 0.0, 0.019999999552965164, 0.009999999776482582,
  0.0, 0.009999999776482582, 0.0, 0.0, 0.019999999552965164,
  0.0, 0.03999999910593033, 0.0,
]
finger2: [
  0.0, 0.019999999552965164, 0.0, 0.03999999910593033, 0.029999999329447746,
  0.029999999329447746, 0.019999999552965164, 0.019999999552965164,
  0.029999999329447746, 0.019999999552965164, 0.019999999552965164,
  0.019999999552965164, 0.029999999329447746, 0.029999999329447746,
  0.07000000029802322, 0.09000000357627869, 0.0, 0.09000000357627869,
  0.009999999776482582, 0.019999999552965164, 0.05999999865889549,
  0.009999999776482582, 0.0, 0.03999999910593033,
]

```

```
finger3: [
    0.0, 0.0, 0.0, 0.0, 0.019999999552965164, 0.029999999329447746,
    0.0, 0.0, 0.019999999552965164, 0.0, 0.009999999776482582,
    0.029999999329447746, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0,
    0.0, 0.019999999552965164, 0.0, 0.0, 0.0,
]
palm: [
    0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0,
    0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0,
]
```

## Chapter 4

# Scene and object recognition with Computer Vision

At this section we explore ways to detect and recognize the surgical tools as well as other objects of the simulation scene. To reduce the complexity of this thesis and focus on the more important features of this thesis, we assume in the simulation that the surgical tools are blue and the mounting dock, where the tools will be placed, is green. These assumptions make the scene and object recognition much easier without the need of more advanced image processing and/or machine learning recognition algorithms.

**Camera setup** used in this thesis:

- 2 HD RGB cameras with resolution  $1280 \times 720$
- near clipping plane: 0.02
- far clipping plane: 300
- horizontal FoV (field of view): 1.396
- update rate: 30fps

### 4.1 Laparoscopic tool detection

In order to detect the shape of the tool there are some standard steps that need to be executed. After having loaded the input image we convert it to grayscale, so that we can work on only one channel instead of 3 color channels and thus reduce the amount of calculations. Also for the purposes of extracting the shape of an object, the color doesn't have a very significant role in the algorithm. Next step is to remove the unwanted noise. In this thesis we only assume that the video frames have only Additive White Gaussian Noise (AWGN). To remove some of the noise we use a moving average filter (the filter is also known as a kernel), which is convoluted around the whole image. The filter that was used is the following 3-by-3 matrix

$$h = \frac{1}{9} \begin{bmatrix} 1 & 1 & 1 \\ 1 & 1 & 1 \\ 1 & 1 & 1 \end{bmatrix}$$

the output, filtered image is the result of the convolution of the image with the filter and is calculated as following

$$g(i, j) = \sum_{k,l} f(i + k, j + l)h(k, l) \quad (4.1.0.1)$$

where  $g(\cdot, \cdot)$  is the output image and  $f(\cdot, \cdot)$  is the input image.

After the noise is removed the image is getting binarized. To do that, we set a threshold, below which the pixels will be black and the rest will be white. This conversion to binary format, makes it easier to extract the boundaries of the black shapes, which will correspond to the boundaries of the objects of the initial image.




Figure 4.1: Simple tool detection in simulation based on color, using OpenCV. The green polygon is the convex hull, and the red point is the estimated center of mass

## 4.2 Stereoscopic vision




Figure 4.2: Disparity image calculated from the 2 cameras




Figure 4.3: Point cloud of surgical tools, generated from the 2 cameras and visualized in RViz

## 4.3 Calculation of tool position and orientation

In order for the gripper to grasp correctly the laparoscopic tool, it is required to calculate the tool's position and orientation in the pixel space which must then be converted with

respect to the robot's workspace. From all the pixels that have been classified as part of the laparoscopic tool, one can estimate the center of mass and two perpendicular vectors attached to that point that define the orientation. The center of mass is simply the average of the  $(x, y)$  coordinates of all the tool's pixels

$$(\bar{x}, \bar{y}) = \left( \frac{1}{N} \sum_{i=1}^N x_i, \frac{1}{N} \sum_{i=1}^N y_i \right) \quad (4.3.0.1)$$

The easiest way to calculate the center of mass is by calculating the average using the first moments of the contour points. However, since the contour is only using the boundary of the object and not it's area, this method is not very accurate. To get a more accurate value for the center of mass, one must use the pixels that are inside the detected object's contour. The simplest way (but most expensive) to get the inside pixels of the tool is to loop over all the pixels and for each pixel check if it is inside the polygon (point inside polygon test). To make this method even faster, one can take a sample of the total pixels, for example check one in every 10 pixels in the x and y coordinates, which means reducing the time complexity to one tenth.

Taking this approach a step further in optimization, one can iterate not in all the video frame pixels but only those pixels that are inside the **Region of Interest** of the tool. The Region of Interest, also known as ROI, is a widely used structure in computer vision and is simply a bounding box (rectangle) that fits exactly (or is a bit bigger than) an object or part of the image frame that we want to study. Having already calculated the contour of the surgical tool and it's convex hull we can easily calculate this bounding box. For this calculation we prefer to use the convex hull, because it often contains much less pixels than the contour. We iterate over all the pixels of the convex hull and we get the minimum and maximum x and y coordinates. The combination of these four values is the desired ROI. Since we now have access to the tool's ROI, we can iterate and sample the pixels inside it (and not all pixels as we did before) to get some of the pixels of the tool so that we can more accurately calculate it's center of mass and orientation vectors.

The two orientation vectors are the eigenvectors of the covariance matrix of the above pixels. Let  $\mathbf{a}, \mathbf{b}$  be the orientation vectors, then  $\mathbf{a}, \mathbf{b}$  are solutions of the equation

$$\mathbf{Cv} = \lambda \mathbf{v} \quad (4.3.0.2)$$

where  $\mathbf{C}$  is the covariance matrix given by

$$\mathbf{C} = \begin{bmatrix} \sigma(x, x) & \sigma(x, y) \\ \sigma(y, x) & \sigma(y, y) \end{bmatrix} \quad (4.3.0.3)$$

$$\sigma(x, y) = \frac{1}{n - 1} \sum_{i=1}^N (x_i - \bar{x})(y_i - \bar{y}) \quad (4.3.0.4)$$

## 4.4 Calculation of grasping points




Figure 4.4: Estimation of tool's pose (position and orientation). The red dot is the center of mass and attached to that are the two orientation vectors of the tool. The green polygon is the convex hull of the tool and the white rectangle is it's ROI as calculated from the convex hull




Figure 4.5: Finding candidate grasping points from the intersections of a growing circle and the contour of the detected surgical tool

The calculation of the candidate grasping points is a problem where we seek to find the points that lie on the contour of the detected object such that the gripper can make a good grasp of the object and preferably with force closure. The method that was implemented in this thesis for a simplistic calculation of these points is by using a **growing circle**. This circle is initiated with a small radius and has at all times its center at the center of mass of the detected tool. At each step of the method the radius is incremented by a fixed amount and then we check if this circle has any intersection with the contour of the detected tool. If no intersection is found the method proceeds with a new radius. The method is terminated when at least 3 intersections are found, and that's because the gripper that is used in this thesis has three fingers.

$$\mathbb{G} = \arg \max_{(x,y)} I_1(x,y) \odot I_2(x,y) \quad (4.4.0.1)$$

At the equation 4.4.0.1, the set of intersection points  $\mathbb{G}$  is calculated. Given one binary image  $I_1(x,y)$  which contains the contour of the detected tool (all white pixels are the contour) and one second binary image  $I_2(x,y)$  which contains the growing circle, then the set of intersection points are the  $(x,y)$  coordinates where the Hadamard product  $I_1(x,y) \odot I_2(x,y)$  (element-wise product) of the two binary images is maximum (or equivalently has a value of 1).

It is often the case that for one intersection multiple pixels are returned from this method due to the "pixelated nature" of all curves. To filter all these pixels and get only one pixel for each intersection point we initialize a list of the final points with the first pixel found and then iterate over all of the other pixels. For each pixel we check if it has a Manhattan distance bigger than a threshold (e.g. 10) from the pixels that are already added in the list of the final pixels. If two pixels have a Manhattan distance bigger than a selected threshold then we consider them to be two different intersection points. The Manhattan distance of two points  $\mathbf{p}_1 = (x_1, y_1)$ ,  $\mathbf{p}_2 = (x_2, y_2)$  is given by

$$d_1(\mathbf{p}_1, \mathbf{p}_2) = |x_1 - x_2| + |y_1 - y_2| \quad (4.4.0.2)$$

## 4.5 Trocar detection & Estimation of fulcrum point

The detection of the trocar, which is a small tube through which the surgical tool is inserted, is accomplished using a similar simple trivial detection algorithm as the one used in 4.1




Figure 4.6: Simple trocar detection in simulation based on color, using OpenCV. In simulation, the trocar is simply considered to be a small cylindrical hole and its center is the fulcrum point

# Chapter 5

## Path Planning

**Path Planning** is a geometric problem, where it is desired to find a path from a starting point to a goal point and also satisfying a set of constraints, such as: restricting the solutions inside the robot's configuration space, avoiding obstacles in the task space, avoiding singularity points and respecting the robot's joint limits.

### 5.1 Sampling methods

The path planning algorithms that were mostly used in this thesis belong to the category of sampling methods. These methods use random functions to choose a sample from the configuration space or the state space. Sampling methods differ from the deterministic grid methods which, which discretize the whole space. Sampling methods are less computationally expensive than the grid methods, but they do not deliver optimal solutions like the latter.

#### 5.1.1 RRT Algorithms

The **Rapidly-exploring Random Trees** algorithm is a sampling planning method that searches for an obstacle-free motion plan from an initial state  $x_{init}$  to a set of goal states  $\mathcal{X}_{goal}$ . We refer to a set of goal states, because apart from the one desired goal state there can be other neighbor states that are within the allowed position and orientation

tolerances.

---

**Algorithm 2:** RRT Algorithm

---

```

foreach replanning attempt do
    initialize vertices  $V \leftarrow \{x_{init}\}$ ;
    initialize edges  $E \leftarrow \emptyset$ ;
    initialize search tree  $T \leftarrow (V, E)$ ;
    while  $time \leq maxPlanningTime$  do
         $x_{rand} \leftarrow \text{getSampleStateFrom}(\mathcal{X})$ ;
         $x_{nearest} \leftarrow \text{getNearestNodeInTreeToState}(T, x_{rand})$ ;
         $x_{new} \leftarrow \text{findLocalPlanFromTo}(x_{nearest}, x_{rand})$ ;
        if  $\text{isPathCollisionFree}(x_{nearest}, x_{rand})$  then
             $V \leftarrow V \cup \{x_{new}\}$ ;
             $E \leftarrow E \cup \{(x_{nearest}, x_{rand})\}$ ;
            if  $x_{new} \in \mathcal{X}_{goal}$  then
                return SUCCESS and path plan  $T = (V, E)$  ;
            end
        end
    end
end
return FAILURE and  $T = (V, E)$  ;

```

---

Other variations of the RRT Algorithm, which are also available in the OMPL library, included in the MoveIt library of ROS framework are:

- **TRRT** Transition-based RRT
- **BiTRRT** Bidirectional Transition-based RRT
- **RRT\***
- **RRTConnect** with is the default OMPL path planner in ROS
- **LBTRRT** Lower Bound Tree RRT

### 5.1.2 PRM Algorithms

The **Probabilistic Roadmap** (PRM) algorithm is a sampling planning method that constructs a roadmap representation of  $\mathcal{C}_{free}$  **before searching** for a solution. After the roadmap is successfully built, then the algorithm searches for a solution using a traditional graph-based search algorithm. A very important aspect of this algorithm is how the sampling of the free configuration space will be done. The sampling is usually performed using a uniform distribution except from the regions close to objects where

the sampling is more dense.

---

**Algorithm 3:** PRM roadmap construction (preprocessing phase)

---

```

initialize vertices  $V \leftarrow \{x_{init}\}$ ;
initialize edges  $E \leftarrow \emptyset$ ;
initialize roadmap graph  $G \leftarrow (V, E)$ ;
for  $i = 1, \dots, n$  do
     $x_{rand,i} \leftarrow \text{getSampleStateFrom}(\mathcal{X})$ ;
     $\mathcal{N}(x_{rand,i}) \leftarrow \text{getKNearestNeighbors}(G = (V, E), x_{rand,i})$ ;
     $V \leftarrow V \cup \{x_{rand,i}\}$ ;
    foreach  $x \in \mathcal{N}(x_{rand,i})$  do
        if there is no edge between  $x$  and  $x_{rand,i}$  then
            if  $\text{isPathCollisionFree}(x_{nearest}, x_{rand,i})$  then
                 $E \leftarrow E \cup \{(x_{rand,i}, x), (x, x_{rand,i})\}$ 
            end
        end
    end
end
return  $G = (V, E)$ 
```

---

Other variations of the PRM Algorithm, which are also available in the OMPL library, included in the MoveIt library of ROS framework are:

- PRM\*
- LazyPRM
- LazyPRM\*

## 5.2 Pick and place algorithm

---

**Algorithm 4:** Pick and Place algorithm

---

```

foreach surgical tool do
    /* Plan the Pick pipeline */  

    set grasp pose;  

    set pre-grasp approach;  

    set post-grasp retreat;  

    set posture of eef before grasp (open gripper);  

    set posture of eef during grasp (closed gripper);
    /* Plan the Place pipeline */  

    set place location pose;  

    set pre-place approach;  

    set post-grasp retreat;  

    set posture of eef after placing object;  

    Plan pick and place paths;
end
```

---

If the pick and place algorithm targets small objects, such as cubes or spheres or other small convex objects then the path planning is straightforward. In the case where, the object to pick and place has at least one dimension that is bigger than the others like a rod or other long objects, such as the surgical tools, used in this thesis, then the path

planning becomes more complicated, because of the almost certain collisions of the tool with the links of the rest of the robot (the link of the end-effector will probably not collide with the tool).

### 5.3 Task space analysis

Before designing any paths and trajectories it is very important to better understand the taskspace in which the surgical tool will operate in. When the robot arm is in the pick-and-place phase where it detexts the surgical tool and grasps and then go to the mounting dock to insert it, then at this phase, the taskspace is the same as the robot's taskspace. However, when the surgical tool is inserted in the patient's body and starts executing pivoting motions, then there are 2 taskspaces that are studied. The first one is the surgical taskspace, which is where the surgical movements are planned (sutures, laparoscopic camera movements etc.) and the second taskspace is the one outside of patient's body in which the planned paths are "mirrored" so that the robot can execute them. The surgical taspace  $\mathbb{S}$  is the one shown in figure 5.3. The paths inside the surgical task are transformed via the Fulcrum effect transformation, which is described in more detail in 6.1, to the pivot paths taskspace  $\mathbb{P}$  which is a subset of the robot's taskspace  $\mathbb{T}$  (we assume that all pivot motions can be executed, i.e. that all motions are reachable and fully inside the robot's taskspace). The paths are then used as input to a trajectory generator whose output is transformed via the Inverse Kinematics equations to the joint angles that belong to the joint space  $\mathbb{J}$ .

Alternatively in a mathematical notation, the fulcrum effect transformation is notated as

$$\Phi : \mathbb{S} \longrightarrow \mathbb{P} \quad (5.3.0.1)$$

the inverse kinematics transformation is described as

$$IK : \mathbb{P} \subset \mathbb{T} \longrightarrow \mathbb{J} \quad (5.3.0.2)$$

and similarly the forward kinematics transformation can be described as

$$FK : \mathbb{J} \longrightarrow \mathbb{T} \quad (5.3.0.3)$$




Figure 5.1: The spaces studied in this thesis and how they are connected with each other via transformations

Having defined all the spaces, the Dexterity metric of the tool's task space (same as the surgical taskspace) can be defined as

$$\mathcal{D} = \mathcal{L}_q \mathcal{M} \quad (5.3.0.4)$$

where

$$\mathcal{M} = \sqrt{\det(JJ^\top)} \quad (5.3.0.5)$$

$$\mathcal{L}_q = 1 - \exp \left\{ -\kappa \prod_{i=1}^{n_k} \frac{(q_i - q_{i,\min})(q_{i,\max} - q_i)}{(q_{i,\max} - q_{i,\min})^2} \right\} \quad (5.3.0.6)$$




Figure 5.2: Plot of the manipulability of the robot arm at sample points of the executed trajectory

The equation 5.3.0.6 calculates a joint limit measure which is multiplied with the manipulability measure and gives the dexterity measure. From that equation we can conclude the following:

- If  $q_i = q_{\min}$  or  $q_i = q_{\max}$  then the exponential is equal to 1 which means that  $\mathcal{L}_q$  and  $\mathcal{D}$  are both 0, which means that the robot has **no dexterity at the boundary of the task space**.
- If the value of  $q_i$  is close to it's boundary value then the dexterity approaches 0. The how much close or far it is from the boundary (or in other words how fast the exponential term converges) depends on the parameter  $\kappa$
- The  $q_{\min}, q_{\max}$  are calculated from the geometry of the task-space

For maximum dexterity at most points of a trajectory in a pivoting motion, the pivot subspace (i.e. the space of all configurations of feasible pivot motions) must be fully within the robot's whole reachable taskspace, otherwise only a small range of pivot movements will be feasible.

Finding  $q_{i,\min}, q_{i,\max}$  at 5.3.0.6 is very difficult and time-consuming especially at task spaces with more intricate geometries. A similar and more practical equation to 5.3.0.6 can be written for calculating the dexterity of the robot in task space:

$$\mathcal{L}_p = 1 - e^{-\kappa(r_{\max}-r)} \quad (5.3.0.7)$$

where  $r_{\max}$  is the maximum radius of a circle that the tool tip can follow at a given insertion depth  $z$ . Moreover, at every point of the taskspace, it is  $L^2 = r^2 + z^2$ . The equation 5.3.0.7 however only shows dexterity in terms of approaching the boundary of

the taskspace and it does not take into consideration internal points of low dexterity and singularities like equation 5.3.0.4.

---

```

1 x = [] ; y = [] ; z = [] ;
2 r = [] ;
3 s = 0:0.005:0.5;
4 L = 0.48;
5 k = 4.5;
6
7 for z0=-L:0.01:0
8 if abs(z0)*sqrt(2) <= L
9     rmax = abs(z0);
10 else
11     rmax = sqrt(L^2-z0^2);
12 end
13 for r0=0:0.02:rmax
14     x = [x, r0*cos(2*pi*s)];
15     y = [y, r0*sin(2*pi*s)];
16     z = [z, z0*ones(size(s))];
17     lp = 1-exp(-k*(rmax-r0));
18     r = [r, lp*ones(size(s))];
19 end
20 end

```

---

Listing 1: RCM Taskspace calculation using MATLAB




Figure 5.3: Task space inside patients body. Colors with 0 or low value correspond to points with low dexterity. This is the trivial case, where no collision objects are taken into consideration

All of the metrics above, measure how much reachable are various points of the surgical taskspace, but they are calculated from different perspectives, using input values from different spaces.

$$\mathcal{L}_q, \mathcal{M} : \mathbb{J} \longrightarrow \mathbb{R} \quad \text{and} \quad \mathcal{L}_p : \mathbb{S} \longrightarrow \mathbb{R} \quad (5.3.0.8)$$



## Chapter 6

# Trajectory Planning - Laparoscopic tool manipulation

At this step, given the points of the desired path, a more detailed trajectory is calculated, which will contain all the waypoints that the robot will have to visit. Trajectory planning is executed after a desired path is generated, and consists in mapping the geometric points to specific **time points**, as well as assigning specific **velocities**, **accelerations** and **jerks**, in order to generate the commands needed for the robot controller to execute a smooth motion.

The paths that are calculated are parameterized by the path parameter  $s$ . As  $s$  increases from 0, the robot moves from the start configuration  $q(0)$  to the goal configuration  $q(1)$ . Path planning outputs geometric information  $q(s), s \in [0, 1]$ , whereas the **trajectories** that are the subject of this chapter, also include **time information**  $q(t), t \in [0, T]$ . A path can be converted to a trajectory by defining a function  $s(t) : [0, T] \rightarrow [0, 1]$  which maps the time parameter's range to the path parameter's range. This function is also known as **time scaling** or **time parameterization**. The most common methodology of trajectory planning, which is also used in this thesis, is the one that is studied in the **joint angles space** also known as **configuration space**.

The biggest challenge in manipulating a laparoscopic tool with a robot is overcoming the **fulcrum effect** problem. This is also one of the reasons that robotic assisted surgery replaced the traditional laparoscopic procedures. The fulcrum effect means that the surgeon's hand motions are inverted and scaled with respect to the Remote Center of Motion point, which lies approximately on the center of the incision. Apart from the scaling and inversion, laparoscopic procedures add an additional motion constraint that demands at each time one point of the laparoscopic tool to coincide with the RCM point.

### 6.1 Tool pose & the Fulcrum Effect

The laparoscopic tool pose is given by the position and orientation vectors at target point  $B$  with respect to the coordinate frame  $\{F\}$ . The pose is given by the following




Figure 6.1: Tool pose at target point  $B$  calculated with respect to Fulcrum's reference frame  $\{F\}$

transformation matrix

$${}^F T_B = \begin{bmatrix} {}^F R_B & {}^F \mathbf{p}_B \\ \mathbf{0} & 1 \end{bmatrix} \quad \text{where} \quad {}^F R_B = [\hat{\mathbf{x}}_B \quad \hat{\mathbf{y}}_B \quad \hat{\mathbf{z}}_B]$$

$$\hat{\mathbf{x}}_B = \hat{\varphi} = -\sin(\varphi)\hat{\mathbf{x}}_F + \cos(\varphi)\hat{\mathbf{y}}_F = \begin{bmatrix} -\sin(\varphi) \\ \cos(\varphi) \\ 0 \end{bmatrix} \quad (6.1.0.1)$$

$$\hat{\mathbf{y}}_B = \hat{\theta} = \cos(\theta)\cos(\varphi)\hat{\mathbf{x}}_F + \cos(\theta)\sin(\varphi)\hat{\mathbf{y}}_F - \sin(\theta)\hat{\mathbf{z}}_F = \begin{bmatrix} \cos(\theta)\cos(\varphi) \\ \cos(\theta)\sin(\varphi) \\ -\sin(\theta) \end{bmatrix} \quad (6.1.0.2)$$

$$\hat{\mathbf{z}}_B = \hat{\mathbf{r}} = \sin(\theta)\cos(\varphi)\hat{\mathbf{x}}_F + \sin(\theta)\sin(\varphi)\hat{\mathbf{y}}_F + \cos(\theta)\hat{\mathbf{z}}_F = \begin{bmatrix} \sin(\theta)\cos(\varphi) \\ \sin(\theta)\sin(\varphi) \\ \cos(\theta) \end{bmatrix} \quad (6.1.0.3)$$

The position of the point  $B$  is given in spherical coordinates by:

- $r = \rho$  : outside penetration of laparoscopic tool
- $\theta = \beta$  : altitude angle
- $\varphi = \alpha$  : orientation angle

thus the position with respect to the coordinate frame  $\{F\}$  is given by

$${}^F \mathbf{p}_B = \begin{bmatrix} \rho \sin(\beta) \cos(\alpha) \\ \rho \sin(\beta) \sin(\alpha) \\ \rho \cos(\beta) \end{bmatrix} = \rho \hat{\mathbf{r}} \quad (6.1.0.4)$$

After having calculated the  $\hat{\mathbf{x}}, \hat{\mathbf{y}}, \hat{\mathbf{z}}$ , then these are rotated according to how the tool is attached on the end-effector (e.g. in this thesis the  $\hat{\mathbf{x}}$  vector points towards the origin of the frame, see figure 9.6) of the robot and they are also translated (see also figure 9.6) based on the offset between the end-effector and the tool (distance between end-effector and TCP). Note, that one can also use the  $\varphi, \theta$  angles as two of the Euler rotation angles and thus calculate the orientation with these angles instead of using the spherical coordinate unit vectors method above. The final transformed goal pose must be the same as the  $TCP$  point of the robot's end-effector. This means, that this pose must be converted with respect to the robot's reference frames.

$${}^U T_{TCP} = {}^U T_B$$

$${}^U T_0 {}^0 T_7 {}^7 T_{TCP} = {}^U T_F {}^F T_B$$

$${}^0 T_7 = {}^U T_0^{-1} {}^U T_F {}^F T_B {}^7 T_{TCP}^{-1} \quad (6.1.0.5)$$

---

```

1 function tcp = fulcrumEffectTrajectory(P, L)
2     tcp = zeros(size(P));
3     for i=1:size(P)
4         px = P(i,1); py = P(i,2); pz = P(i,3);
5         r = sqrt(px^2+py^2+pz^2);
6         th = atan2(sqrt(px^2+py^2), pz);
7         phi = atan2(py, px);
8         vx = [cos(th)*cos(phi); cos(th)*sin(phi); -sin(th)];
9         vy = [-sin(phi); cos(phi); 0];
10        vz = [-sin(th)*cos(phi); -sin(th)*sin(phi); cos(th)];
11        vp = r*[sin(th)*cos(phi); sin(th)*sin(phi); cos(th)];
12        T = zeros(4,4);
13        R = [vx, vy, vz];
14        T(1:3,1:3) = R;
15        T(1:3,4) = vp;
16        T(4,4) = 1;
17        Td = eye(4);
18        Td(1:3,4) = (r-L)/r*vp;
19        tcp_point = Td*inv(T)*[P(i,:).' 1];
20        tcp(i,:) = tcp_point(1:3).';
21    end
22 end

```

---

Listing 2: Fulcrum Effect transformation of a trajectory, in MATLAB

## 6.2 Trajectory planning in cartesian coordinates

On this section, some basic pivoting trajectories around the fulcrum point, are presented. In all of the following three example pivoting motions, we have made the assumption that the position and orientation of the  $F$  reference frame is precisely known, which is however not applicable in real-life scenarios. The trajectories presented in this section are planned in cartesian coordinates or also known as **Task space**.

### Advantages of planning in Task Space

- Since the interpolation of the path points is in task space, then the planned motion is **more predictable**.
- It is easier to design trajectories which are **better in avoiding obstacles and handling collisions**.

### Disadvantages of planning in Task Space

- **Planning and execution are significantly slower**, because for each interpolation point in task space the Inverse Kinematics problem must be solved. This issue is even more problematic when the IK problem is not solved with analytical equations but numerically using optimization techniques.
- A smooth trajectory in task space is not necessarily smooth in Joint Space (see figure 6.2).




Figure 6.2: Path/trajecotry interpolation done at two stages. (a) the initial desired circular trajectory, (b) sample waypoints that will approximate the circle and shape a polygon, (c) the line segments connecting the waypoints and which the robot must theoretically follow exactly, (d) lower-level interpolation of the line segments (made by MoveIt in ROS or by the robot's controller when executing PtP), (e) the actual trajectory that the robot will follow

### 6.2.1 Circular trajectory of tool tip

To generate a circular trajectory for the pivot movement we must specify the center of the circle and a vector whose magnitude is the radius of the circle and it's direction gives the orientation of the plane that the circle lies at. The simplest case of a circular trajectory is the one, whose circle lies in a plane parallel to the  $xy$  plane.




Figure 6.3: Circular trajectory of tool tip with respect to Fulcrum reference frame

We first consider the motion of the laparoscopic tool tip on a circle parallel to a  $z$ -plane, with respect to the  $\{F\}$  coordinate frame.

$$(x_F - x_{F0})^2 + (y_F - y_{F0})^2 = r_0^2, \quad z_F = z_{F0} \quad (6.2.1.1)$$

It's often more convenient to express trajectories in a parametric form, which makes it easier to calculate all the waypoints of the trajectory

$$\begin{cases} x_F = r_0 \cos(2\pi s) + x_{F0} \\ y_F = r_0 \sin(2\pi s) + y_{F0} \\ z_F = z_{F0} \end{cases}, \quad s \in [0, 1] \quad (6.2.1.2)$$

After having calculated the cartesian coordinates we can calculate the spherical coordinates as follows

$$\begin{cases} r = \sqrt{x_F^2 + y_F^2 + z_F^2} \\ \theta = \text{atan2}\left(\sqrt{x_F^2 + y_F^2}, z_F\right) \\ \varphi = \text{atan2}(y_F, x_F) \end{cases} \quad (6.2.1.3)$$

Although the equations 6.2.1.2 are very simple to calculate, it is more often the case that the circular trajectory will lie on an arbitrary plane that will not be parallel to the  $z$ -plane. This means that the equations 6.2.1.2 must first be transformed inside the task space (with the desired rotation and translation) and then these transformed equations should be used as an input to the Fulcrum Effect transformation.




Figure 6.4: Circular trajectory of tool tip with respect to Fulcrum reference frame and it's transformation via the Fulcrum Effect

### 6.2.2 Circular arc trajectory of tool tip

To generate a circular arc trajectory for a pivot motion we must specify the same parameters as in the circular trajectory as well as the length of the arc or the total angle  $\varphi$  of the arc section. Another parameter has more significance in circular arc trajectories than plain circles is the phase of the arc. This initial phase can be expressed as either an angle  $\varphi_0$  added to the arguments of sine and cosine functions or it can be expressed as  $s$  values that have as initial value different from 0. The parametric equations for a circular arc are:

$$\begin{cases} x_F = r_0 \cos(2\pi s + \varphi_0) + x_{F0} \\ y_F = r_0 \sin(2\pi s + \varphi_0) + y_{F0} \\ z_F = z_{F0} \end{cases}, \quad s \in \left[0, \frac{\varphi}{2\pi}\right] \quad (6.2.2.1)$$

### 6.2.3 Helical trajectory of tool tip

The helical trajectory is another useful trajectory that was studied in this thesis. The importance of this trajectory lies in the fact that the helical movement of the surgical tool can be considered as an ideal approximation of a suturing trajectory, a very common task in surgery which is extensively studied and researched in surgery robotics. A helical trajectory can be expressed by the following parametric equations:




Figure 6.5: Circular trajectory that lies on an a plane of arbitrary orientation with respect to the fulcrum point

$$\begin{cases} x_F = r_0 \cos(2\pi s) + x_{F0} \\ y_F = r_0 \sin(2\pi s) + y_{F0} \\ z_F = \pm \beta s \end{cases} \quad (6.2.3.1)$$

where  $s \in [0, \tau]$  expresses the range along the trajectory,  $\tau$  the cycles, and  $\beta/r_0$  is the slope (or also known as the pitch which is given by  $2\pi\beta$ )

#### 6.2.4 Line segment trajectory of tool tip

$$\begin{aligned} \mathbf{d} &= {}^F \mathbf{p}_{T2} - {}^F \mathbf{p}_{T1} = [l, m, n]^\top \\ {}^F \mathbf{p}_T &= [x_F, y_F, z_F]^\top \\ {}^F \mathbf{p}_T &= {}^F \mathbf{p}_{T1} + s \mathbf{d} \\ s &= \frac{x_F - x_{F1}}{l} = \frac{y_F - y_{F1}}{m} = \frac{z_F - z_{F1}}{n} \quad s \in [0, 1] \end{aligned}$$

$$\begin{cases} x_F = sl + x_{F1} = (1-s)x_{F1} + sx_{F2} \\ y_F = sm + y_{F1} = (1-s)y_{F1} + sy_{F2} \\ z_F = sn + z_{F1} = (1-s)z_{F1} + sz_{F2} \end{cases} \quad (6.2.4.1)$$




Figure 6.6: Circular arc trajectory of tool tip with respect to Fulcrum reference frame and it's transformation via the Fulcrum Effect. In this trajectory 2 circular arcs are used

After having calculated the cartesian coordinates we can calculate the spherical coordinates using the 6.2.1.3 equations.

The line segment trajectory of tool tip, as analysed above, **should not be confused with the** computeCartesianPath method provided by ROS MoveIt library that can be used to create line segment trajectories. This method produces line segment trajectories for the end effector of the robot which are not transformed as line segments via the Fulcrum Effect.

### 6.2.5 Cubic Spline trajectory of tool tip

A useful mathematical tool to construct a smooth curve that visits every point from a given set of waypoints are **cubic splines**. A cubic spline is constructed using smaller curves that are described by a polynomial of 3rd order. Let  $\{\mathbf{P}_0, \mathbf{P}_1, \dots, \mathbf{P}_n\}$  be a set of waypoints, where each point has coordinates  $\mathbf{P}_i = [x_i, y_i, z_i]^\top$ . Then between each 2 points a cubic polynomial can be constructed (one for each coordinate, 3 in total). The following equations are for the  $x$ -coordinate and in the exact same way one can calculate the cubic polynomials for the  $y, z$  coordinates as well. For each pair of waypoints we want to calculate the following cubic polynomial

$$x_i(s) = a_i(s - s_i)^3 + b_i(s - s_i)^2 + c_i(s - s_i) + d_i, \quad s_i \leq s \leq s_{i+1} \quad (6.2.5.1)$$

The polynomial in equation 6.2.5.1 has four unknowns which means that four additional equations are needed to get a unique solution and fully define the polynomial. These




Figure 6.7: Helical trajectory of tool tip with respect to Fulcrum reference frame and it's transformation via the Fulcrum Effect




Figure 6.8: Line segment trajectory of tool tip with respect to Fulcrum reference frame

equations can be formed using the boundary conditions for the first and last point of each curve.

$$x_i(s_i) = x_i \quad (6.2.5.2)$$

$$x_i(s_{i+1}) = x_{i+1} \quad (6.2.5.3)$$

$$\dot{x}_i(s_i) = \dot{x}_i \quad (6.2.5.4)$$

$$\dot{x}_i(s_{i+1}) = \dot{x}_{i+1} \quad (6.2.5.5)$$




Figure 6.9: A Line segment trajectory and it's transformation via the Fulcrum Effect

First we solve for  $c_i$  and  $d_i$ , which can easily be calculated as follows

$$d_i = x_i(s_i) = x_i \quad (6.2.5.6)$$

and by taking the derivative of 6.2.5.1, we can calculate  $c_i$

$$\dot{x}_i(s_i) = 3a_i(s - s_i)^2 + 2b_i(s - s_i) + c_i \quad (6.2.5.7)$$

$$c_i = \dot{x}_i(s_i) = \dot{x}_i \quad (6.2.5.8)$$

By substituting  $s = s_{i+1}$  in 6.2.5.1 and 6.2.5.7, by using equations 6.2.5.8, 6.2.5.6 and if we set  $\sigma = s_{i+1} - s_i$  for brevity, we get the following two equations

$$x_{i+1} = x_i(s_{i+1}) = a_i\sigma^3 + b_i\sigma^2 + c_i\sigma + x_i \quad (6.2.5.9)$$

and

$$\dot{x}_{i+1} = \dot{x}_i(s_{i+1}) = 3a_i\sigma^2 + 2b_i\sigma + \dot{x}_i \quad (6.2.5.10)$$

By multiplying 6.2.5.10 by  $\sigma$  and 6.2.5.9 by  $-3$  and add them together we get

$$\begin{aligned} \dot{x}_{i+1}\sigma - 3x_{i+1} &= -b_i\sigma^2 - 2\dot{x}_i\sigma - 3x_i \\ b_i &= \frac{1}{\sigma^2}(3x_{i+1} - 3x_i - \dot{x}_{i+1}\sigma - 2\dot{x}_i\sigma) \end{aligned} \quad (6.2.5.11)$$

Similarly, by multiplying 6.2.5.10 by  $\sigma$  and 6.2.5.9 by  $-2$  and add them together we get

$$\begin{aligned} \dot{x}_{i+1}\sigma - 2x_{i+1} &= a_i\sigma^3 - \dot{x}_i\sigma - 2x_i \\ a_i &= \frac{1}{\sigma^3}(\dot{x}_{i+1}\sigma - 2x_{i+1} + \dot{x}_i\sigma + 2x_i) \end{aligned} \quad (6.2.5.12)$$




Figure 6.10: Cubic Spline curve with 10 waypoints




Figure 6.11: A Cubic Spline trajectory and it's transformation via the Fulcrum Effect

### 6.2.6 B-Spline trajectory of tool tip

The **B-Splines** are smooth curves which are constructed from **Bézier** curves. A Bézier curve is a parametric smooth curve and is a  $k$ -th order interpolation of  $k + 1$  control points.




Figure 6.12: Cubic Bézier curve calculated using cubic interpolation of 4 control points

We first calculate the linear interpolation of the control points

$$\mathbf{L}_0(s) = (1 - s)\mathbf{P}_0 + s\mathbf{P}_1 \quad (6.2.6.1)$$

$$\mathbf{L}_1(s) = (1 - s)\mathbf{P}_1 + s\mathbf{P}_2$$

$$\mathbf{L}_2(s) = (1 - s)\mathbf{P}_2 + s\mathbf{P}_3$$

The next step is to calculate the quadratic interpolation of the control points or equivalently, the linear interpolation of the previously calculated points  $\mathbf{L}_0, \mathbf{L}_1, \mathbf{L}_2$

$$\mathbf{Q}_0(s) = (1 - s)\mathbf{L}_0(s) + s\mathbf{L}_1(s)$$

$$\mathbf{Q}_0(s) = (1 - s)^2\mathbf{P}_0 + 2(1 - s)s\mathbf{P}_1 + s^2\mathbf{P}_2 \quad (6.2.6.2)$$

$$\mathbf{Q}_1(s) = (1 - s)^2\mathbf{P}_1 + 2(1 - s)s\mathbf{P}_2 + s^2\mathbf{P}_3$$

Similarly for the last step, we calculate the cubic interpolation of the control points or equivalently, the linear interpolation of the previously calculated points  $\mathbf{Q}_0, \mathbf{Q}_1$

$$\mathbf{C}_0(s) = (1 - s)\mathbf{Q}_0(s) + s\mathbf{Q}_1(s)$$

$$\mathbf{C}_0(s) = (1 - s)^3\mathbf{P}_0 + 3(1 - s)^2s\mathbf{P}_1 + 3(1 - s)s^2\mathbf{P}_2 + s^3\mathbf{P}_3 \quad (6.2.6.3)$$

The cubic Bézier curve can also be calculated using the following more compact equation, in matrix form

$$\mathbf{C}_0(s) = [\mathbf{P}_0 \ \mathbf{P}_1 \ \mathbf{P}_2 \ \mathbf{P}_3] \begin{bmatrix} -1 & 3 & -3 & 1 \\ 3 & -6 & 3 & 0 \\ -3 & 3 & 0 & 0 \\ 1 & 0 & 0 & 0 \end{bmatrix} \begin{bmatrix} s^3 \\ s^2 \\ s \\ 1 \end{bmatrix} \quad (6.2.6.4)$$




Figure 6.13: A cubic Bézier curve calculated and plotted in MATLAB




Figure 6.14: B-Spline curve constructed from 3 Bézier curves. The first Bézier curve colored in red is a quadratic one and the following two are both cubic.

A  $k$ -degree **B-Spline** curve defined by  $n+1$  control points will consist of  $n-k+1$  Bézier curves. For example if we want to construct a cubic B-Spline using 6 control points, then we will need to construct and connect together 3 Bézier curves.

In most cases the B-Spline curves are constructed by starting from a quadratic Bézier curve, which is constructed from 3 control points and then all other parts of the curve are constructed from cubic Bézier curves, each constructed from 4 control points. As shown in figure 6.14, the B-Spline curves do not pass from all control points. This means

that if we have a path formed by a set of waypoints and we want the robot to pass from all of them, then in order to construct a B-Spline trajectory we will need additional intermediary points. The first and last points are part of the curve and the other control points are not. If no additional points can be calculated then the robot will not pass from all the points, which in some cases is also acceptable and useful.

One must notice also, in figure 6.14 for example, that some points must be colinear in order for the transition from one Bézier curve to another to be smooth, or equivalently the point where the two curves are connected to have a continuous derivative. For example in figure 6.14,  $\mathbf{P}_2, \mathbf{P}_3, \mathbf{P}_4$  must be colinear so that the derivative of the curve at  $\mathbf{P}_3$  is continuous. In the same example one can also notice that if the distance of  $\overrightarrow{\mathbf{P}_2\mathbf{P}_3}$  and  $\overrightarrow{\mathbf{P}_3\mathbf{P}_4}$  is getting smaller then the curve at  $\mathbf{P}_3$  is getting sharper and if these distances are 0 then instead of a smooth curve we have a sharp corner and the curve has no longer a continuous derivative at  $\mathbf{P}_3$ . These two parameters; **3 colinear points** and the **distances of the two vectors** of these 3 colinear points can be very useful in designing B-Spline trajectories when we only have the waypoints available and not the extra control points required to construct the Bézier curves.

It is very important that the designed trajectory respects the joints angles' range. For example depending on the starting position of the circular trajectory depicted at figure ??, the robot arm may reach it's joint bounds and in order to continue executing the trajectory it will have to make a sudden jump to reset the angles. This could have serious side-effects for both the surgical task and thus the patient, as well as for the operating staff, who control the robot.

## 6.3 Trajectory planning in joint angles space

### Advantages of planning in Joint Space

- Planning trajectories in Joint Space is **much faster in execution** than Task Space planning, because the Inverse Kinematics problem is solved for fewer points, only at the waypoints of the trajectory and not at the intermediate points (the points between the waypoints).
- The actuators' motion is smoother

### Disadvantages of planning in Joint Space

- The interpolated intermediate points are not guaranteed to be collision-free.

#### 6.3.1 Polynomials of 5th order

Sometimes for a smooth trajectory between 2 consecutive path points, polynomials of higher degree are used. One such common family of polynomials are those of 5th degree with which we can specify the desired position, velocity, as well as acceleration at the beginning and at the end of the trajectory segment. This polynomial has the following closed form

$$q_i(t) = a_i + b_i t + c_i t^2 + d_i t^3 + e_i t^4 + f_i t^5 \quad (6.3.1.1)$$




Figure 6.15: A Bézier curve trajectory and it's transformation via the Fulcrum Effect

where

$$q_i = q_i(t_i), \quad q_{i+1} = q_i(t_{i+1}) = q_{i+1}(t_{i+1}) \quad \text{and} \quad t_i \leq t \leq t_{i+1} \quad (6.3.1.2)$$

The constants  $a_i, b_i, \dots, f_i$  are computed from the boundary conditions, i.e. the position, and its derivatives, evaluated at the beginning and at the end of the trajectory segment.

$$\begin{aligned} q_i &= a_i \\ q_{i+1} &= a_i + b_i t_{i+1} + c_i t_{i+1}^2 + d_i t_{i+1}^3 + e_i t_{i+1}^4 + f_i t_{i+1}^5 \\ \dot{q}_i &= b_i \\ \dot{q}_{i+1} &= b_i + 2c_i t_{i+1} + 3d_i t_{i+1}^2 + 4e_i t_{i+1}^3 + 5f_i t_{i+1}^4 \\ \ddot{q}_i &= 2c_i \\ \ddot{q}_{i+1} &= 2c_i + 6d_i t_{i+1} + 12e_i t_{i+1}^2 + 20f_i t_{i+1}^3 \end{aligned} \quad (6.3.1.3)$$

Solving the system of boundary condition equations 6.3.1.3, the solution for the constants

is the following

$$\begin{aligned}
 a_i &= q_i \\
 b_i &= \dot{q}_i \\
 c_i &= \frac{\ddot{q}_i}{2} \\
 d_i &= \frac{20q_{i+1} - 20q_i - (8\dot{q}_{i+1} + 12\dot{q}_i)t_{i+1} - (3\ddot{q}_i - \ddot{q}_{i+1})t_{i+1}^2}{2t_{i+1}^3} \\
 e_i &= \frac{30q_i - 30q_{i+1} - (14\dot{q}_{i+1} + 16\dot{q}_i)t_{i+1} + (3\ddot{q}_i - 2\ddot{q}_{i+1})t_{i+1}^2}{2t_{i+1}^4} \\
 f_i &= \frac{12q_{i+1} - 12q_i - (6\dot{q}_{i+1} + 6\dot{q}_i)t_{i+1} - (\ddot{q}_i - \ddot{q}_{i+1})t_{i+1}^2}{2t_{i+1}^5}
 \end{aligned} \tag{6.3.1.4}$$

### 6.3.2 Planning with velocity profiles

#### 6.3.2.1 Trapezoid velocity profile - LSPB

Trapezoid velocity profiles are a family of trajectories in motion control, that combines (blends) a linear segment with two parabolic segments. This type of trajectory is also known in the bibliography as Linear Segments with Parabolic Blends or LSPB. The equations of motions are studied in 3 intervals  $[t_i, t_a]$ ,  $[t_a, t_d]$  and  $[t_d, t_{i+1}]$  where  $t_a = t_i + \tau$  and  $t_d = t_{i+1} - \tau$  where  $\tau$  is the time duration for both the acceleration and deceleration phases (symmetric trapezoid profile).

For  $t_i \leq t \leq t_a$  the equations of the trajectory are the following:

$$q_i(t) = c_0 + c_1t + c_2t^2, \quad c_0, c_1, c_2 \in \mathbb{R} \tag{6.3.2.1}$$

$$\dot{q}_i(t) = c_1 + 2c_2t \tag{6.3.2.2}$$

Using the initial conditions  $q_i(0) = q_i$ ,  $\dot{q}_i(0) = 0$  and  $\dot{q}_i(t_a) = \dot{q}_{ic}$  we can solve for the constants  $c_i$ .  $\dot{q}_{ic}$  is the desired constant velocity for the linear segment.

$$c_0 = q_i \quad \text{and} \quad c_1 = 0 \tag{6.3.2.3}$$

$$\dot{q}_i + 2c_2t_a = \dot{q}_{ic}$$

$$c_2 = \frac{\dot{q}_{ic}}{2t_a} \tag{6.3.2.4}$$

The trajectory solution for  $t_i \leq t \leq t_a$  is

$$\begin{aligned}
 q_i(t) &= q_i + \frac{\dot{q}_{ic}}{2t_a}t^2 \\
 \dot{q}_i(t) &= \frac{\dot{q}_{ic}}{t_a}t \\
 \ddot{q}_i(t) &= \frac{\dot{q}_{ic}}{t_a^2}
 \end{aligned} \tag{6.3.2.5}$$

For  $t_a \leq t \leq t_d$  the equations of the trajectory are the following:

$$q_i(t) = q_i(t_a) + \dot{q}_{ic}(t - t_a) \quad (6.3.2.6)$$

Due to the symmetry of the trajectory, at half time the following equation must hold, that incorporates the 2 boundary conditions for the joint position

$$q_i(t_h) = \frac{q_i + q_{i+1}}{2}, \quad \text{where } t_h = \frac{t_{i+1} - t_i}{2} \quad (6.3.2.7)$$

and

$$q_i(t_h) = q_i(t_a) + \dot{q}_{ic}(t_h - t_a) \quad (6.3.2.8)$$

Combining 6.3.2.7 and 6.3.2.8 the joint position at  $t_a$  is

$$q_i(t_a) = \frac{q_i + q_{i+1}}{2} - \dot{q}_{ic}(t_h - t_a) \quad (6.3.2.9)$$

The trajectory solution for  $t_a \leq t \leq t_d$  is

$$\begin{aligned} q_i(t) &= \frac{q_i + q_{i+1}}{2} - \dot{q}_{ic}(t_h - t_a) + \dot{q}_{ic}(t - t_a) \\ \dot{q}_i(t) &= \dot{q}_{ic} \\ \ddot{q}_i(t) &= 0 \end{aligned} \quad (6.3.2.10)$$

For  $t_d \leq t \leq t_{i+1}$  the equations of the trajectory are similar to those of the first interval. Let  $q_{i1}$  be the parabolic function of the first segment. From that the other parabolic segment will be calculated by mirroring  $q_{i1}$  by the  $t$ -axis, shift to  $t_{i+1}$  on the  $t$ -axis and translate by  $q_{i+1} + q_i$  on the  $y$ -axis.

$$q_i(t) = -q_{i1}(t - t_{i+1}) + (q_{i+1} + q_i) \quad (6.3.2.11)$$

The trajectory solution for  $t_d \leq t \leq t_{i+1}$  is

$$\begin{aligned} q_i(t) &= q_{i+1} - \frac{\dot{q}_{ic}}{2t_a} t^2 \\ \dot{q}_i(t) &= -\frac{\dot{q}_{ic}}{t_a} t \\ \ddot{q}_i(t) &= -\frac{\dot{q}_{ic}}{t_a} \end{aligned} \quad (6.3.2.12)$$

It is important to note that in order for the motion control using a trapezoid velocity profile to be feasible, the desired constant velocity  $\dot{q}_{ic}$  must satisfy a velocity constraint. The constraint is calculated using the equations at time  $t_a = t_i + \tau$

$$q_i(t_a) = \frac{q_i + q_{i+1}}{2} - \dot{q}_{ic} \left( \frac{t_f}{2} - t_a \right) = q_i + \frac{\dot{q}_{ic}}{2t_a} t_a^2 \quad (6.3.2.13)$$

where  $t_f/2 = t_h$

$$\frac{q_i + q_{i+1} - \dot{q}_{ic} t_f}{2} + \dot{q}_{ic} t_a = q_i + \frac{\dot{q}_{ic}}{2} t_a \quad (6.3.2.14)$$

$$\frac{q_{i+1} - q_i - \dot{q}_{ic} t_f}{2} = -\frac{\dot{q}_{ic}}{2} t_a \quad (6.3.2.15)$$

$$t_a = \frac{\dot{q}_{ic} t_f + q_i - q_{i+1}}{\dot{q}_{ic}} \quad (6.3.2.16)$$

For the time constant  $t_a$  the following inequalities must hold (to simplify calculations we consider the case where  $t_i = 0$ )

$$0 \leq t_a \leq \frac{t_f}{2} = t_h \quad (6.3.2.17)$$

Substituting  $t_a$  with 6.3.2.16

$$0 \leq \frac{\dot{q}_{ic}t_f + q_i - q_{i+1}}{\dot{q}_{ic}} \leq \frac{t_f}{2} \quad (6.3.2.18)$$

$$0 \leq 2\dot{q}_{ic}t_f + 2(q_i - q_{i+1}) \leq \dot{q}_{ic}t_f \quad (6.3.2.19)$$

$$-2\dot{q}_{ic}t_f \leq 2(q_i - q_{i+1}) \leq -\dot{q}_{ic}t_f \quad (6.3.2.20)$$

$$-\frac{t_f}{q_i - q_{i+1}} \geq \frac{1}{\dot{q}_{ic}} \geq -\frac{t_f}{2(q_i - q_{i+1})} \quad (6.3.2.21)$$

$$\frac{q_i - q_{i+1}}{t_f} \leq \dot{q}_{ic} \leq \frac{2(q_i - q_{i+1})}{t_f} \quad (6.3.2.22)$$

### 6.3.2.2 S-Curve velocity profile

The s-curve trajectories introduce a cubic term to joint position polynomial, which has as a result the derivative of the acceleration, also known in the bibliography as jerk, to be non-zero. When introducing jerk in the equations of motion, then we can no longer have discontinuities in the acceleration which means generating a smoother trajectory than the trapezoid profile's trajectory. The equations of motions are studied in 7 intervals  $[t_i, t_a], [t_a, t_b], [t_b, t_c], [t_c, t_d], [t_d, t_e], [t_e, t_g]$  and  $[t_g, t_{i+1}]$  where

$$\begin{aligned} t_a &= t_i + \tau_1 \\ t_b &= t_i + \tau_1 + \tau_2 \\ t_c &= t_i + 2\tau_1 + \tau_2 \\ t_d &= t_{i+1} - 2\tau_1 - \tau_2 \\ t_e &= t_{i+1} - \tau_1 - \tau_2 \\ t_g &= t_{i+1} - \tau_1 \end{aligned} \quad (6.3.2.23)$$

where  $\tau_1$  is the time duration for both the acceleration and deceleration phases (symmetric trapezoid acceleration profile) and  $\tau_2$  is the time duration of constant, non-zero acceleration.

For  $t_i \leq t \leq t_a$  the equations of the trajectory are the following:

$$q_i(t) = c_0 + c_1t + c_2t^2 + c_3t^3, \quad c_0, c_1, c_2, c_3 \in \mathbb{R} \quad (6.3.2.24)$$

$$\dot{q}_i(t) = c_1 + 2c_2t + 3c_3t^2 \quad (6.3.2.25)$$

$$\ddot{q}_i(t) = 2c_2 + 6c_3t \quad (6.3.2.26)$$

Using the following initial conditions,

$$q_i(0) = q_i, \quad \dot{q}_i(0) = 0, \quad \text{and} \quad \ddot{q}_i(0) = 0 \quad (6.3.2.27)$$

the constants  $c_0, c_1$  and  $c_2$  can be calculated

$$c_0 = q_i, \quad c_1 = 0, \quad \text{and} \quad c_2 = 0 \quad (6.3.2.28)$$

Using a desired acceleration  $\ddot{q}_a$  at time  $t_a = t_i + \tau_1$ , the constant  $c_3$  can be calculated

$$q^{(4)}(t) = 6c_3 = J_a \quad \text{and} \quad J_a = \frac{\ddot{q}_a}{\tau_1} \quad (6.3.2.29)$$

The trajectory solution for  $t_i \leq t \leq t_a = t_i + \tau_1$  is

$$\begin{aligned} q_i(t) &= q_i - \frac{\ddot{q}_a}{6\tau_1} t^3 \\ \dot{q}_i(t) &= \frac{\ddot{q}_a}{2\tau_1} t^2 \\ \ddot{q}_i(t) &= \frac{\ddot{q}_a}{\tau_1} t \end{aligned} \quad (6.3.2.30)$$

The trajectory solution for  $t_a \leq t \leq t_b$  is

$$\begin{aligned} q_i(t) &= q_a + \dot{q}_a(t - t_a) + \frac{\ddot{q}_a}{2}(t - t_a)^2 \\ \dot{q}_i(t) &= \dot{q}_a + \ddot{q}_a(t - t_a) \\ \ddot{q}_i(t) &= \ddot{q}_a \end{aligned} \quad (6.3.2.31)$$

The trajectory solution for  $t_b \leq t \leq t_c$  is

$$\begin{aligned} q_i(t) &= q_b + \dot{q}_b(t - t_b) + \frac{\ddot{q}_a}{2}(t - t_b)^2 - \frac{\ddot{q}_a}{6\tau_1}(t - t_b)^3 \\ \dot{q}_i(t) &= \dot{q}_b + \ddot{q}_a(t - t_b) - \frac{\ddot{q}_a}{2\tau_1}(t - t_b)^2 \\ \ddot{q}_i(t) &= \ddot{q}_a - \frac{\ddot{q}_a}{\tau_1}(t - t_b) \end{aligned} \quad (6.3.2.32)$$

The trajectory solution for  $t_c \leq t \leq t_d$  is

$$\begin{aligned} q_i(t) &= q_c + \dot{q}_c(t - t_c) \\ \dot{q}_i(t) &= \dot{q}_c \\ \ddot{q}_i(t) &= 0 \end{aligned} \quad (6.3.2.33)$$

The trajectory solution for  $t_d \leq t \leq t_e$  is

$$\begin{aligned} q_i(t) &= q_d + \dot{q}_d(t - t_d) - \frac{\ddot{q}_a}{6\tau_1}(t - t_d)^3 \\ \dot{q}_i(t) &= \dot{q}_d - \frac{\ddot{q}_a}{2\tau_1}(t - t_d)^2 \\ \ddot{q}_i(t) &= - \frac{\ddot{q}_a}{\tau_1}(t - t_d) \end{aligned} \quad (6.3.2.34)$$

The trajectory solution for  $t_e \leq t \leq t_g$  is

$$\begin{aligned} q_i(t) &= q_e + \dot{q}_e(t - t_e) - \frac{\ddot{q}_a}{2}(t - t_e)^2 \\ \dot{q}_i(t) &= \dot{q}_e - \ddot{q}_a(t - t_e) \\ \ddot{q}_i(t) &= -\ddot{q}_a \end{aligned} \quad (6.3.2.35)$$

The trajectory solution for  $t_g \leq t \leq t_{i+1}$  is

$$\begin{aligned} q_i(t) &= q_g + \dot{q}_g(t - t_g) - \frac{\ddot{q}_a}{2}(t - t_g)^2 + \frac{\ddot{q}_a}{6\tau_1}(t - t_g)^3 \\ \dot{q}_i(t) &= \dot{q}_g - \ddot{q}_a(t - t_g) + \frac{\ddot{q}_a}{2\tau_1}(t - t_g)^2 \\ \ddot{q}_i(t) &= -\ddot{q}_a + \frac{\ddot{q}_a}{\tau_1}(t - t_g) \end{aligned} \quad (6.3.2.36)$$

The equations of the s-curve profile trajectories can also be calculated numerically using integrals, which is however susceptible to small error accumulations. The integral trajectory solution for  $t_k < t \leq t_{k+1}$  is

$$\begin{aligned} q_k(t) &= q_k + \int_{t_k}^t \dot{q}_k(\tau) d\tau \\ \dot{q}_k(t) &= \dot{q}_k + \int_{t_k}^t \ddot{q}_k(\tau) d\tau \\ \ddot{q}_k(t) &= \ddot{q}_k + \int_{t_k}^t \dddot{q}_k(\tau) d\tau \end{aligned} \quad (6.3.2.37)$$

In order to better impose the boundary conditions for the start and end joint positions as well as fix any calculation errors, the following correction (normalization) formula can be used. Let  $\tilde{q}_1$  and  $\tilde{q}_2$  be the calculated start and end joint positions respectively. Then for each calculated joint position  $\tilde{q}_k = q_i(t_k)$ ,  $t_i \leq t_k \leq t_{i+1}$ , the corrected joint position  $q_k$  is calculated using the following equation

$$q_k = (\tilde{q}_k - q_1) \frac{q_2 - q_1}{\tilde{q}_2 - \tilde{q}_1} + q_1 \quad (6.3.2.38)$$

### 6.3.2.3 Comparison of velocity profiles

Both trapezoid and s-curve velocity profiles are widely used in industrial control systems, to design trajectories that are smooth and have a linear segment of constant velocity. Although both profiles are continuous in position and velocity, the trapezoid profile does not have continuous acceleration and thus the generated trajectory is not smooth. These discontinuities in acceleration cause load oscillation or vibrations. This phenomenon can be easily observed in a cart-pendulum system like the one illustrated in 6.17. The s-curve velocity profile can generate a smooth trajectory which at the start and end of the motion will have significantly less oscillation (overshoot in position). Experimental data showing this difference in motion (in one case there is overshoot/oscillation and in the other case there is not), for the cart-pendulum system are available at the following article <https://www.pmdcorp.com/resources/type/articles/>




Figure 6.16: Joint trajectory generated using velocity profiles. Calculated and plotted in MATLAB

get/s-curve-profiles-deep-dive-article. However, it is very important to note, that using smooth acceleration profiles in trajectories in the joint space  $\mathbb{J}$  does not necessarily mean that the acceleration profile in the task space  $\mathbb{P}$  will be equally smooth or any smooth at all due to the non-linear transformation between the spaces  $\mathbb{J} \longleftrightarrow \mathbb{P}$  as well as the limits in the joint angles' ranges. This means that although smooth trajectories will cause less vibrations in the joint space, the vibrations/ oscillations are not necessarily avoided in the task space.




Figure 6.17: Trapezoid vs s-curve velocity profiles applied to the cart-inverted-pendulum system.

The smoothness and absence of vibration/oscillation/overshoot in the point-to-point trajectory of a s-curve trajectory are especially useful in surgical robots that use passive wrists. A **passive wrist** is a mechanical device attached at the end-effector of a robot

arm and it usually has 3 degrees of freedom which are passive, i.e. not actuated. Passive wrists are very useful in minimally-invasive surgery because they allow to use surgical tools (usually endoscopic cameras) that are inserted in the human body at the surgical site, through the trocar and the incision, without exerting much pressure. Passive wrists, however have the downside of passiveness (e.g. they can not be used for active tasks such as lifting an object, suturing etc.) and the difficulty in position control. Experimental data showing the overshoot and oscillation in position control of a laparoscopic camera attached to a passive wrist, are available at figure 7 of article [5].

An active-robot-passive-wrist system and the effect of trapezoid vs s-curve profile trajectories, can be studied using the analogous system of a cart-pendulum system as the one show in figure 6.17. In figure 6.17 the cart is the actuated mechanism (the one that will have a motor) and the pendulum is the passive mechanism (i.e. the joint that attached the pendulum to the cart is not actuated). The pendulum is also attached to a spring-damper system to better simulate the oscillating response to sudden changes in acceleration/force. The pendulum, although not actuated, moves based on the sudden changes of motion of the cart. Using this analogy, the actuated cart can be thought of as the active robotic arm's end-effector and the passive pendulum can be thought of as the passive wrist which is attached to the end-effector.

Trapezoid and s-curve velocity profiles can be further extended and generalized using higher order s-curves where the jerk is also bounded and continuous. Based on each use case the higher order s-curves can be used to generated trajectories that are both controllable smooth and time-optimal. Higher order s-curve profiles can be found at [53].

# Chapter 7

## System Control

### 7.1 RCM Tracking

This section describes how to use a Remote Center of Motion error metric in order to implement a control system that makes sure that the laparoscopic tool is always aligned with the fulcrum point and it satisfies the RCM constraint. To calculate this error, which can then be used as a feedback signal to a control system, the line of the long axis of the surgical tool must be first defined. To define this line, 2 points are needed. Both of these points can be calculated using the transformation of the surgical tool, which is attached to the robot's TCP on the end-effector. Let the following be the pose of the surgical tool with respect to the global reference frame

$${}^U T_{T0} = \begin{bmatrix} \hat{\mathbf{x}} & \hat{\mathbf{y}} & \hat{\mathbf{z}} & \mathbf{p} \\ 0 & 0 & 0 & 1 \end{bmatrix} \quad (7.1.0.1)$$

Using this pose, let  $A, B$  be the points such that

$$\overrightarrow{O_F A} = \mathbf{p}, \quad \text{and} \quad \overrightarrow{O_F B} = \mathbf{p} + \hat{\mathbf{x}} \quad (7.1.0.2)$$

where  $O_F$  is the origin point of the fulcrum reference frame. The line of interest is defined as the line  $l$  that passes through the points  $A$  and  $B$ .

The alignment error is calculated using a known position and orientation for the second fulcrum reference frame. In real-case scenarios the exact position and orientation of the fulcrum points are not precisely known but can be estimated. To model the uncertainty of the pose, the pose message of the fulcrum point includes also a covariance matrix. The ROS message that was used was the **PoseWithCovarianceStamped** which needs the following information (with respect to the global frame) to be fully defined:

$$(\mathbf{p}, \mathbf{q}, \mathbf{C}), \quad \mathbf{p} \in \mathbb{R}^3, \mathbf{q} \in \mathbb{H}, \mathbf{C} \in \mathbb{R}^{6 \times 6}$$

where

$$\mathbf{C} = \begin{bmatrix} \sigma_{xx} & \sigma_{xy} & \sigma_{xz} & \sigma_{x\psi} & \sigma_{x\theta} & \sigma_{x\varphi} \\ \sigma_{xy} & \sigma_{yy} & \sigma_{yz} & \sigma_{y\psi} & \sigma_{y\theta} & \sigma_{y\varphi} \\ \sigma_{xz} & \sigma_{yz} & \sigma_{zz} & \sigma_{z\psi} & \sigma_{z\theta} & \sigma_{z\varphi} \\ \sigma_{x\psi} & \sigma_{y\psi} & \sigma_{z\psi} & \sigma_{\psi\psi} & \sigma_{\psi\theta} & \sigma_{\psi\varphi} \\ \sigma_{x\theta} & \sigma_{y\theta} & \sigma_{z\theta} & \sigma_{\psi\theta} & \sigma_{\theta\theta} & \sigma_{\theta\varphi} \\ \sigma_{x\varphi} & \sigma_{y\varphi} & \sigma_{z\varphi} & \sigma_{\psi\varphi} & \sigma_{\theta\varphi} & \sigma_{\varphi\varphi} \end{bmatrix} \quad (7.1.0.3)$$

The covariance matrix and its coefficients can be calculated using equations 4.3.0.3 and 4.3.0.4, using the mean values of the estimations of  $x, y, z, \psi, \theta, \varphi$ .




Figure 7.1: Geometric calculation of the RCM alignment error  $e$  using the distance between the line  $l$  and the RCM (aka Fulcrum) point.

Since both the origin of the fulcrum reference frame and the line of the long axis of the tool are known then the alignment error can be calculated as the distance of the line  $l$  from the point  $O_F$

$$e_{rcm} = d(l, O_F) \quad (7.1.0.4)$$

To calculate the distance  $d(l, O_F)$  there is available a method in the **Eigen** C++ library that calculates the distance of a line that passes through 2 points, from a third point. Alternatively, this distance can be calculated using 7.1.0.5.

$$d(l, O_F) = \frac{\|\overrightarrow{O_F A} \times \hat{x}\|}{\|\hat{x}\|} \quad (7.1.0.5)$$

Similar approaches to calculate this error/distance are presented in bibliography at [18] and [5].

If  $e_{rcm} \leq 3_{max} = 1mm$  then the surgical tool axis passes through the fulcrum point and executes RCM trajectories, otherwise the robot is considered to have slipped from alignment, it does not execute RCM motion and probably generates a force  $f \propto e$  which exerts pressure to the incision point and the abdominal wall (or the tissue around the incision point), which can have negative side-effects in the recovery of the incision. In paper [5] a different distance  $e_s$  is calculated as the RCM error as shown in figure 7.2, which is along the x-axis of the fulcrum reference frame or the axis of the abdominal wall




Figure 7.2: Force interaction model of the laparoscopic tool and the abdominal wall around the fulcrum point (RCM point)

(we assume local to the Fulcrum point the abdominal wall is a straight line). Using this deviation distance  $e_s$  the force interaction between the surgical tool and the abdominal wall can be modelled with the following force

$$\|\mathbf{f}_s\| = \lambda e_s \quad (7.1.0.6)$$

where  $\lambda$  is the elasticity of the abdominal wall and can be measured experimentally and

$$e_s = \frac{1}{\cos\gamma} e \quad (7.1.0.7)$$




Figure 7.3: RCM error calculation in  $yz$  plane. The RCM error or  $yz$ -error is the distance between the line of the  $\hat{x}$  vector (here seen as a point) and the estimated position of the origin of the fulcrum reference frame  $\tilde{O}_F$

The error  $e_{rcm}$  can provide further information if the distance of the line  $l$  (or of the  $\hat{x}$  axis) from the fulcrum point, is seen from a different perspective than that of figure 7.1. If this distance is seen from a plane that is perpendicular to  $\hat{x}$ , then the line is seen as a point and the distance  $d(l, O_F)$  is seen as a distance between 2 points, as illustrated in figure 7.3. This perspective of the RCM error (will also be referenced as  $yz$ -error  $e_{yz}$ ) is

more useful because it decomposes the error distance in 2 components that can be used to correct the goal pose of the robot so that is fixes the RCM misalignment.

$$e_y = e_{yz} \sin \psi \quad \text{and} \quad e_z = e_{yz} \cos \psi \quad (7.1.0.8)$$

The angle  $\psi$  that is used to split  $e_{rcm}$  in the two components, is already known from the robot's pose and it is the yaw (also known as spin) angle of the surgical tool.

Using the estimated RCM error  $\tilde{e}_{rcm}$  and the estimated position of the origin of the fulcrum reference frame, then an adaptive motion control system can be designed that corrects the trajectory to avoid RCM misalignment. The proposed control system is illustrated in the block diagram 7.4 and a similar pivoting motion control system is also described in the bibliography in [51].




Figure 7.4: RCM tracking proposed control system. The RCM error is used as input in the trajectory generator to correct the trajectory command in order to fix the RCM misalignment

## 7.2 Visual Servoing

At this chapter we briefly investigate how visual servoing can be applied in surgery robotics. **Visual Servoing** is the use of visual information to guide and control a robot. The main task of visual servoing is to control the end-effector's pose using features extracted from visual information. The features that are usually extracted from cameras are the position and orientation of the detected object, the distance of the object from the camera (using stereoscopic vision, photogrammetry or other techniques), the size and the shape of the object. The visual servoing can be executed either in the robot's space using position-based servoing or in the camera's space (also known as "pixel space") by using the image-based technique.

### 7.2.1 Position based servoing




Figure 7.5: Position based visual servoing closed loop control

- **Photogrammetric technique**
- **Stereoscopic vision:** This methodology uses two separate views of the scene as taken from two viewports (from two cameras) and calculates the depth of various objects and areas using information from both views. For more details about stereoscopic vision see chapter 4.2
- **Extracting depth from motion** This methodology is very similar to stereoscopic vision and is also known as *monocular* or *motion stereo*. The difference is that instead of using two views from two distinct cameras this methodology uses two views from the same camera but from different points in time. A very important assumption for this methodology is to assume that two consecutive views from the video frame do not change significantly, so that some feature points can be matched in both views in order to calculate the depth information. This methodology is cheaper in terms of hardware but it fails to extract depth informations in cases where the robot is completely still.
- **Servoing using 3D sensors**

### 7.2.2 Image based servoing

Image based servoing is a methodology for controlling a robot by directly using features extracted from the image as well as positions on the image plane. The goal of this methodology is to drive the robot in such a way so that the video frame is changed




Figure 7.6: Position based visual servoing using depth from motion, stereo vision or 3D sensors, from which the desired position  $\mathbf{x}_d$  is calculated and used to drive the robot.

from an initial view to a final, desired view (see figure 7.7 left and right frames). The commands that are sent to the robot from this methodology are defined in image space and not in the robot's task space. Moreover the distances calculated in image space are not directly related to distances in task space.




Figure 7.7: Image based visual servoing. The robot arm is controlled using the information gained from the video frames. The frames are 2Dimensional and thus the detected objects can have only 3 degrees of freedom which means we can mainly control 3 independent variables, here the  $x, y, \theta$  variables. The left image is the initial frame and the right image is the frame where the object is at the target pose.

The image based visual servoing control system as depicted in figure 7.8 consists of the **Image Controller**, the **Plant** (robot) and the **feedback term**. The Image controller is a simple **PD Controller** (PID can also be used, but in servo systems PD is more common) which outputs commands to be executed in the plant. These commands are not to be confused with the robot's internal controller commands. These commands are to be used to control the robot in task space, whereas the internal controller drives each joint to the desired angle. The feedback used to calculate the error for the controller, uses the camera's output and based on that it calculates the vector from the detected tool's center of mass to the center of the image frame (feature extraction).

$$\mathbf{x}[(k+1)T] = \mathbf{x}[kT] + \mathbf{u}[kT] \quad (7.2.2.1)$$

where  $\mathbf{x}[kT] = [x, y, z, \theta, \varphi, \psi]^\top$  and the discrete PID control law is given by equation 7.2.2.2

$$\mathbf{u}[kT] = K_p \left[ \mathbf{e}[kT] + \frac{T}{T_i} \sum_{i=0}^{k-1} \mathbf{e}[iT] + \frac{T_d}{T} (\mathbf{e}[kT] - \mathbf{e}[(k-1)T]) \right] \quad (7.2.2.2)$$

where  $\mathbf{e}[kT] = [e_x, e_y, e_z, e_\theta, e_\varphi, e_\psi]^\top$ .




Figure 7.8: Image based visual servoing closed loop control

### 7.3 Firm grasping algorithm & Force control

In order to control the Barrett hand gripper of this thesis and make sure that the gripper grasps firmly the surgical tool, a hybrid force control scheme must be implemented. This control scheme is hybrid because it combines positions measurements with force measurements. In the context of the Barrett hand, the position of a finger is known using the forward kinematics of the finger's joint angles and the forces are measured using the tactile sensors array which are distributed in the surface of the gripper and the fingers. The proposed force control system is illustrated in the block diagram 7.9.




Figure 7.9: Force control on a Barrett Hand gripper finger

To ensure a firm grasp of the surgical tool, so that it can later be more easily and precisely manipulated to do pivot surgical motions, a reference force is required to be defined. The following analysis is for one of the 3 fingers of the gripper and it is the same for all of them. Following the block diagram of 7.9, if the actual measured force is 0, then the finger is not in contact, which means that there is an error in force.

This force error produces a position error via a first PD controller. This position error will be positive and will be added to the current measured position and thus will make the finger move closer to the object. When the finger contacts for the first time the object, then the measured force is non-zero, but it is still less than the desired force that is required for a firm grasp. This means that there is still a force error, which again produces a positions error and again makes the finger move even closer ("squeeze") the object. This control loop repeats until a satisfactory contact is reached and until the desired force is exerted on the object. If the measured force is bigger than the desired value, then the force error is negative and thus a negative position error is generated which in its turn makes the finger to move slightly away from the object, in order to reduce the exerted force. More about force control principles can be found at <http://www.osrobotics.org/osr/control/principles.html> as well as an example of force control in ROS and Gazebo at <http://www.osrobotics.org/osr/control/examples.html>.

# Chapter 8

## ROS framework

### 8.1 Introduction to the ROS framework

**ROS** is an open-source robotics software framework. It is a meta-operating system, which means that it provides its own abstractions on top of the host's operating system including filesystem, hardware abstractions, low-level device control, package management and networking. It also provides tools and services to develop large, scalable robotics software, it supports a wide variety of libraries and programming languages and it has a huge community, support and documentation resources.

#### 1. ROS Filesystem

- Packages
- Metapackages
- Package Manifests
- Messages
- Services
- Launch files

#### 2. ROS Computation Graph

- Nodes
- Master
- Parameter Server
- Topics
- Bags

#### 3. ROS Community

- Distributions
- Repositories
- ROS Wiki
- ROS Answers

#### 4. ROS Tools

- Gazebo
- RViz
- Moveit
- Filesystem tools




Figure 8.1: Communication diagram of 2 ROS nodes with a topic and a service

A **node** is a small piece of code that runs in a process and executes a task. Usually nodes should execute one task and in cases of more complex robot applications, multiple nodes are combined and run together to run more complicated tasks. Nodes are combined together into a graph and communicate with each other using topics, remote procedure call services and the parameter server. Splitting the robot application into multiple smaller nodes is more fault tolerant, because an issue or a crash in one node does not affect much the other nodes (individual nodes are isolated). Scalability (i.e. the ability to easily add new features and code) using nodes is also much easier, but the code complexity increases with the number of nodes, the more the number of nodes, the more the interconnections between them and the harder it is to debug issues or to run and maintain the nodes.

**Topics** are namespaced buses over which nodes exchange messages. A topic is a stream of messages with a **publish and subscribe** mechanism, which decouples the production of information from its consumption. Topics connect nodes in a many-to-many relationship, which means that all nodes that are interested in the topic data subscribe to the relevant topic and all nodes that generate data publish to the relevant topic. Topic data have a predefined **message** type that can be a String, Float, Integer, Array or even more complicated custom object structures.

## 8.2 Gazebo simulation environment

Gazebo <http://gazebosim.org/> is the most popular simulation software used in most ROS projects and it is a very important tool that mimics the real world and how the robot would realistically interact with it. It comes with a wide range of features such as:

- Dynamics simulation with physics engines including ODE, Bullet and others, to efficiently simulate forces, torques and collisions
- Advanced 3D graphics utilizing OGRE that provide realistic environment rendering, lighting, shadows and textures.

- Sensors like 2D/3D cameras (optionally with simulated noise), laser range finders, contact sensors, force and torque sensors
- customizable plugins, pre-made 3D objects, environments and robots and many more




Figure 8.2: Simulation environment in Gazebo

The main environment setup of this thesis was designed using the Gazebo simulation environment and it consists of the following objects:

- the robot arm, KUKA<sup>®</sup>iiwa14 lbr, being at the center of the setup
- the robot base, so that the robot arm can better reach the tools and the surgical site and have more flexibility in movement
- 2 tables, one for the tools and one for the surgical site
- 4 surgical tools, using a modified version of the surgical tools used in the Raven II surgical platform
- a mounting dock, which has holes that have the same role as the trocars (small tubes from which the surgical tool is inserted). Initially a mounting dock with 4 same holes of 4mm diameter was used, but it was later replaced with a new one with holes of variable diameters to test feasibility of pivot motions. Larger diameters means more space for motion planner to search for solution and thus more probable to find a solution.




Figure 8.3: Control & Hardware Interfaces in Gazebo and ROS

### 8.3 Visualization with RViz

RViz is one of the most important and most used tools in robotic applications development and is a 3D visualizer for the Robot Operating System framework. RViz functionality should not be confused with that of Gazebo, because the first one visualizes the robot state and the **perceived** world (perceived objects or other calculations related to the world) whereas the second one simulates the real world.




Figure 8.4: RViz: Visualizing the robot state as well as the state of the perceived world. In this screenshot, various poses of the robot are shown: 1) the current actual real pose of the robot, 2) the planned pose and 3) the goal pose, which can freely be moved within the RViz environment.

The objects that appear in RViz can either be visualized from approximations calculated from actual measurements from the robot (for example a point cloud) or can be manually loaded, in which case we make an assumption that the robot already "knows" the exact position, orientation, size and shape of the object, which is rarely the case in real life scenarios. It is important to mention, that every such object is taken into consideration in collision checks and in path planning algorithms.

## 8.4 Motion Planning with Moveit




Figure 8.5: MoveIt ROS Architecture

When using the Moveit ROS library a set of parameters need to be configured in order to generate the desired commands for the controller:

- **Position tolerance:** The radius of the sphere that the end-effector must reach. This is the maximum allowed error in the target's position. This tolerance is typically much smaller inside the surgical site, to avoid fatalities.
- **Orientation tolerance:** The tolerance or maximum allowed error for roll, pitch and yaw, in radians
- **Maximum planning time:** Maximum amount of time to be used when planning a trajectory
- **Replanning:** Specify whether the robot is allowed to replan if it detects changes in the environment
- **Maximum planning attempts:** Number of times the motion plan is to be computed from scratch before the shortest solution is returned
- **Base frame:** The frame in respect to which the motion plan is calculated.

- **Jump threshold:** This parameter sets an upper bound to the amount of "jump" (change in distance) that can occur between two consecutive trajectory points in joint positions. Disabling the jump threshold while operating real hardware can cause large unpredictable motions of redundant joints and could be a safety issue
- **Velocity scaling factor:** The approaching motion needs to be slower. We reduce the speed of the robot arm via a scaling factor of the maximum speed of each joint. Note this is not the speed of the end effector point
- **End-effector step:** The resolution at which the Cartesian path is interpolated or the max step in Cartesian translation
- **Planner algorithm:**
- **Fraction:** The fraction of the path achieved as described by the waypoints

Typical motion planning parameter values outside of surgical site:

- Position tolerance: 50 - 500 $\mu\text{m}$
- Orientation tolerance: 0.00005 deg
- Planning time: 5-10s
- Replanning allowed: true

Typical motion planning parameter values inside surgical site:

- Position tolerance: 5 $\mu\text{m}$
- Orientation tolerance: 0.000005deg
- Planning time: 5s
- Replanning allowed: true
- End-effector interpolation step: 1mm
- Maximum velocity scaling factor: 0.5
- Maximum planning attempts: 6

Sometimes the motion planner finds a solution but the execution from the controller is aborted. After many iterations of the same experiment this does not happen always, which means that the feasibility of the execution of the movement by the controller depends on the initial state of the robot, i.e. if initially some joints of the robot are at their boundaries, then the next commanded trajectory maybe unfeasible. Another reason that the path planner may fail is the probabilistic nature of the path planning algorithms (see also RRT and PRM algorithms in chapter 6).

At each time step it is important to publish a custom message containing all the information about the kinematic state of the robot. In this thesis a custom **ROS** message was created containing a tf transform with a 3D vector for the position and a quaternion for the rotation and a custom 6-by-7 matrix containing the values of the Jacobian. The MoveIt library, from which the kinematic state of the robot is obtained, returns the orientation of the end effector as a 3-by-3 rotation matrix, but in the ROS tf message

it must be expressed as a quaternion. To convert the matrix to a quaternion we first calculate the euler angles and then use these values to construct the quaternion “vector”. The quaternion representation of rotation is often preferred in robotic applications due to its efficiency in calculations and memory. To convert the transformation matrix to euler angles and then to quaternions the following formulas were used:

$$T = \begin{bmatrix} r_{11} & r_{12} & r_{13} & x \\ r_{21} & r_{22} & r_{23} & y \\ r_{31} & r_{32} & r_{33} & z \\ 0 & 0 & 0 & 1 \end{bmatrix}$$

$$\varphi = \text{atan2}(r_{21}, r_{11})$$

$$\theta = \text{atan2}(-r_{31}, \sqrt{r_{11}^2 + r_{21}^2})$$

$$\psi = \text{atan2}(r_{32}, r_{33})$$

where  $T$  is the transformation matrix and  $\varphi, \theta, \psi$  are the roll, pitch and yaw (Euler) angles.

## 8.5 Tools, Packages and Libraries

- **moveit** libraries for path planning and kinematics solutions (see more in 8.4). More specifically the following libraries, among others, were used moveit\_core, moveit\_ros\_planning\_interface, moveit\_ros\_planning, moveit\_visual\_tools
- **tf2** is an important library that allows to keep track of multiple coordinate frames over time as well as calculate poses with respect to a given reference frame and apply transformations to vectors or other transformations (see more in bibliography in [20] or at <http://wiki.ros.org/tf2>).
- **geometry\_msgs**: used mostly for the Pose and PoseWithCovarianceStamped messages to exchange robot and object poses between nodes and give them as input to moveit’s path planners
- **Eigen**: a c++ library to efficiently do linear algebra calculations (matrix multiplications, inversions, vector calculations and simple geometrix calculations like finding the distance between a line and a point)
- **OpenCV2** together with the **cv\_bridge** ROS package for the computer vision tasks of this thesis
- **numpy**
- Stereo Vision with **stereo\_image\_proc**
- State machines with **Smach**
- **actionlib**
- **barrett\_hand** [https://github.com/RobotnikAutomation/barrett\\_hand.git](https://github.com/RobotnikAutomation/barrett_hand.git)

- **gazebo-pkgs** <https://github.com/JenniferBuehler/gazebo-pkgs.git>
- **moveit-pkgs** <https://github.com/JenniferBuehler/moveit-pkgs.git>
- **general-message-pkgs** <https://github.com/JenniferBuehler/general-message-pkgs.git>

# Chapter 9

# Experiments and Results

## 9.1 Robot Planner 1: Simple MoveIt planning

In this first experiment we are testing some simple trajectories with the surgical tool already attached to the robot arm's end effector. The path is designed using the appropriate coordinates and orientations so that the robot begins from the home position, then visits the table with the surgical tools and then visits the other table on top of which the mounting dock is placed. Upon arrival at the mounting dock, the robot inserts the tool inside a hole (we consider these holes to be a simplistic alternative to the trocars used in real operations), then executes a simple pivot motion, while the tool is still inserted and then the tool gets ejected from the mounting dock's hole.

The aim of this experiment is to test the overall behaviour of the robot inside the work space, before implementing more complex path planning algorithms.




Figure 9.1: Experiment 1

| Robot Planner 1           | <b>RRTConnect</b>                                  |                  |                          |                  |
|---------------------------|--|------------------|--------------------------|------------------|
|                           | <b>Fake tool picking trajectory</b>                |                  |                          |                  |
| Experiment                | Approach planning time                             | Execution status | Move away planning time  | Execution status |
| 1                         | 0.060402   | 1                | 0.144881                 | 1                |
| 2                         | 0.06053  | 1                | 0.058341                 | 1                |
| 3                         | 0.064706   | 1                | 0.060981                 | 1                |
| 4                         | 0.059789   | 1                | 0.119351                 | 1                |
| 5                         | 0.164789   | 1                | 0.330373                 | 1                |
| 6                         | 0.147037   | 1                | 0.289805                 | 1                |
| 7                         | 0.18233  | 1                | 0.093362                 | 1                |
| 8                         | 0.054469   | 1                | 0.062209                 | 1                |
| 9                         | 0.05313  | 1                | 0.409191                 | 1                |
| 10                        | 0.105909   | 1                | 0.307963                 | 1                |
| <b>Average</b>            | 0.0953091  | 1                | 0.1876457                | 1                |
| <b>Standard deviation</b> | 0.048230   | -                | 0.125796                 | -                |
|                           | <b>Insertion &amp; Pivot trajectories</b>          |                  |                          |                  |
| Experiment                | Insertion planning time                            | Execution status | Pivot planning time      | Execution status |
| 1                         | 0.216565   | 1                | 3.639193                 | 1                |
| 2                         | 0.057143   | 1                | 0.057187                 | 1                |
| 3                         | 0.073242   | 1                | 0.072451                 | 1                |
| 4                         | 0.056255   | 1                | 0.068156                 | 1                |
| 5                         | 0.16178  | 1                | 0.150123                 | 1                |
| 6                         | 0.071426   | 1                | 0.065059                 | 1                |
| 7                         | 0.155125   | 1                | -                        | 0                |
| 8                         | 0.315921   | 1                | 0.194663                 | 1                |
| 9                         | 0.127381   | 1                | 0.19026                  | 1                |
| 10                        | 0.396182   | 1                | 0.075866                 | 1                |
| <b>Average</b>            | 0.163102   | 1                | 0.5014398                | 0.9              |
| <b>Standard deviation</b> | 0.110001   | -                | 1.110582                 | -                |
|                           | <b>Reverse pivot &amp; retraction trajectories</b> |                  |                          |                  |
| Experiment                | Reverse pivot planning time                        | Execution status | retraction planning time | Execution status |
| 1                         | 2.419514   | 1                | 2.388166                 | 1                |
| 2                         | 1.386188   | 1                | 2.874223                 | 0                |
| 3                         | -  | 0                | 5.106926                 | 1                |
| 4                         | 5.466561   | 1                | 4.562506                 | 1                |
| 5                         | 5.62329  | 1                | 5.587679                 | 1                |
| 6                         | 5.488728   | 0                | -                        | 0                |
| 7                         | -  | 0                | -                        | 0                |
| 8                         | -  | 0                | -                        | 0                |

|                           |          |     |          |     |
|---------------------------|----------|-----|----------|-----|
| 9                         | 5.291442 | 1   | 5.096234 | 1   |
| 10                        | 5.381595 | 1   | 5.576362 | 1   |
| <b>Average</b>            | 4.436760 | 0.6 | 4.456014 | 0.6 |
| <b>Standard deviation</b> | 1.628910 | -   | 1.204682 | -   |

Table 9.1: Time results for robot planner 1 using the RRTConnect path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.000005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position.

| Robot Planner 1           |                         | RRT*                                    |                         |                  |
|---------------------------|-------------------------|---|-------------------------|------------------|
|                           |                         | Fake tool picking trajectory            |                         |                  |
| Experiment                | Approach planning time  | Execution status                        | Move away planning time | Execution status |
| 1                         | 5.096772                | 1                                       | 5.023175                | 1                |
| 2                         | 5.015857                | 1                                       | 5.034447                | 1                |
| 3                         | 5.01843                 | 1                                       | 5.101766                | 1                |
| 4                         | 5.074703                | 1                                       | 5.089464                | 1                |
| 5                         | 5.019108                | 1                                       | 5.056875                | 1                |
| 6                         | 5.011631                | 1                                       | 5.217069                | 1                |
| 7                         | 5.119638                | 1                                       | 5.027692                | 1                |
| 8                         | 5.121159                | 1                                       | 5.040244                | 1                |
| 9                         | 5.12812                 | 1                                       | 5.098381                | 1                |
| 10                        | 5.343964                | 1                                       | 5.374314                | 1                |
| <b>Average</b>            | 5.0949382               | 1                                       | 5.1063427               | 1                |
| <b>Standard deviation</b> | 0.094669                | -                                       | 0.104655                | -                |
|                           |                         | Insertion & Pivot trajectories          |                         |                  |
| Experiment                | Insertion planning time | Execution status                        | Pivot planning time     | Execution status |
| 1                         | 5.200983                | 1                                       | 5.044568                | 1                |
| 2                         | 5.009846                | 1                                       | -                       | 0                |
| 3                         | 5.064216                | 1                                       | 5.085314                | 1                |
| 4                         | 5.145115                | 1                                       | 5.059245                | 1                |
| 5                         | 5.019322                | 1                                       | 5.173925                | 1                |
| 6                         | 5.015804                | 1                                       | -                       | 0                |
| 7                         | 5.033637                | 1                                       | -                       | 0                |
| 8                         | 5.159212                | 1                                       | 5.100395                | 1                |
| 9                         | 5.134356                | 1                                       | 5.081432                | 1                |
| 10                        | 5.052                   | 0                                       | -                       | 0                |
| <b>Average</b>            | 5.083449                | 0.9                                     | 5.090813                | 0.6              |
| <b>Standard deviation</b> | 0.066253                | -                                       | 0.041338                | -                |
|                           |                         | Reverse pivot & retraction trajectories |                         |                  |

| Experiment                | Reverse pivot planning time | Execution status | retraction planning time | Execution status |
|---------------------------|-----------------------------|------------------|--------------------------|------------------|
| 1                         | -                           | 0                | -                        | 0                |
| 2                         | -                           | 0                | -                        | 0                |
| 3                         | -                           | 0                | 5.508861                 | 1                |
| 4                         | -                           | 1                | 5.417935                 | 1                |
| 5                         | 5.057058                    | 1                | 5.093558                 | 1                |
| 6                         | -                           | 0                | -                        | 0                |
| 7                         | -                           | 0                | -                        | 0                |
| 8                         | -                           | 0                | -                        | 0                |
| 9                         | -                           | 0                | -                        | 0                |
| 10                        | -                           | 0                | 5.358954                 | 0                |
| <b>Average</b>            | inconclusive                | 0.2              | inconclusive             | 0.3              |
| <b>Standard deviation</b> | inconclusive                | -                | inconclusive             | -                |

Table 9.2: Time results for robot planner 1 using the RRT\* path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.000005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position.

## 9.2 Robot Planner 2: Simulation layout and reachability experiments

In this experiment, we plan a path such that the robot arm will visit all holes of the mounting dock and will try the insertion movement of the surgical tool. This experiment is very useful, because it shows whether all holes of the mounting dock are **reachable** (inside the robot's work space) and if so, how **dexterous** the robot will be in pivoting around each hole, i.e. how free the robot arm is to execute pivot motions.

| Robot Planner 2a | RRTConnect                     |                  |                          |                  |
|------------------|--------------------------------|------------------|--------------------------|------------------|
|                  | Insertion & Pivot trajectories |                  |                          |                  |
| Experiment       | Trocars1 insertion time        | Execution status | Trocars1 retraction time | Execution status |
| 1                | 0.060728                       | 1                | 2.875072                 | 1                |
| 2                | 0.070508                       | 1                | 5.235667                 | 1                |
| 3                | 0.071487                       | 1                | 5.239014                 | 1                |
| 4                | 0.059288                       | 1                | 1.733352                 | 1                |
| 5                | 0.053619                       | 1                | 3.376982                 | 1                |
| 6                | 0.062                          | 1                | 5.389454                 | 1                |
| 7                | 0.084007                       | 1                | -                        | 0                |

| 8   | 0.058306                | 1                | 5.254352                | 1                |
|---|-------------------------|------------------|-------------------------|------------------|
| 9   | 0.046925                | 1                | 4.90185                 | 1                |
| 10  | 0.060491                | 1                | 5.073171                | 1                |
| <b>Average</b>                            | 0.062736                | 1                | 4.342102                | 0.9              |
| <b>Standard deviation</b>                 | 0.010348                | -                | 1.335526                | -                |
| <b>Insertion &amp; Pivot trajectories</b> |                         |                  |                         |                  |
| Experiment                                | Approach trocar2 time   | Execution status | Trocar2 insertion time  | Execution status |
| 1   | 2.67618                 | 1                | 0.168283                | 1                |
| 2   | 5.187283                | 1                | 0.179048                | 1                |
| 3   | 0.050117                | 1                | 0.057194                | 1                |
| 4   | 1.538822                | 1                | 0.184641                | 1                |
| 5   | 1.62114                 | 1                | 0.253224                | 1                |
| 6   | 5.397757                | 1                | 0.268188                | 1                |
| 7   | 5.379305                | 1                | 0.384924                | 1                |
| 8   | 5.401832                | 1                | 0.193265                | 1                |
| 9   | 2.845741                | 1                | 0.267069                | 1                |
| 10  | 5.355111                | 1                | 0.250265                | 1                |
| <b>Average</b>                            | 3.545329                | 1                | 0.220610                | 1                |
| <b>Standard deviation</b>                 | 2.038595                | -                | 0.086008                | -                |
| <b>Insertion &amp; Pivot trajectories</b> |                         |                  |                         |                  |
| Experiment                                | Trocar2 retraction time | Execution status | Approach trocar3 time   | Execution status |
| 1   | 0.152233                | 1                | 0.214332                | 1                |
| 2   | 0.321677                | 1                | 0.361712                | 1                |
| 3   | 5.404121                | 1                | 5.271597                | 1                |
| 4   | 0.147981                | 1                | 0.15915                 | 1                |
| 5   | 0.333447                | 1                | 0.298799                | 1                |
| 6   | 0.246624                | 1                | 0.209347                | 1                |
| 7   | 0.381983                | 1                | 0.473779                | 1                |
| 8   | 0.219369                | 1                | 0.167211                | 1                |
| 9   | 0.227563                | 1                | 0.297372                | 1                |
| 10  | 5.149372                | 1                | 5.3578                  | 1                |
| <b>Average</b>                            | 1.258437                | 1                | 1.281110                | 1                |
| <b>Standard deviation</b>                 | 2.120018                | -                | 2.128103                | -                |
| <b>Insertion &amp; Pivot trajectories</b> |                         |                  |                         |                  |
| Experiment                                | Trocar3 insertion time  | Execution status | Trocar3 retraction time | Execution status |
| 1   | 0.196175                | 1                | 0.855452                | 0                |
| 2   | 0.412455                | 1                | 1.133213                | 0                |
| 3   | 0.355923                | 1                | 0.814161                | 0                |
| 4   | 0.194839                | 1                | 0.885119                | 0                |
| 5   | 0.351561                | 1                | 0.364089                | 0                |

|                           |          |      |          |       |
|---------------------------|----------|------|----------|-------|
| 6                         | 0.355251 | 1    | 0.826636 | 0     |
| 7                         | 0.336123 | 1    | 0.30715  | 1     |
| 8                         | 0.147867 | 1    | 1.053035 | 0     |
| 9                         | 0.347956 | 0.6  | 0.80884  | 0.37  |
| 10                        | 0.28364  | 0.6  | 0.229825 | 1     |
| <b>Average</b>            | 0.298179 | 0.92 | 0.727752 | 0.237 |
| <b>Standard deviation</b> | 0.088385 | -    | 0.314852 | -     |

Table 9.3: Time results for robot planner 2a using the RRTConnect path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.0005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position.

To overcome the reachability issue shown in Figure 9.2, the algorithm was repeated, but this time using a different simulation layout in Gazebo, in which the mounting dock is closer to the robot and in front of it. This new layout enables the robot to reach all mounting holes with ease and with sufficient dexterity, the robot is free to pivot around.

Observing the screenshots at figure 9.3, it is clear that the robot must always be in an elbow-up configuration in order to avoid collisions with the mounting dock. This constraint can be described either using the relative distance of the third link with the base or the relative angles of the third link’s axis with respect to the axis of the base, as described with more detail in 2.2.3.3. The latter description with angles is easier to implement using the ROS MoveIt! framework, but it would require to solve an extra inverse and forward kinematics problem targeting the third link, instead of the end-effector. To avoid these additional, computationally expensive calculations and simplify the experiments, instead of mathematically describing the constraint, some extra points were added in the trajectory. These points are usually close to the robot’s axis and are such, that moveit will be forced to find a solution with an elbow-up configuration (because there will be no other solution satisfying the target point). Starting with an elbow-up configuration makes the path planner stick with that configuration for most of the path, because otherwise it would make a big jump in the joint state space which is not allowed from the parameters used in the experiments.

| Robot<br>Planner 2b | <b>RRTConnect</b>                         |                  |                         |                  |
|---------------------|---|------------------|-------------------------|------------------|
|                     | <b>Insertion &amp; Pivot trajectories</b> |                  |                         |                  |
| Experiment          | Trocarn insertion time                    | Execution status | Trocarn retraction time | Execution status |
| 1                   | 0.269901                                  | 1                | 0.355588                | 1                |
| 2                   | 0.220509                                  | 1                | 0.255968                | 1                |
| 3                   | 0.260483                                  | 1                | 5.28604                 | 1                |
| 4                   | 0.267778                                  | 1                | 0.267796                | 1                |
| 5                   | 0.388487                                  | 1                | 5.321684                | 1                |

| 6   | 0.316275                | 1                | 0.2088                  | 1                |
|---|-------------------------|------------------|-------------------------|------------------|
| 7   | 0.202614                | 1                | 0.14469                 | 1                |
| 8   | 0.289368                | 1                | 0.275917                | 1                |
| 9   | 0.353631                | 1                | 0.353631                | 1                |
| 10  | 0.185345                | 1                | 0.154755                | 1                |
| <b>Average</b>                            | 0.275439                | 1                | 1.262487                | 1                |
| <b>Standard deviation</b>                 | 0.064555                | -                | 2.131175                | -                |
| <b>Insertion &amp; Pivot trajectories</b> |                         |                  |                         |                  |
| Experiment                                | Approach trocar2 time   | Execution status | Trocar2 insertion time  | Execution status |
| 1   | 0.322578                | 1                | 0.283497                | 1                |
| 2   | 0.209871                | 1                | 0.410543                | 1                |
| 3   | 5.099769                | 1                | 0.296228                | 1                |
| 4   | 0.216997                | 1                | 0.342776                | 1                |
| 5   | 5.328204                | 1                | 0.394472                | 1                |
| 6   | 0.450936                | 1                | 0.249248                | 1                |
| 7   | 0.336209                | 1                | 0.165375                | 1                |
| 8   | 0.397699                | 1                | 0.202118                | 1                |
| 9   | 0.235555                | 1                | 0.333129                | 1                |
| 10  | 0.320059                | 1                | 0.343595                | 1                |
| <b>Average</b>                            | 1.291788                | 1                | 0.302098                | 1                |
| <b>Standard deviation</b>                 | 2.069297                | -                | 0.079229                | -                |
| <b>Insertion &amp; Pivot trajectories</b> |                         |                  |                         |                  |
| Experiment                                | Trocar2 retraction time | Execution status | Approach trocar3 time   | Execution status |
| 1   | 5.374646                | 1                | 5.451335                | 1                |
| 2   | 0.452231                | 1                | 0.253669                | 1                |
| 3   | 0.22638                 | 1                | 0.383933                | 1                |
| 4   | 5.371822                | 1                | 5.611649                | 1                |
| 5   | 0.395787                | 1                | 0.309212                | 1                |
| 6   | 5.15406                 | 1                | 5.515007                | 1                |
| 7   | 4.189377                | 1                | 5.570568                | 1                |
| 8   | 5.167346                | 1                | 5.522056                | 1                |
| 9   | 5.101735                | 1                | 5.452301                | 1                |
| 10  | 5.273342                | 1                | 5.467273                | 1                |
| <b>Average</b>                            | 3.670673                | 1                | 3.953700                | 1                |
| <b>Standard deviation</b>                 | 2.311081                | -                | 2.511216                | -                |
| <b>Insertion &amp; Pivot trajectories</b> |                         |                  |                         |                  |
| Experiment                                | Trocar3 insertion time  | Execution status | Trocar3 retraction time | Execution status |
| 1   | 0.372382                | 1                | 5.34059                 | 1                |
| 2   | 0.280432                | 1                | 0.261765                | 1                |
| 3   | 0.179581                | 1                | 0.187589                | 1                |

|                           |          |   |          |     |
|---------------------------|----------|---|----------|-----|
| 4                         | 0.121094 | 1 | 5.152808 | 1   |
| 5                         | 0.472468 | 1 | -        | 0   |
| 6                         | 0.251195 | 1 | 0.442282 | 0   |
| 7                         | 0.20647  | 1 | 0.318481 | 1   |
| 8                         | 0.178941 | 1 | 0.185758 | 1   |
| 9                         | 0.188906 | 1 | 0.222821 | 1   |
| 10                        | 0.165681 | 1 | 0.170876 | 1   |
| <b>Average</b>            | 0.241715 | 1 | 1.364774 | 0.8 |
| <b>Standard deviation</b> | 0.107534 | - | 2.202951 | -   |

Table 9.4: Time results for robot planner 2b using the RRTConnect path planner algorithm and a different table layout from robot planner 2a. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.0005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position.

Due to the probabilistic nature of the motion planner (in these experiments the OMPL library is used with the RRTConnect path planning algorithm), the solutions to the path planning problem are not always the same and thus it is possible that the robot arm reaches a pose which is close to a singularity

Sometimes, when planning or executing a trajectory the robot may fail to complete the task because it has approached a singularity point. The points of singularity or of low dexterity are those points shown in the screenshot 9.4 which have red color. The color coding is calculated using the equation 5.3.0.4. The values of the Jacobian matrix are calculated at every kinematic state using a custom ROS node that subscribes to the robot's kinematic state (joints' angle positions, velocities, etc) and publishes the values of the Jacobian matrix as well as the forward kinematics solutions, to the /kinematic\_state topic (see figure 9.5).

### 9.3 Robot Planner 3: Trajectory planning

The goal of this third experiment is to design and test only some pivot trajectories. The pivot motions follow the equations described in 6.2. The trajectories that were designed and tested in this group of experiments are the following:

- Line segment
- Circle
- Cubic spline
- B-Spline
- Quintic polynomial in joint space
- Trapezoidal velocity profile in joint space




Figure 9.2: Experiment 2a:




Figure 9.3: Experiment 2b: Running robot planner 2b with a different table layout so that all target poses have improved reachability. Note that all trajectories shown in the screenshots are collision-free, because the robotic arm is in an elbow-up configuration, so that it avoids the collision between the 3rd link of the robot and the mounting dock (green object shown in simulation).

- S-Curve velocity profile in joint space

- Helix




Figure 9.4: Experiment 2b: Singularity failure



Figure 9.5: Custom kinematic state node that subscribes to the joint values and publishes forward kinematics solutions and the jacobian matrix values.

### 9.3.1 Line segment trajectories in task space

The goal of this experiment is to generate a line segment trajectory inside the surgical taskspace which will then be transformed via the fulcrum transformation to a trajectory that the robotic arm can execute. To define a line segment only 2 points are needed, the coordinates of the start and those of the end of the line segment. An other, way of defining a line segment trajectory, is by passing as parameters the coordinates of the start point and a vector attached to that point, whose and points to the end point. The second definition of the line segment can be very useful in cases where the direction of the line is needed.

In the diagram 9.7 one can see the RCM error values with respect to time. The x-axis shows the ROS time in seconds and the y-axis the RCM error in logarithmic scale. The robot starts from the home position where the rcm error is bigger, then approaches the fulcrum point, where the error decreases and then it executes the line segment pivot trajectory where the error is bounded in the magnitude of less than a micrometer  $10^{-6}m$  then stays constant, then changes again during the execution of the reverse line-segment trajectory and then finally it stays constant while the robot stays still in the initial insertion position. The RCM error while the robot is inserted but still and the error while the robot executes a pivot trajectory are studied separately.




Figure 9.6: Experiment 3b: Create the line segment trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP. (a) Preparatory path to achieve elbow-up pose, (b) transformed line segment trajectory for the end-effector to follow, (c) transformed line segment trajectory with respect to the tool base frame (there is an offset from the end-effector see 2.1.1), (d) fulcrum reference frame 2  $\{F_2\}$ , (e) line segment trajectory in surgical taskspace, (f) line of the axis along the length of the surgical tool, which is used to calculate the distance error (RCM deviation)




Figure 9.7: Experiment 3b: RCM error diagram from home position to line and reverse-line segment trajectories.




Figure 9.8: Experiment 3b: RCM error distributions, measurements from 10 iterations of the same experiment. From left to right: distribution of all measurements, distribution of measurements while the robot was pivoting, distribution of measurements while the robot was inserted but still.

|                                 | Average [m]<br>(accuracy) | Standard Deviation [m]<br>(repeatability) | sample size |
|---------------------------------|---------------------------|---|-------------|
| <b>while pivoting</b>           | $2.112649 \cdot 10^{-6}$  | $1.609277 \cdot 10^{-6}$                  | 2309        |
| <b>while inserted and still</b> | $2.948652 \cdot 10^{-7}$  | $2.948652 \cdot 10^{-7}$                  | 2696        |

Table 9.5: Accuracy and repeatability of the line segment experiment, calculated using measurements from 10 iterations of the same experiment




Figure 9.9: Experiment 3b: Manipulability plots of the whole trajectory the robot executed during 2 iterations of the same experiment

Note that although this type of trajectory is trivial in robot planner, this specific line segment trajectory should not be confused with ROS MoveIt line segment trajectories. The line-segment studied in this experiment is linear when defined in the surgical task-space, but it is highly non-linear when transformed via the fulcrum transformation and it has a curved shape. The only exceptions to this transformation is for line segments that lie on the direction defined by the radius unit vector  $\hat{\mathbf{r}}$  of the spherical coordinate system of the Fulcrum reference frame, or equivalently the points  $A, B$  defining the line-segment and the origin  $O$  of the reference frame, must be collinear. These exceptions can also

be planned by the MoveIt framework and are also known as and referenced throughout this thesis, as insertion movements. Let  $\overrightarrow{AB}$  be the vector representing the line segment, then for the points  $A, B$  the following must hold, in order for the line segment to be invariant under the fulcrum transformation in terms of shape (i.e. the line to remain a line).

$$\overrightarrow{AB} = \overrightarrow{OB} - \overrightarrow{OA} \quad (9.3.1.1)$$

and

$$\overrightarrow{OB} = r\overrightarrow{OA}, \quad r \in \mathbb{R} \quad (9.3.1.2)$$




Figure 9.10: Experiment 3b: Line segment trajectory that is invariant under the fulcrum transformation, in terms of shape (the line remains a line).

| Robot Planner 3b | Approach and <b>line segment pivot</b> trajectories with <b>RRTConnect</b> |                  |   |                  |  |
|------------------|--|------------------|---|------------------|--|
|                  | <b>elbow-up preparatory path</b>   |                  |   |                  |  |
| Experiment       | Elbow-up Start pose planning time (sec)                                    | Execution status | Elbow-up preparation path planning time (sec) | Execution status |  |
| 1                | 0.221091   | 1                | 0.074075                                      | 1                |  |
| 2                | 0.19466  | 1                | 0.194823                                      | 1                |  |
| 3                | 0.268828   | 1                | 0.073928                                      | 1                |  |
| 4                | 0.154783   | 1                | 0.049908                                      | 1                |  |
| 5                | 0.110496   | 1                | 0.104181                                      | 1                |  |
| 6                | 0.155316   | 1                | 0.061127                                      | 1                |  |
| 7                | 0.140189   | 1                | 0.048735                                      | 1                |  |
| 8                | 0.166412   | 1                | 0.261208                                      | 1                |  |

| 9                                      | 0.121243                                    | 1                | 0.247453                                      | 1                |
|--|---|------------------|---|------------------|
| 10                                     | 0.209206                                    | 1                | 0.054966                                      | 1                |
| <b>Average</b>                         | 0.174222                                    | 1                | 0.117040                                      | 1                |
| <b>Standard deviation</b>              | 0.049002                                    | -                | 0.084238                                      | -                |
| <b>Approach &amp; Insertion</b>        |   |                  |   |                  |
| Experiment                             | Approach fulcrum 2 path planning time (sec) | Execution status | Insertion path planning time (sec)            | Execution status |
| 1                                      | 0.067982                                    | 1                | 0.30244                                       | 1                |
| 2                                      | 0.345301                                    | 1                | 0.325638                                      | 1                |
| 3                                      | 0.112407                                    | 1                | 0.173074                                      | 1                |
| 4                                      | 0.054112                                    | 1                | 0.194001                                      | 1                |
| 5                                      | 0.117048                                    | 1                | 0.23512                                       | 1                |
| 6                                      | 0.055864                                    | 1                | 0.284625                                      | 1                |
| 7                                      | 0.07501                                     | 1                | 0.231642                                      | 1                |
| 8                                      | 0.170249                                    | 1                | 0.105259                                      | 1                |
| 9                                      | 0.102762                                    | 1                | 0.374426                                      | 1                |
| 10                                     | 0.064243                                    | 1                | 0.269333                                      | 1                |
| <b>Average</b>                         | 0.116498                                    | 1                | 0.249556                                      | 1                |
| <b>Standard deviation</b>              | 0.088078                                    | -                | 0.078941                                      | -                |
| <b>Line segment pivot trajectories</b> |   |                  |   |                  |
| Experiment                             | Line segment path planning time (sec)       | Execution status | Reverse line segment path planning time (sec) | Execution status |
| 1                                      | 5.326128                                    | 1                | 5.486623                                      | 1                |
| 2                                      | 0.479823                                    | 1                | 5.279854                                      | 1                |
| 3                                      | 0.288405                                    | 1                | -   | 0                |
| 4                                      | 0.295343                                    | 1                | -   | 0                |
| 5                                      | 0.225066                                    | 1                | 5.445483                                      | 1                |
| 6                                      | 5.132968                                    | 1                | -   | 0                |
| 7                                      | 0.300322                                    | 1                | 5.285311                                      | 1                |
| 8                                      | 5.484813                                    | 1                | 5.403696                                      | 1                |
| 9                                      | 0.297406                                    | 1                | 5.309383                                      | 1                |
| 10                                     | 0.259739                                    | 1                | 5.285902                                      | 1                |
| <b>Average</b>                         | 1.809001                                    | 1                | 5.356607                                      | 0.7              |
| <b>Standard deviation</b>              | 2.421448                                    | -                | 0.086818                                      | -                |

Table 9.6: Time results for robot planner 1 using the RRTConnect path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.000005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position.

### 9.3.2 Circular trajectories in task space

The goal of this experiment is to generate a circular trajectory inside the surgical taskspace which will then be transformed via the fulcrum transformation to a trajectory that the robotic arm can execute. To define a circular trajectory in the taskspace, two parameters are required: the  $(x, y, z)$  coordinates of the circle's center and it's radius  $r$ .




Figure 9.11: Experiment 3a: Create circular trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP.

Note that in this experiment (see screenshot 9.11), the trivial case is examined where the circle is parallel to the  $xy$  plane of the fulcrum's coordinate system. That is because the parametric definition if the circle, can be easily expressed when in a standard plane of the coordinate system i.e.  $xy$ ,  $xz$  or  $yz$  planes and not in an arbitrary orientation.

### 9.3.3 Cubic Spline trajectories in task space

The goal of this experiment is to generate a cubic spline trajectory inside the surgical taskspace which will then be transformed via the fulcrum transformation to a trajectory that the robotic arm can execute.




Figure 9.12: Experiment 3a: A more detailed view of the circular trajectories. (a) the original circular trajectory designed inside the surgical taskspace, (b) the transformed trajectory that the base of the surgical tool will follow, (c) the actual transformed trajectory that the robot's end-effector will follow




Figure 9.13: Experiment 3c: Create the cubic spline trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP.

As seen on the screenshot 9.13, for the surgical task there are 4 four points that were

selected to create 3 cubic splines. The points that define the trajectory were:

$$\begin{aligned}\mathbf{x}_1 &= [-0.1, -0.1, -0.2] \\ \mathbf{x}_2 &= [0.1, -0.1, -0.1] \\ \mathbf{x}_3 &= [0.1, 0.1, -0.2] \\ \mathbf{x}_4 &= [-0.1, -0.1, -0.2] = \mathbf{x}_1\end{aligned}$$

and a constant derivative for all points of  $\mathbf{x}_d = [0.1, 0.1, 0.1]$ . Note that this derivative describes the shape and smoothness at the points that connect 2 consecutive splines. These derivatives may not necessarily express a velocity in the cartesian space. That is because this derivative is calculated with respect to the path variable  $s$ . The time derivative of the trajectory would be calculated using the chain rule:

$$\begin{aligned}\dot{\mathbf{x}} &= \frac{d\mathbf{x}}{dt} \\ &= \frac{d\mathbf{x}(s)}{dt} = \frac{d\mathbf{x}(s(t))}{dt} \\ &= \frac{d\mathbf{x}}{ds} \cdot \frac{ds}{dt} \\ &= \mathbf{x}_d \cdot \frac{ds}{dt}\end{aligned}\tag{9.3.3.1}$$

### 9.3.4 B-Spline trajectories in task space




Figure 9.14: Experiment 3d: Create the B-spline trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP.

### 9.3.5 Polynomial trajectories in joint space

The goal of this experiment is to generate a trajectory in joint space using a polynomial of 5th degree (see 6.3.1). To generate this trajectory, at least 2 points are needed in the cartesian space. For each of these points the inverse kinematics problem is solved. The joint values of the first point are used as the start points of the trajectory and the joint values of the second point are used as the end points. The velocities and accelerations are chosen to be zero for both start and end positions. The poses of the 2 points that were used as input to the 2 IK problems are

$$T_A = \begin{bmatrix} & & & 0.1 \\ & \mathbf{R}_{\text{rpy}} & & 0.1 \\ 0 & 0 & 0 & 1.95 \end{bmatrix}$$

$$T_B = \begin{bmatrix} & & & 0.4 \\ & \mathbf{R}_{\text{rpy}} & & 0.1 \\ 0 & 0 & 0 & 1.95 \end{bmatrix}$$

where

$$\mathbf{R}_{\text{rpy}} = \mathbf{Rot}(\hat{\mathbf{z}}, 2.952052) \cdot \mathbf{Rot}(\hat{\mathbf{y}}, 1.311528) \cdot \mathbf{Rot}(\hat{\mathbf{x}}, -1.750799)$$

and the solutions chosen for each point are

$$\mathbf{q}_A = \begin{bmatrix} 1.148534 \\ -0.583084 \\ -0.212395 \\ -1.430756 \\ 0.609015 \\ 1.168518 \\ -0.523555 \end{bmatrix} \quad \text{and} \quad \mathbf{q}_B = \begin{bmatrix} 2.293053 \\ -0.277892 \\ -1.795364 \\ -0.941923 \\ 0.876039 \\ 1.451593 \\ -0.916277 \end{bmatrix}$$




Figure 9.15: Experiment 3e: Polynomial trajectories of 5th degree for each of the 7 joints. The trajectory is computed at 60 sampling points.

### 9.3.6 Trajectories in joint space with trapezoidal velocity profile

The goal of this experiment is to generate a trajectory in joint space using a trapezoidal velocity profile. The start and end points as well as the inverse kinematics solutions for these points are the same as those in 9.3.5.




Figure 9.16: Experiment 3f: Trajectory using a trapezoid velocity profile. The time constant (also known as blend time) is  $\tau = 15$  seconds and the total trajectory duration is 60 seconds. The trajectory is computed at 60 sampling points.




Figure 9.17: Experiment 3f: Trajectory using a trapezoid velocity profile. The time constant (also known as blend time) is  $\tau = 30$  seconds and the total trajectory duration is 60 seconds. Note that the blend time is chosen as half of the total duration which has as a result the linear segment (constant velocity) to disappear and create a "bang-bang" trajectory. In control theory, a "bang-bang" controller, is a controller that switches abruptly between two states. The trajectory is computed at 60 sampling points.

### 9.3.7 Trajectories in joint space with s-curve velocity profile

The goal of this experiment is to generate a trajectory in joint space using a smooth s-curve velocity profile. The start and end points as well as the inverse kinematics solutions for these points are the same as those in 9.3.5.




Figure 9.18: Experiment 3g: Trajectory using a s-curve velocity profile. The time constants are  $\tau_1 = \tau_2 = 6$  seconds and the total trajectory duration is 60 seconds. The trajectory is computed at 60 sampling points.

### 9.3.8 Helical trajectories in task space

The goal of this experiment is to generate a helical trajectory inside the surgical taskspace which will then be transformed via the fulcrum transformation to a trajectory that the robotic arm can execute. To define a helical trajectory in the taskspace, two parameters are required: the  $(x, y, z)$  coordinates of the helix center, its radius  $r$ , as well as the number of cycles  $\tau$  of the helix and slope parameter  $\beta$ .




Figure 9.19: Experiment 3h: Create helical trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot’s TCP.

#### 9.4 Robot Planner 4: Simple cube pick-and-place experiment

In this experiment we plan a simple pick-and-place path for a cube. The robotic arm first visits the left table and starts from the pre-grasp posture and then slowly approaches the cube until the grasp posture. When the gripper has reached the grasp posture, it closes the fingers to grasp the object and then retreats to the post-grasp posture. After that the robotic arm visits the right table to execute the place steps which are similar to the pick steps. The images below show some frames from the experiment with the first three to show the pick steps in the simulation environment and then other three images show the place steps in the visualization program.




Figure 9.20: Experiment 4: Simple pick-and-place experiment of a cube

Observing the results from table 9.7, the time duration for the pick pipeline of this experiment using the RRTConnect path planning algorithm, ranges from approximately 0.01 to 0.02 seconds, whereas in the Place pipeline we observe mainly 2 distinct groups of time ranges. One group has values around 0.02 seconds and the other has bigger values around 0.14 seconds. In the case with the bigger time durations, the solution made the robot go around the obstacle whereas in the other cases the path planning solution avoided the obstacle, which means that an easier path was found, it was solved quicker and the path solution was much simpler (in terms of kinematic constraints) which led to smaller path simplification time durations. It is also possible, that due to the obstacle and the initial conditions, the robot may not find a solution at the first attempt or none at all.

| Robot<br>Planner 4 |        | RRTConnect    |                               |                      |  |
|--------------------|--------|---------------|-------------------------------|----------------------|--|
|                    |        | Pick Pipeline |                               |                      |  |
| Experiment         | Status | Solution Time | Path Simplifica-<br>tion Time | Planning<br>Attempts |  |
| 1                  | 1      | 0.026189      | 0.065173                      | 1                    |  |
| 2                  | 1      | 0.016835      | 0.043333                      | 1                    |  |
| 3                  | 1      | 0.025439      | 0.023178                      | 1                    |  |
| 4                  | 1      | 0.029292      | 0.066913                      | 1                    |  |
| 5                  | 1      | 0.024873      | 0.01747                       | 1                    |  |
| 6                  | 1      | 0.017615      | 0.024568                      | 1                    |  |
| 7                  | 1      | 0.014263      | 0.028095                      | 1                    |  |
| 8                  | 1      | 0.015479      | 0.027035                      | 1                    |  |
| 9                  | 1      | 0.027803      | 0.057064                      | 1                    |  |
| 10                 | 1      | 0.026057      | 0.033179                      | 1                    |  |
| <b>Average</b>     | 1      | 0.02196178    | 0.0386008                     | 1                    |  |
| Place Pipeline     |        |               |                               |                      |  |
| Experiment         | Status | Solution Time | Path Simplifica-<br>tion Time | Planning<br>Attempts |  |
| 1                  | 1      | 0.014644      | 0.020947                      | 1                    |  |
| 2                  | 1      | 0.131334      | 0.938948                      | 1                    |  |
| 3                  | 1      | 0.021425      | 0.08429                       | 1                    |  |
| 4                  | 1      | 0.01675       | 0.01675                       | 1                    |  |
| 5                  | 1      | 0.165795      | 1.661019                      | 1                    |  |
| 6                  | 1      | 0.119819      | 0.394493                      | 1                    |  |
| 7                  | 1      | 0.140645      | 0.476835                      | 1                    |  |
| 8                  | 1      | 0.133917      | 0.673233                      | 1                    |  |
| 9                  | 1      | 0.017644      | 0.038319                      | 1                    |  |
| 10                 | 1      | 0.020025      | 0.074847                      | 1                    |  |
| <b>Average</b>     | 1      | 0.0781998     | 0.4379681                     | 1                    |  |

Table 9.7: Time results for robot planner 4 using the RRTConnect path planner algorithm

The main observation from the results of table 9.8 is that RRT\* time durations are

much bigger than those from RRTConnect, but the RRT\* algorithm has the advantage of finding better, more accurate solutions (approximately the same solutions at most attempts) and with less collisions. Although these time durations are not optimal for real-time applications, they could be useful in pick-and-place pipelines if the solutions are pre-computed (memoized) and saved for later use.

| Robot<br>Planner 4 | <b>RRT*</b>           |               |                               |          |               |
|--------------------|-----------------------|---------------|-------------------------------|----------|---------------|
|                    | <b>Pick Pipeline</b>  |               |                               |          |               |
| Experiment         | Status                | Solution Time | Path Simplifica-<br>tion Time | Planning | At-<br>tempts |
| 1                  | 1                     | 44.97476      | 0.030918                      | 1        |               |
| 2                  | 1                     | 45.006897     | 0.073009                      | 1        |               |
| 3                  | 1                     | 44.989085     | 0.053440                      | 1        |               |
| 4                  | 1                     | 44.998414     | 0.034571                      | 1        |               |
| 5                  | 1                     | 44.982524     | 0.041732                      | 1        |               |
| 6                  | 1                     | 44.997148     | 0.017660                      | 1        |               |
| 7                  | 1                     | 45.00115      | 0.022290                      | 1        |               |
| 8                  | 1                     | 44.991409     | 0.046728                      | 1        |               |
| <b>Average</b>     | 1                     | 44.99267      | 0.0400435                     | 1        |               |
|                    | <b>Place Pipeline</b> |               |                               |          |               |
| Experiment         | Status                | Solution Time | Path Simplifica-<br>tion Time | Planning | At-<br>tempts |
| 1                  | 1                     | 45.064568     | 0.884821                      | 1        |               |
| 2                  | 1                     | 44.965931     | 0.054692                      | 1        |               |
| 3                  | 1                     | 44.976697     | 0.012784                      | 1        |               |
| 4                  | 1                     | 44.968431     | 0.020354                      | 1        |               |
| 5                  | 1                     | 45.068239     | 0.551800                      | 1        |               |
| 6                  | 1                     | 45.016043     | 1.089529                      | 1        |               |
| 7                  | 1                     | 45.048851     | 0.680121                      | 1        |               |
| 8                  | 1                     | 45.023364     | 0.000004                      | 1        |               |
| <b>Average</b>     | 1                     | 45.0165155    | 0.411763                      | 1        |               |

Table 9.8: Time results for robot planner 4 using the RRT\* path planner algorithm

| Robot<br>Planner 4 | <b>PRM*</b>          |               |                               |          |               |
|--------------------|----------------------|---------------|-------------------------------|----------|---------------|
|                    | <b>Pick Pipeline</b> |               |                               |          |               |
| Experiment         | Status               | Solution Time | Path Simplifica-<br>tion Time | Planning | At-<br>tempts |
| 1                  | 1                    | 44.987182     | 0.000028                      | 1        |               |
| 2                  | 1                    | 44.992757     | 0.000005                      | 1        |               |
| 3                  | 1                    | 45.00983      | 0.000004                      | 1        |               |
| 4                  | 1                    | 45.004154     | 0.105568                      | 1        |               |
| 5                  | 1                    | 44.99367      | 0.000002                      | 1        |               |
| 6                  | 1                    | 45.015169     | 0.000002                      | 1        |               |
| 7                  | 1                    | 45.02914      | 0.000002                      | 1        |               |
| <b>Average</b>     | 1                    | 45.00456      | 0.015088                      | 1        |               |

| Experiment     | Place Pipeline |                  |                          |                   |     |
|----------------|----------------|------------------|--------------------------|-------------------|-----|
|                | Status         | Solution Time    | Path Simplification Time | Planning Attempts | At- |
| 1              | 1              | 44.992207        | 0.000004                 | 1                 |     |
| 2              | 1              | 45.512132        | 0.000001                 | 1                 |     |
| 3              | 1              | 45.950533        | 0.000002                 | 1                 |     |
| 4              | 1              | 44.99777         | 0.000003                 | 1                 |     |
| 5              | 1              | 45.691226        | 0.000002                 | 1                 |     |
| 6              | 1              | 45.023251        | 0.013478                 | 1                 |     |
| 7              | 1              | 45.782305        | 0.000003                 | 1                 |     |
| <b>Average</b> | <b>1</b>       | <b>45.421346</b> | <b>0.0019276</b>         | <b>1</b>          |     |

Table 9.9: Time results for robot planner 4 using the PRM\* path planner algorithm

## 9.5 Robot Planner 5: Visual servoing

The goal of this fifth experiment is to control the KUKA robot using the camera via the visual servoing technique. In the first part of the experiment the robotic arm goes to an initial known position (e.g. the corner of the table) and then moves around until it detects a surgical tool. When that happens, the image-based visual servoing will send commands to the robot so that the detected tool is at the center of the video frame and with the same orientation as the video frame. At the second part of the experiment, the robot follows a similar algorithm. It starts with a known position, like the corner of the second table, then moves around until the mounting dock starts to appear inside the frame. When that happens, the image-based visual servoing will send commands to the robot so that the center of the trocar or the fulcrum reference frame is at the center and with the same orientation as the video frame. Similar results can be achieved by using position-based visual servoing, but that was not chosen at this implementation for simplicity and less operations. Position-based servoing requires more calculations because it is required to get the camera's transformation, express it with respect to the end-effector and then calculate the end-effector pose which is then used as an input to a Cartesian Controller.




Figure 9.21: Visual servo controller error diagrams. On the left image in the error graphs appear some spikes. These spikes occur from the sudden temporary detection of a nearby surgical tool. On the right image, these spikes are filtered out, and only the error graphs of the visual servoing of one tool are shown. The controller parameters are  $K_p = 0.9, K_d = 0.2$




Figure 9.22: Image based visual servoing and calculation of grasp points. The yellow points are the grasp points and the thin black circumscribed circle is the growing circle that was used to calculate them.

## 9.6 Robot Planner 6: RCM alignment error in insertion and retraction

The goal of this experiment is to measure the alignment error of the long axis of the surgical tool with the fulcrum point. This error tracks whether the robot pose satisfies the RCM constraint, in which the axis of the tool must always pass through the fulcrum point and is explained in more detail in 7.1. To simplify the experiment, constant values are assumed for both position coordinates and orientation angles and a constant arbitrary

diagonal covariance matrix.

$$\begin{bmatrix} x \\ y \\ z \\ \psi \\ \theta \\ \varphi \end{bmatrix} = \begin{bmatrix} 0.529996 \\ 0.059271 \\ 1.398114 \\ -0.271542 \\ 0 \\ 0 \end{bmatrix}, \quad \mathbf{C} = \text{diag}(0.001, \dots, 0.001) \quad (9.6.0.1)$$

where  $\mathbf{p} = [x, y, z]$  and the Euler angles  $\psi, \theta, \varphi$  are later used to calculate the quaternion  $\mathbf{q}$ .




Figure 9.23: Robot planner6: Path from home, to point above Fulcrum point and path of insertion/retraction




Figure 9.24: RCM alignment error, diagrams from 2 executions of the same experiment. The x-axis is measured in seconds (ROS time) and the y-axis is the distance error measured in meters in logarithmic scale.

## 9.7 Robot Planner 7: State machine - End-to-end running

The goal of this experiment is to run all stages of this thesis together to study the end-to-end result. Each stage is run by a different node and the sequence in which every task is executed is dictated by the status of the state machine as shown in figure 9.27.




Figure 9.25: ROS nodes and topics used for the robot-planner6 experiment. In this experiment the trajectories and RCM fulcrum errors are with respect to the 2nd fulcrum reference frame only.




Figure 9.26: Surgical tool slides from an aligned, RCM pose to a pose misaligned from the fulcrum point, no RCM motion and surgical tool is in collision, exerting pressure to the abdominal wall. The diagram on the left shows the error starting from a correct position to a problematic position. The right image shows the tool in collision with the mounting dock (abdominal wall) and there is an obvious distance from the fulcrum reference frame.




Figure 9.27: State machine status, shown in smach viewer



## Chapter 10

# Conclusions and Future Work

### 10.1 Conclusions

Minimally invasive surgery robotics is a fascinating area of robotics research that has a huge impact in improving surgical operations, but is also very demanding and complex in implementation. Due to the nature of the tasks the surgical robots must execute, that is to operate on patients, the implemented solutions must have very strict requirements in accuracy and quality assurance. The critical requirements that were studied in this thesis are discussed in more detail below.

**Positional accuracy:** The trajectories that the robot executes (especially the pivot trajectories inside the surgical site) must be executed with micrometer accuracy. This positional accuracy is required for both the end-effector as well as for the tip of the surgical tool. It is important to note, that due to the fulcrum effect a small error in the end-effector can cause a bigger error in the position of the tool tip and vice-versa. Errors in a magnitude that is bigger than the magnitude of micrometers can cause serious surgical side-effects and can also be fatal. The experiments of this thesis were conducted with the requirement of bounding the position error of the end-effector to  $\pm 5\mu m$ , but smaller values are recommended (if possible). The positional accuracy in trajectories outside of the patient body, like for example approaching the table of the surgical tools to execute a pick-and-place pipeline, is not as strict and was increased to  $0.5mm$ .

**Orientation accuracy:** Similar to the positional accuracy, orientation accuracy is also very crucial for both the end-effector and the tip of the surgical tool, and it also sometimes affects the deviation error from the fulcrum point. Orientation errors can also have negative side-effects in the surgical operation and small errors in the end-effector can cause bigger errors in the tool tip and vice-versa. The experiments of this thesis were conducted with the requirement of bounding the orientation error of the end-effector to  $\pm 5 \cdot 10^{-6}$  degrees. The orientation accuracy in trajectories outside of the patient body, is not as strict and was increased to  $\pm 5 \cdot 10^{-4}$  degrees.

**Time optimization:** Time optimal trajectories in the context of this thesis means to find the paths, avoiding collisions and respecting the constraints as well as calculating the trajectories in the shortest amount of time as possible. This is very important, so that the robot can be responsive in real-time to the surgeon's commands and to be able to quickly and safely execute a given task. In all experiments a maximum of 5 seconds

was specified for each path planning request. Although this time duration is significantly big, many experiment path planning requests were completed in less than a second (see measurements from 9.1, 9.2, 9.3.1).

**RCM constraint:** The Remote Center of Motion constraint is the one of the most important constraints in minimally invasive surgeries (see also section 2.2.3.2). To satisfy this constraint, all trajectories were designed using spherical coordinates with respect to the fulcrum reference frame. To make sure that the surgical tool satisfies this constraint a RCM error metric was used to measure the distance of the line of the long axis of the tool from the fulcrum point. This error was mostly measured for the insertion, retraction and line segment trajectories with very satisfactory results with the errors being in the magnitude of micrometers (see figure 9.7). It is important to keep this error at a minimum to avoid exerting pressure to the patient's abdominal wall.

**Interpolation accuracy:** This requirement states that the number of interpolated waypoints of a path/trajecotry should be enough such that the geometry of the path is not significantly distorted, for example a circular trajectory designed in the taskspace should have enough sample points so that the approximated polygon will be close to the desired circle. Choosing 4 sample points for example for a circular trajectory would reduce the circle to a square trajectory. In this thesis the interpolation is done at two stages, the first stage is the one already mentioned and the second is a lower level interpolation made by MoveIt path planner when executing cartesian line paths. For this second interpolation, a step distance is defined such that the actual executed path is as close to the line as possible (see figure 6.2). In the experiments, the geometric interpolation was made using 20 or 50 sample points and the second interpolation was made using a step size of 1mm. For both parameters, a higher choice is recommended for more precise movements but with an extra cost of heavier computational requirements.

**Collision avoidance:** This requirement is common in most robotic applications and it means that the path planning algorithms must take into consideration the environment obstacles and execute trajectories around them without colliding with them. In most cases this requirement was automatically satisfied from the MoveIt framework, where it was specified that each kinematics solution should be collision-aware. The second case that was not handled by MoveIt and was separately handled in the experiments was the elbow-up constraint. This constraint (see also 2.2.3.3) was purposefully imposed so that the robot arm's elbow would not collide with the mounting dock (the object with the trocars that simulates the patient) when executing pivot motions.

**Suitable path planning algorithms:** The MoveIt motion planning framework for ROS provides a wide range of path planning algorithms to choose from. The requirements for choosing a path planning algorithm were to find a collision-aware solution in the shortest time possible, respecting all constraints, without any replanning (if possible) and to provide under the same conditions the same results. In the first experiment the two algorithms that were benchmarked were the RRTConnect and the RRT\* algorithms and all other experiments were conducted using the RRTConnect algorithm, which provided satisfactory time results and is also the default path planning algorithm in MoveIt.

**Repeatability & deterministic results:** When studying robotic applications one other metric that one should study other than the accuracy, is the robot's repeatability. The

repeatability measures how “close” the measurements are with each other or in terms of statistics, what is the standard deviation of the measurements. A good repeatability is achieved when the standard deviation is as small as possible. In this thesis, all measurements were generated from running each experiment at least 10 times, in order to calculate the average and the standard deviation. Deterministic results in the measurements, in the context of this thesis, means that the measurements are not random and are predicted to be close to the average measurement and within a range of two or three standard deviations.

**Good environment layout and robot base position:** When choosing how to position the robot in the operating room and how to set up the objects’ layout it is very important to take into consideration the robot’s available workspace. The surgical tools’ positions that the robot must approach, and the surgical site, where the robot must operate at, must be fully inside the robot’s workspace and be well reachable, which means that the robot must be able to reach a desired position with ease and flexibility. In the first 2 experiments, there was used a layout that made it difficult for the robot to reach all surgical tools and trocar points, so in the rest of the experiments a different layout was used, where the robot was much closer to the tools and the surgical site and could execute the pivot trajectories with more flexibility.

**Good reachability of trajectories:** Similar to the good layout discussed above, the trajectories, especially those of the pivot motions, must be designed in such a way so that the robot can fully follow them with ease and flexibility. The “flexibility” term means, to operate at points away from singularity points, away from the workspace boundary and without “weird” poses that make the robot to “self-fold” or even worse to self-collide.

**Singularity avoidance:** This requirement is also common in all robotic applications but is even more important in surgical robotics. When in a singularity point, the robot loses one or more kinematic degrees of freedom and cannot move or moving at a singularity point would require huge effort from the joints. Both cases could result in surgical side-effects, as well as cause problems to the robot and should always be avoided. Singularity points are avoided from the MoveIt framework when calculating the paths, and are also avoided in the lower-level controllers of the robot’s real hardware. Singularity point approaching was also tracked using the robot’s Jacobian and the manipulability index (see figure 5.2).

**Jump threshold:** This is an important parameter when executing trajectories with real robot hardware and reduces the large unpredictable motions of redundant joints that could be a safety issue (in this case both for the patient and the operating staff). These undesirable motions can occur when the arm approaches singularities and needs to reorient the arm in order to continue following the trajectory. In simulation experiments this parameter was disabled to better study the path planning in all possible cases, but this is highly not recommended when operating real robot hardware. The jump threshold parameter can be more relaxed in pick and place pipelines because there the robot has more flexibility to move, but it must be more restricted when executing pivot motions.

The conclusions above were drawn given some **assumptions** that were taken into consideration to simplify, without loss of generality, some experiments. The assumptions were the following:

- The **fulcrum position and orientation** were assumed known and constant. All trajectories from the experiments were calculated using constant fulcrum reference frames, which according to the bibliography in more realistic scenarios is not the case, and the pose of a fulcrum point is usually estimated.
- The surgical tool appears fixed on the end-effector of the robot. In this thesis a higher level overview of **surgical tool grasping** was studied in order to better study the pivot trajectories separately without the being affected by grasping forces and fulcrum-tool torques.
- The simulation environment features were assumed known and constant, which means that the pose of the surgical tools and the trocar were assumed known and their values were not extracted from the **Computer Vision node** that calculated these poses using a stereoscopic camera.

The goal of this thesis was to study in an **end-to-end approach**, all the stages involved in the recognition, control and manipulation of laparoscopic tools, but **more emphasis was given to the pivot trajectories and the RCM constrained motion planning**. Since this approach is very complex and involves many different algorithms, mathematics, techniques and technologies, it was very useful that each stage was studied separately and isolated to make sure that each stage performs well on its own (unit testing), so that later all stages can be integrated and studied together (integration testing). A higher level end-to-end pipeline that can be used for integration testing is proposed in the state machine of 9.7.

## 10.2 Future Work

**Simulation and interaction with deformable bodies.** In this thesis the laparoscopic tool is inserted through holes (trocars) in a mounting dock that simulates the patient. A more realistic approach would be instead of using such a rigid mounting dock, to use a deformable phantom object to study the interaction between the laparoscopic tool, the trocar and the patient's abdominal wall. Such a simulation is not feasible using ROS Gazebo simulation environment because it does not support collisions and physics with deformable objects. A framework that could be used with the help of a suitable ROS plugin to simulate deformable objects is the SOFA Framework.

**Advanced visualization and Haptics feedback** In this thesis, no medical imaging is used relevant to laparoscopic operations. It would be greatly beneficial to study pivot motions based on medical imaging or haptic feedback from endoscopic instruments. CHAI3D is an open source, platform agnostic framework for computer haptics, visualization and interactive real-time simulation which supports haptic devices.

Other ideas for future work that could improve and further explore the outcomes of this thesis are:




Figure 10.1: Deformable tissue/organ medical simulation - Simulation of breast probing using the SOFA Framework. Screenshots from running the repository at <https://gitlab.com/altairLab/probe-tissue-simulation>




Figure 10.2: Heart endoscopy medical simulation using the CHAI3D framework. Screenshots from running the repository at <https://github.com/chai3d/chai3d>

- Using the trajectories from chapter 6 as building blocks for more complicated trajectories like suturing or cauterization
- Design pivot trajectories without assuming that the Fulcrum point is known and constant and use estimation methods (like a Kalman filter) to estimate its pose
- Multiple robot arm collaboration: designing pivot trajectories for 2 or more robot arms that collaborate for a common surgical task, for example one robot controls an endoscopic camera and the other robot(s) control the surgical tools
- Applications of Machine Learning in Computer Vision: detection of laparoscopic tools



# Appendices



## .1 Software and Documentation

- All software that developed for this thesis is available and will be maintained at [https://github.com/karadalex/surgery\\_robots\\_kuka\\_barrett](https://github.com/karadalex/surgery_robots_kuka_barrett)
- Instruction on how to run the software of this thesis, as well as documentation of the various software components is available and will be maintained at [https://karadalex.github.io/surgery\\_robots\\_kuka\\_barrett/](https://karadalex.github.io/surgery_robots_kuka_barrett/)




Figure 3: Documentation written with Sphinx and rosdoc\_lite

## .2 Mathematics

### .2.1 Euler angles to Quaternions

Let  $\theta, \phi, \psi$  be the Euler angles (roll, pitch, yaw) respectively, then using the following equations

$$c\theta = \cos\left(\frac{\theta}{2}\right), s\theta = \sin\left(\frac{\theta}{2}\right)$$

$$c\varphi = \cos\left(\frac{\varphi}{2}\right), s\varphi = \sin\left(\frac{\varphi}{2}\right)$$

$$c\psi = \cos\left(\frac{\psi}{2}\right), s\psi = \sin\left(\frac{\psi}{2}\right)$$

we can calculate the associated quaternion, in vector notation, as follows

$$\mathbf{q} = \begin{bmatrix} q_x \\ q_y \\ q_z \\ q_w \end{bmatrix} = \begin{bmatrix} s\theta c\varphi c\psi - c\theta s\varphi s\psi \\ c\theta s\varphi c\psi + s\theta c\varphi s\psi \\ c\theta c\varphi s\psi - s\theta s\varphi c\psi \\ c\theta c\varphi c\psi + s\theta s\varphi s\psi \end{bmatrix}$$

## .2.2 Cartesian to spherical coordinates

$$r = \sqrt{x^2 + y^2 + z^2}$$

$$\theta = atan2(\sqrt{x^2 + y^2}, z)$$

$$\varphi = atan2(y, x)$$

## .2.3 Spherical to cartesian coordinates

$$x = r \sin(\theta) \cos(\varphi)$$

$$y = r \sin(\theta) \sin(\varphi)$$

$$z = r \cos(\theta)$$

# Nomenclature

|  |   |
|--|---|
| $\ddot{q}_i$   | Angle jerk of joint $i$   |
| $\ddot{q}_i$   | Angle acceleration of joint $i$   |
| $\dot{q}_i$  | Angle velocity of joint $i$   |
| $\hat{\mathbf{r}}, \hat{\boldsymbol{\theta}}, \hat{\boldsymbol{\phi}}$ | Unit vectors of $r, \theta, \varphi$ axes respectively, in spherical coordinates  |
| $\hat{\mathbf{x}}, \hat{\mathbf{y}}, \hat{\mathbf{z}}$                 | Unit vectors of $x, y, z$ axes respectively   |
| $\mathbb{H}$   | Quaternions group. A four-dimensional space with basis $\mathbf{1}, \mathbf{i}, \mathbf{j}, \mathbf{k}$ that includes all quaternions. In the context of this thesis quaternions are used for 3D rotations instead of matrices from $SO(3)$ |
| $\mathbb{J}$   | Joint taskspace   |
| $\mathbb{P}$   | Pivot paths 3D taskspace, $\mathbb{P} \subset \mathbb{T}$   |
| $\mathbb{R}^n$   | Vector space of n-dimensional real-valued vectors   |
| $\mathbb{R}^{n \times m}$  | Vector space of all real-valued $n \times m$ matrices   |
| $\mathbb{S}$   | Surgical 3D taskspace   |
| $\mathbb{T}$   | Robot's Euclidean 3D taskspace  |
| $\mathbf{C}$   | Covariance matrix   |
| $\mathbf{q}$   | Angle positions vector of all joints  |
| $\mathcal{C}$  | Configuration Space   |
| $\mathcal{C}_{free}$   | Free Configuration Space  |
| $\mathcal{C}_{obs}$  | Obstacle Space  |
| $\mathcal{L}_q$  | Dexterity measure of the robotic arm  |
| $\mathcal{M}$  | Manipulability measure of the robotic arm   |
| $\theta, \phi, \psi$   | roll, pitch, yaw angles, also known as the Euler angles   |
| $\tilde{O}_{Fi}$   | Estimated origin point of fulcrum reference frame $\{i\}$   |
| ${}^{i-1}\mathbf{p}_{iO}$  | Position vector from the origin of the coordinate frame $\{i\}$ to the origin of the coordinate frame $\{i - 1\}$   |

${}^{i-1}R_i$  Rotation matrix from coordinate frame  $\{i\}$  to coordinate frame  $\{i - 1\}$

${}^{i-1}T_i$  Transformation matrix from coordinate frame  $\{i\}$  to coordinate frame  $\{i - 1\}$

$c_i$  Shorthand notation for  $\cos\theta_i$

$J^\dagger$  Pseudoinverse of the Jacobian

$O_F, O_{Fi}$  A generic origin point of fulcrum reference frame and origin point of fulcrum reference frame  $\{i\}$  and estimated origin point of fulcrum reference frame  $\{i\}$  respectively

$q_i$  Angle position of joint  $i$

$s_i$  Shorthand notation for  $\sin\theta_i$

$SE(3)$  Special Euclidean Group. Vector space of all 3D transformations

$SO(3)$  Special Orthogonal Group. Vector space of all 3D rotations

$\tau$  Time constant, represents a specific time duration in a trajectory velocity profile or in a system controller

RCM Remote Center of Motion

TCP Tool's Center Point

# List of Figures

|     |  |    |
|-----|--|----|
| 1.1 | The PUMA 560 robotic arm, which was the first to be used in surgery robotics in 1985 . . . . .   | 20 |
| 1.2 | DaVinci Xi, ©2020 Intuitive Surgical, Inc. Patient Cart with the robotic arms that control the surgical tools . . . . .  | 21 |
| 1.3 | The Monarch™ Platform endoscopic system . . . . .  | 21 |
| 1.4 | DaVinci Xi ©2020 Intuitive Surgical, Inc. Surgeon Console . . . . .  | 22 |
| 1.5 | Motion planning pipeline . . . . .   | 24 |
| 1.6 | Kanban view of backlog tasks to organize all features, requirements and tasks needed to complete this thesis. The tool used to keep track of all tasks is Airtable . . . . .                       | 25 |
| 1.7 | Quick Prototyping using the VREP (CoppeliaSim) simulation environment  | 26 |
| 2.1 | Joint reference frames of the KUKA iiwa14 robot . . . . .  | 28 |
| 2.2 | Approximation of the KUKA iiwa14 workspace, calculated with Forward Kinematics by randomly sampling the value ranges of the joints. . . . .  | 30 |
| 2.3 | Reference frames of last link $\{7\}$ , end-effector $\{TCP\}$ , surgical tool base (center of mass) $\{B\}$ and tool-tip frame $\{T\}$ . . . . .  | 30 |
| 2.4 | Calculation of angles $\theta_2, \theta_4$ . . . . .   | 32 |
| 2.5 | The first 4 out of 8 solutions of the Inverse Kinematics problem, using the decoupling technique . . . . .   | 33 |
| 2.6 | KUKA iiwa LBR14 workspace dimensions . . . . .   | 34 |
| 2.7 | Illustration of pivoting motion of surgical laparoscopic tool around RCM point (also known as fulcrum or trocar point). Due to the RCM constraint, the tool has only 4 degrees of freedom. . . . . | 36 |
| 2.8 | Top: elbow-down solution, bottom: elbow-up solution . . . . .  | 38 |
| 2.9 | Elbow-up constraint description with relative distance or angle between links with lengths $d_1$ and $d_3$ . . . . .   | 39 |
| 3.1 | Barrett Hand gripper (model BH8-282) dimensions . . . . .  | 41 |
| 3.2 | Coordinates systems for forward kinematics for a generalized finger of the gripper . . . . .   | 42 |
| 3.3 | Top view of one of the 3 fingers of the gripper with 3 joints (RRR kinematic chain) . . . . .  | 42 |
| 3.4 | Side view of one of the 3 fingers of the gripper with 3 joints (RRR kinematic chain) . . . . .   | 43 |
| 4.1 | Simple tool detection in simulation based on color, using OpenCV. The green polygon is the convex hull, and the red point is the estimated center of mass . . . . .                                | 48 |

|      |  |    |
|------|--|----|
| 4.2  | Disparity image calculated from the 2 cameras . . . . .  | 49 |
| 4.3  | Point cloud of surgical tools, generated from the 2 cameras and visualized in RViz . . . . .   | 49 |
| 4.4  | Estimation of tool's pose (position and orientation). The red dot is the center of mass and attached to that are the two orientation vectors of the tool. The green polygon is the convex hull of the tool and the white rectangle is it's ROI as calculated from the convex hull . . . . .  | 51 |
| 4.5  | Finding candidate grasping points from the intersections of a growing circle and the contour of the detected surgical tool . . . . .   | 51 |
| 4.6  | Simple trocar detection in simulation based on color, using OpenCV. In simulation, the trocar is simply considered to be a small cylindrical hole and it's center is the fulcrum point . . . . .   | 52 |
| 5.1  | The spaces studied in this thesis and how they are connected with each other via transformations . . . . .   | 56 |
| 5.2  | Plot of the manipulability of the robot arm at sample points of the executed trajectory . . . . .  | 57 |
| 5.3  | Task space inside patients body. Colors with 0 or low value correspond to points with low dexterity. This is the trivial case, where no collision objects are taken into consideration . . . . .   | 58 |
| 6.1  | Tool pose at target point $B$ calculated with respect to Fulcrum's reference frame $\{F\}$ . . . . .   | 62 |
| 6.2  | Path/trajectory interpolation done at two stages. (a) the initial desired circular trajectory, (b) sample waypoints that will approximate the circle and shape a polygon, (c) the line segments connecting the waypoints and which the robot must theoretically follow exactly, (d) lower-level interpolation of the line segments (made by MoveIt in ROS or by the robot's controller when executing PtP), (e) the actual trajectory that the robot will follow . . . . . | 64 |
| 6.3  | Circular trajectory of tool tip with respect to Fulcrum reference frame . .  | 65 |
| 6.4  | Circular trajectory of tool tip with respect to Fulcrum reference frame and it's transformation via the Fulcrum Effect . . . . .   | 66 |
| 6.5  | Circular trajectory that lies on an a plane of arbitrary orientation with respect to the fulcrum point . . . . .   | 67 |
| 6.6  | Circular arc trajectory of tool tip with respect to Fulcrum reference frame and it's transformation via the Fulcrum Effect. In this trajectory 2 circular arcs are used . . . . .  | 68 |
| 6.7  | Helical trajectory of tool tip with respect to Fulcrum reference frame and it's transformation via the Fulcrum Effect . . . . .  | 69 |
| 6.8  | Line segment trajectory of tool tip with respect to Fulcrum reference frame . . . . .  | 69 |
| 6.9  | A Line segment trajectory and it's transformation via the Fulcrum Effect . . . . .   | 70 |
| 6.10 | Cubic Spline curve with 10 waypoints . . . . .   | 71 |
| 6.11 | A Cubic Spline trajectory and it's transformation via the Fulcrum Effect . . . . .   | 71 |
| 6.12 | Cubic Bézier curve calculated using cubic interpolation of 4 control points . . . . .  | 72 |
| 6.13 | A cubic Bézier curve calculated and plotted in MATLAB . . . . .  | 73 |
| 6.14 | B-Spline curve constructed from 3 Bézier curves. The first Bézier curve colored in red is a quadratic one and the following two are both cubic. . . . .  | 73 |
| 6.15 | A Bézier curve trajectory and it's transformation via the Fulcrum Effect . . . . .   | 75 |

|      |  |     |
|------|--|-----|
| 6.16 | Joint trajectory generated using velocity profiles. Calculated and plotted in MATLAB . . . . .   | 81  |
| 6.17 | Trapezoid vs s-curve velocity profiles applied to the cart-inverted-pendulum system. . . . .   | 81  |
| 7.1  | Geometric calculation of the RCM alignment error $e$ using the distance between the line $l$ and the RCM (aka Fulcrum) point. . . . .  | 84  |
| 7.2  | Force interaction model of the laparoscopic tool and the abdominal wall around the fulcrum point (RCM point) . . . . .   | 85  |
| 7.3  | RCM error calculation in $yz$ plane. The RCM error or $yz$ -error is the distance between the line of the $\hat{\mathbf{x}}$ vector (here seen as a point) and the estimated position of the origin of the fulcrum reference frame $\tilde{O}_F$ . . . . .   | 85  |
| 7.4  | RCM tracking proposed control system. The RCM error is used as input in the trajectory generator to correct the trajectory command in order to fix the RCM misalignment . . . . .  | 86  |
| 7.5  | Position based visual servoing closed loop control . . . . .   | 87  |
| 7.6  | Position based visual servoing using depth from motion, stereo vision or 3D sensors, from which the desired position $\mathbf{x}_d$ is calculated and used to drive the robot. . . . .   | 88  |
| 7.7  | Image based visual servoing. The robot arm is controlled using the information gained from the video frames. The frames are 2Dimensional and thus the detected objects can have only 3 degrees of freedom which means we can mainly control 3 independent variables, here the $x, y, \theta$ variables. The left image is the initial frame and the right image is the frame where the object is at the target pose. . . . . | 88  |
| 7.8  | Image based visual servoing closed loop control . . . . .  | 89  |
| 7.9  | Force control on a Barrett Hand gripper finger . . . . .   | 89  |
| 8.1  | Communication diagram of 2 ROS nodes with a topic and a service . . . . .  | 92  |
| 8.2  | Simulation environment in Gazebo . . . . .   | 93  |
| 8.3  | Control & Hardware Interfaces in Gazebo and ROS . . . . .  | 94  |
| 8.4  | RViz: Visualizing the robot state as well as the state of the perceived world In this screenshot, various poses of the robot are shown: 1) the current actual real pose of the robot, 2) the planned pose and 3) the goal pose, which can freely be moved within the RViz environment . . . . .  | 94  |
| 8.5  | MoveIt ROS Architecture . . . . .  | 95  |
| 9.1  | Experiment 1 . . . . .   | 99  |
| 9.2  | Experiment 2a: . . . . .   | 107 |
| 9.3  | Experiment 2b: Running robot planner 2b with a different table layout so that all target poses have improved reachability. Note that all trajectories shown in the screenshots are collision-free, because the robotic arm is in an elbow-up configuration, so that it avoids the collision between the 3rd link of the robot and the mounting dock (green object shown in simulation). . . . .                              | 107 |
| 9.4  | Experiment 2b: Singularity failure . . . . .   | 108 |
| 9.5  | Custom kinematic state node that subscribes to the joint values and publishes forward kinematics solutions and the jacobian matrix values. . . . .   | 108 |

|      |   |     |
|------|---|-----|
| 9.6  | Experiment 3b: Create the line segment trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP. (a) Preparatory path to achieve elbow-up pose, (b) transformed line segment trajectory for the end-effector to follow, (c) transformed line segment trajectory with respect to the tool base frame (there is an offset from the end-effector see 2.1.1), (d) fulcrum reference frame 2 $\{F_2\}$ , (e) line segment trajectory in surgical taskspace, (f) line of the axis along the length of the surgical tool, which is used to calculate the distance error (RCM deviation) . . . . . | 109 |
| 9.7  | Experiment 3b: RCM error diagram from home position to line and reverse-line segment trajectories. . . . .  | 109 |
| 9.8  | Experiment 3b: RCM error distributions, measurements from 10 iterations of the same experiment. From left to right: distribution of all measurements, distribution of measurements while the robot was pivoting, distribution of measurements while the robot was inserted but still. . . . .   | 110 |
| 9.9  | Experiment 3b: Manipulability plots of the whole trajectory the robot executed during 2 iterations of the same experiment . . . . .   | 110 |
| 9.10 | Experiment 3b: Line segment trajectory that is invariant under the fulcrum transformation, in terms of shape (the line remains a line). . . . .   | 111 |
| 9.11 | Experiment 3a: Create circular trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP. . . . .   | 113 |
| 9.12 | Experiment 3a: A more detailed view of the circular trajectories. (a) the original circular trajectory designed inside the surgical taskspace, (b) the transformed trajectory that the base of the surgical tool will follow, (c) the actual transformed trajectory that the robot's end-effector will follow .   | 114 |
| 9.13 | Experiment 3c: Create the cubic spline trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP. . . . .   | 114 |
| 9.14 | Experiment 3d: Create the B-spline trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP. . . . .   | 115 |
| 9.15 | Experiment 3e: Polynomial trajectories of 5th degree for each of the 7 joints. The trajectory is computed at 60 sampling points. . . . .  | 117 |
| 9.16 | Experiment 3f: Trajectory using a trapezoid velocity profile. The time constant (also known as blend time) is $\tau = 15$ seconds and the total trajectory duration is 60 seconds. The trajectory is computed at 60 sampling points. . . . .  | 118 |
| 9.17 | Experiment 3f: Trajectory using a trapezoid velocity profile. The time constant (also known as blend time) is $\tau = 30$ seconds and the total trajectory duration is 60 seconds. Note that the blend time is chosen as half of the total duration which has as a result the linear segment (constant velocity) to disappear and create a "bang-bang" trajectory. In control theory, a "bang-bang" controller, is a controller that switches abruptly between two states. The trajectory is computed at 60 sampling points. . .  | 119 |
| 9.18 | Experiment 3g: Trajectory using a s-curve velocity profile. The time constants are $\tau_1 = \tau_2 = 6$ seconds and the total trajectory duration is 60 seconds. The trajectory is computed at 60 sampling points. . . . .   | 120 |

|      |  |     |
|------|--|-----|
| 9.19 | Experiment 3h: Create helical trajectory inside the surgical site (below the green mounting dock) and transform it via the fulcrum transformation to a trajectory for the robot's TCP. . . . .   | 121 |
| 9.20 | Experiment 4: Simple pick-and-place experiment of a cube . . . . .   | 121 |
| 9.21 | Visual servo controller error diagrams. On the left image in the error graphs appear some spikes. These spikes occur from the sudden temporary detection of a nearby surgical tool. On the right image, these spikes are filtered out, and only the error graphs of the visual servoing of one tool are shown. The controller parameters are $K_p = 0.9, K_d = 0.2$ . . . . .  | 125 |
| 9.22 | Image based visual servoing and calculation of grasp points. The yellow points are the grasp points and the thin black circumscribed circle is the growing circle that was used to calculate them. . . . .   | 125 |
| 9.23 | Robot planner6: Path from home, to point above Fulcrum point and path of insertion/retraction . . . . .  | 126 |
| 9.24 | RCM alignment error, diagrams from 2 executions of the same experiment. The x-axis is measured in seconds (ROS time) and the y-axis is the distance error measured in meters in logarithmic scale. . . . .   | 127 |
| 9.25 | ROS nodes and topics used for the robot-planner6 experiment. In this experiment the trajectories and RCM fulcrum errors are with respect to the 2nd fulcrum reference frame only. . . . .  | 128 |
| 9.26 | Surgical tool slides from an aligned, RCM pose to a pose misaligned from the fulcrum point, no RCM motion and surgical tool is in collision, exerting pressure to the abdominal wall. The diagram on the left shows the error starting from a correct position to a problematic position. The right image shows the tool in collision with the mounting dock (abdominal wall) and there is an obvious distance from the fulcrum reference frame. . . . . | 128 |
| 9.27 | State machine status, shown in smach viewer . . . . .  | 129 |
| 10.1 | Deformable tissue/organ medical simulation - Simulation of breast probing using the SOFA Framework. Screenshots from running the repository at <a href="https://gitlab.com/altairLab/probe-tissue-simulation">https://gitlab.com/altairLab/probe-tissue-simulation</a> . . . . .   | 135 |
| 10.2 | Heart endoscopy medical simulation using the CHAI3D framework. Screenshots from running the repository at <a href="https://github.com/chai3d/chai3d">https://github.com/chai3d/chai3d</a> . . . . .  | 135 |
| 3    | Documentation written with Sphinx and rosdoc _ lite . . . . .  | 139 |



# List of Listings

|     |  |    |
|-----|--|----|
| 3.1 | Example ROS message with collision/contact information between one finger of the gripper and one surgical tool . . . . .   | 44 |
| 3.2 | Example values from the Barrett Hand tactile array. Units N/cm <sup>2</sup> message type: bhand_controller/TactArray <a href="https://github.com/RobotnikAutomation/barrett_hand/tree/kinetic-devel/bhand_controller">https://github.com/RobotnikAutomation/barrett_hand/tree/kinetic-devel/bhand_controller</a> . . . . . | 45 |
| 1   | RCM Taskspace calculation using MATLAB . . . . .   | 58 |
| 2   | Fulcrum Effect transformation of a trajectory, in MATLAB . . . . .   | 63 |



# List of Algorithms

|   |  |    |
|---|--|----|
| 1 | Newton-Raphson numerical method . . . . .                | 33 |
| 2 | RRT Algorithm . . . . .                                  | 54 |
| 3 | PRM roadmap construction (preprocessing phase) . . . . . | 55 |
| 4 | Pick and Place algorithm . . . . .                       | 55 |



# List of Tables

|     |  |     |
|-----|--|-----|
| 9.1 | Time results for robot planner 1 using the RRTConnect path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.000005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position. . . . .   | 101 |
| 9.2 | Time results for robot planner 1 using the RRT* path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.000005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position. . . . .   | 102 |
| 9.3 | Time results for robot planner 2a using the RRTConnect path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.0005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position. . . . .  | 104 |
| 9.4 | Time results for robot planner 2b using the RRTConnect path planner algorithm and a different table layout from robot planner 2a. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.0005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position. . . . . | 106 |
| 9.5 | Accuracy and repeatability of the line segment experiment, calculated using measurements from 10 iterations of the same experiment . . . . .   | 110 |
| 9.6 | Time results for robot planner 1 using the RRTConnect path planner algorithm. Planning time is the sum of solution time and path simplification time. Execution status is 1 for success and 0 for failure. Parameters: tolerances: 0.000005, max planning time: 5 seconds, replanning: true, max planning attempts: 6. Experiments start from home position. . . . .   | 112 |
| 9.7 | Time results for robot planner 4 using the RRTConnect path planner algorithm . . . . .   | 122 |
| 9.8 | Time results for robot planner 4 using the RRT* path planner algorithm .   | 123 |
| 9.9 | Time results for robot planner 4 using the PRM* path planner algorithm   | 124 |



# Bibliography

- [1] Nastaran Aghakhani et al. "Task control with remote center of motion constraint for minimally invasive robotic surgery". In: *2013 IEEE International Conference on Robotics and Automation* (2013), pp. 5807–5812.
- [2] Jorge Angeles. *Fundamentals of Robotic Mechanical Systems*. Springer International Publishing, 2014. DOI: 10.1007/978-3-319-01851-5. URL: <https://doi.org/10.1007/978-3-319-01851-5>.
- [3] Tadej Bajd et al. *Robotics*. Springer Netherlands, 2010. DOI: 10.1007/978-90-481-3776-3. URL: <https://doi.org/10.1007/978-90-481-3776-3>.
- [4] E. Bauzano et al. "Active wrists endoscope navigation in robotized laparoscopic surgery". In: *2009 IEEE International Conference on Mechatronics*. Apr. 2009, pp. 1–6. DOI: 10.1109/ICMECH.2009.4957177.
- [5] Enrique Bauzano et al. "Control Methodologies for Endoscope Navigation in Robotized Laparoscopic Surgery". In: *Eurobot Conference*. 2009.
- [6] Mark de Berg et al. *Computational Geometry*. Springer Berlin Heidelberg, 2008. DOI: 10.1007/978-3-540-77974-2. URL: <https://doi.org/10.1007/978-3-540-77974-2>.
- [7] E. Boctor et al. "Virtual Remote Center of Motion Control for Needle Placement Robots". In: *Computer aided surgery : official journal of the International Society for Computer Aided Surgery* 9 5 (2003), pp. 175–83.
- [8] M. C. Capolei et al. "Positioning the laparoscopic camera with industrial robot arm". In: *2017 3rd International Conference on Control, Automation and Robotics (ICCAR)*. Apr. 2017, pp. 138–143. DOI: 10.1109/ICCAR.2017.7942675.
- [9] François Chaumette and Seth Hutchinson. "Visual Servoing and Visual Tracking". In: *Springer Handbook of Robotics*. Ed. by Bruno Siciliano and Oussama Khatib. Berlin, Heidelberg: Springer Berlin Heidelberg, 2008, pp. 563–583. ISBN: 978-3-540-30301-5. DOI: 10.1007/978-3-540-30301-5\_25. URL: [https://doi.org/10.1007/978-3-540-30301-5\\_25](https://doi.org/10.1007/978-3-540-30301-5_25).
- [10] Sachin Chitta et al. "ros\_control: A generic and simple control framework for ROS". In: *The Journal of Open Source Software* (2017). DOI: 10.21105/joss.00456. URL: <http://www.theoj.org/joss-papers/joss.00456/10.21105.joss.00456.pdf>.
- [11] Peter Corke. *Robotics, Vision and Control*. Springer International Publishing, 2017. DOI: 10.1007/978-3-319-54413-7. URL: <https://doi.org/10.1007/978-3-319-54413-7>.
- [12] G. Cowley. "Introducing "Robodoc". A robot finds his calling—in the operating room". In: *Newsweek* 120.21 (Nov. 1992), p. 86.

- [13] Bassem Dahroug, B. Tamadazte, and N. Andreff. “3D Path Following with Remote Center of Motion Constraints”. In: *ICINCO*. 2016.
- [14] Bassem Dahroug, B. Tamadazte, and N. Andreff. “Task Controller for Performing Remote Centre of Motion”. In: *ICINCO*. 2016.
- [15] Bassem Dahroug, B. Tamadazte, and N. Andreff. “Visual servoing controller for time-invariant 3D path following with remote centre of motion constraint”. In: *2017 IEEE International Conference on Robotics and Automation (ICRA)* (2017), pp. 3612–3618.
- [16] Bassem Dahroug, Brahim Tamadazte, and Nicolas Andreff. “Unilaterally Constrained Motion of a Curved Surgical Tool”. In: *Robotica* (2020), pp. 1–23. DOI: 10.1017/S0263574719001735.
- [17] M. M. Dalvand and B. Shirinzadeh. “Remote centre-of-motion control algorithms of 6-RRCRR parallel robot assisted surgery system (PRAMiSS)”. In: *2012 IEEE International Conference on Robotics and Automation* (2012), pp. 3401–3406.
- [18] Lin Dong and Guillaume Morel. “Robust trocar detection and localization during robot-assisted endoscopic surgery”. In: *2016 IEEE International Conference on Robotics and Automation (ICRA)* (2016), pp. 4109–4114.
- [19] Carlos Faria et al. “Position-based kinematics for 7-DoF serial manipulators with global configuration control, joint limit and singularity avoidance”. In: *Mechanism and Machine Theory* 121 (2018), pp. 317–334. ISSN: 0094-114X. DOI: <https://doi.org/10.1016/j.mechmachtheory.2017.10.025>. URL: <http://www.sciencedirect.com/science/article/pii/S0094114X17306559>.
- [20] Tully Foote. “tf: The transform library”. In: *Technologies for Practical Robot Applications (TePRA), 2013 IEEE International Conference on*. Open-Source Software workshop. Apr. 2013, pp. 1–6. DOI: 10.1109/TePRA.2013.6556373.
- [21] K. Fujii et al. “Gaze contingent cartesian control of a robotic arm for laparoscopic surgery”. In: *2013 IEEE/RSJ International Conference on Intelligent Robots and Systems*. Nov. 2013, pp. 3582–3589. DOI: 10.1109/IROS.2013.6696867.
- [22] M. Fujii et al. “Relationship between workspace reduction due to collisions and distance between endoscope and target organ in pediatric endoscopic surgery”. In: *5th IEEE RAS/EMBS International Conference on Biomedical Robotics and Biomechatronics*. Aug. 2014, pp. 46–51. DOI: 10.1109/BIOROB.2014.6913750.
- [23] J. Funda et al. “Constrained Cartesian motion control for teleoperated surgical robots”. In: *IEEE Trans. Robotics Autom.* 12 (1996), pp. 453–465.
- [24] J. Funda et al. “Control and evaluation of a 7-axis surgical robot for laparoscopy”. In: *Proceedings of 1995 IEEE International Conference on Robotics and Automation*. Vol. 2. 1995, 1477–1484 vol.2.
- [25] Alessandro Gasparetto et al. “Path Planning and Trajectory Planning Algorithms: A General Overview”. In: *Motion and Operation Planning of Robotic Systems: Background and Practical Approaches*. Ed. by Giuseppe Carbone and Fernando Gomez-Bravo. Cham: Springer International Publishing, 2015, pp. 3–27. ISBN: 978-3-319-14705-5. DOI: 10.1007/978-3-319-14705-5\_1. URL: [https://doi.org/10.1007/978-3-319-14705-5\\_1](https://doi.org/10.1007/978-3-319-14705-5_1).

- [26] G. Gras et al. “Implicit gaze-assisted adaptive motion scaling for highly articulated instrument manipulation”. In: *2017 IEEE International Conference on Robotics and Automation (ICRA)*. May 2017, pp. 4233–4239. DOI: 10.1109/ICRA.2017.7989488.
- [27] Techbriefs Media Group. *Surgical Robotics: The Evolution of a Medical Technology - Medical Design Briefs*. URL: <https://www.medicaldesignbriefs.com/component/content/article/mdb/features/technology-leaders/25006> (visited on 09/18/2020).
- [28] Caspar Gruijthuijsen et al. “Leveraging the Fulcrum Point in Robotic Minimally Invasive Surgery”. In: *IEEE Robotics and Automation Letters* 3 (2018), pp. 2071–2078.
- [29] G. B. Hanna, S. Shimi, and A. Cuschieri. “Optimal port locations for endoscopic intracorporeal knotting”. In: *Surgical Endoscop* 11.4 (Apr. 1997), pp. 397–401. ISSN: 1432-2218. DOI: 10.1007/s004649900374. URL: <https://doi.org/10.1007/s004649900374>.
- [30] B. Hannaford et al. “Raven-II: An Open Platform for Surgical Robotics Research”. In: *IEEE Transactions on Biomedical Engineering* 60.4 (Apr. 2013), pp. 954–959. ISSN: 1558-2531. DOI: 10.1109/TBME.2012.2228858.
- [31] M. R. Hasan et al. “Modelling and Control of the Barrett Hand for Grasping”. In: *2013 UKSim 15th International Conference on Computer Modelling and Simulation*. Apr. 2013, pp. 230–235. DOI: 10.1109/UKSim.2013.142.
- [32] Felix C. Huang et al. “Learning kinematic mappings in laparoscopic surgery”. In: *Conference proceedings : ... Annual International Conference of the IEEE Engineering in Medicine and Biology Society. IEEE Engineering in Medicine and Biology Society. Annual Conference 2010* (2010). PMC3280950[pmcid], pp. 2097–2102. ISSN: 1557-170X. DOI: 10.1109/IEMBS.2010.5626188. URL: <https://pubmed.ncbi.nlm.nih.gov/21095685>.
- [33] J. Hutzl and H. Wörn. “Spatial probability distribution for port planning in minimal invasive robotic surgery (MIRS)”. In: *2015 6th International Conference on Automation, Robotics and Applications (ICARA)*. Feb. 2015, pp. 204–210. DOI: 10.1109/ICARA.2015.7081148.
- [34] Corke P. I. *Visual Control of Robots, high-performance visual servoing*. John Wiley& Sons Inc., 1996.
- [35] Craig J. Εισαγωγή στη ρομποτική, Μηχανική και Αυτόματος Ελεγχός. Τζιόλα, 2009. ISBN: 978-960-418-160-5.
- [36] Reza N. Jazar. *Theory of Applied Robotics, Kinematics, Dynamics, and Control (2nd Edition)*. Springer, Boston, MA, 2010. ISBN: 978-1-4419-1750-8. DOI: 10.1007/978-1-4419-1750-8.
- [37] S. Karaman and Emilio Frazzoli. “Sampling-based algorithms for optimal motion planning”. In: *The International Journal of Robotics Research* 30 (2011), pp. 846–894.
- [38] Abbas Karami et al. “Force, orientation and position control in redundant manipulators in prioritized scheme with null space compliance”. In: *Control Engineering Practice* 85 (2019), pp. 23–33.
- [39] Parham Kebria et al. “Kinematic and dynamic modelling of UR5 manipulator”. In: Oct. 2016, pp. 004229–004234. DOI: 10.1109/SMC.2016.7844896.

- [40] Zachary K. Kingston, Mark Moll, and Lydia E. Kavraki. “Sampling-Based Methods for Motion Planning with Constraints”. In: *Annual Review of Control, Robotics, and Autonomous Systems* (2018).
- [41] J. J. Kuffner and S. M. LaValle. “RRT-connect: An efficient approach to single-query path planning”. In: *Proceedings 2000 ICRA. Millennium Conference. IEEE International Conference on Robotics and Automation. Symposia Proceedings (Cat. No.00CH37065)*. Vol. 2. Apr. 2000, 995–1001 vol.2. doi: 10.1109/ROBOT.2000.844730.
- [42] I. Kuhlemann et al. “Robust inverse kinematics by configuration control for redundant manipulators with seven DoF”. In: *2016 2nd International Conference on Control, Automation and Robotics (ICCAR)*. Apr. 2016, pp. 49–55. doi: 10.1109/ICCAR.2016.7486697.
- [43] Chin-Hsing Kuo and Jian Dai. “Robotics for Minimally Invasive Surgery: A Historical Review from the Perspective of Kinematics”. In: Jan. 2009, pp. 337–354. ISBN: 978-1-4020-9484-2. doi: 10.1007/978-1-4020-9485-9\_24.
- [44] P. Lago, Carlo Lombardi, and I. Vallone. “From laparoscopic surgery to 3-D double console robot-assisted surgery”. In: *Proceedings of the 10th IEEE International Conference on Information Technology and Applications in Biomedicine* (2010), pp. 1–4.
- [45] A. Llamosi and S. Toussaint. “Measuring Force Intensity and Direction with a Spatially Resolved Soft Sensor for Biomechanics and Robotic Haptic Capability”. In: *Soft Robot* 6.3 (June 2019), pp. 346–355.
- [46] Sally K. Longmore, Ganesh R. Naik, and Gaetano Dario Gargiulo. “Laparoscopic Robotic Surgery: Current Perspective and Future Directions”. In: *Robotics* 9 (2020), p. 42.
- [47] Kevin M Lynch and Frank C. Park. *Modern Robotics: Mechanics, Planning, and Control*. English (US). Cambridge Univeristy Press, 2017. ISBN: 978-1107156302.
- [48] M. Marinho et al. “A Unified Framework for the Teleoperation of Surgical Robots in Constrained Workspaces”. In: *2019 International Conference on Robotics and Automation (ICRA)* (2019), pp. 2721–2727.
- [49] Murilo M. Marinho, Mariana C. Bernardes, and Antônio Padilha Lanari Bo. “A programmable remote center-of-motion controller for minimally invasive surgery using the dual quaternion framework”. In: *5th IEEE RAS/EMBS International Conference on Biomedical Robotics and Biomechatronics* (2014), pp. 339–344.
- [50] Q. Mei et al. “PROBOT — A computer integrated prostatectomy system”. In: *Visualization in Biomedical Computing*. Ed. by Karl Heinz Höhne and Ron Kikinis. Berlin, Heidelberg: Springer Berlin Heidelberg, 1996, pp. 581–590. ISBN: 978-3-540-70739-4.
- [51] Victor F. Muñoz et al. “Pivoting motion control for a laparoscopic assistant robot and human clinical trials”. In: *Advanced Robotics* 19 (2005), pp. 694–712.
- [52] A. A. Navarro et al. “Automatic positioning of surgical instruments in minimally invasive robotic surgery through vision-based motion analysis”. In: *2007 IEEE/RSJ International Conference on Intelligent Robots and Systems*. Oct. 2007, pp. 202–207. doi: 10.1109/IROS.2007.4399150.

- [53] Kim-Doang Nguyen, Teck Ng, and I-Ming Chen. “On Algorithms for Planning S-Curve Motion Profiles”. In: *International Journal of Advanced Robotic Systems* 5 (Mar. 2008). DOI: 10.5772/5652.
- [54] Jason M. O’Kane. *A Gentle Introduction to ROS*. Available at <http://www.cse.sc.edu/~jokane/agitr/>. Independently published, Oct. 2013. ISBN: 978-1492143239.
- [55] Claudio Pacchierotti. “Needle Insertion in Simulated Soft Tissue”. In: *Cutaneous Haptic Feedback in Robotic Teleoperation*. Cham: Springer International Publishing, 2015, pp. 21–36. ISBN: 978-3-319-25457-9. DOI: 10.1007/978-3-319-25457-9\_2. URL: [https://doi.org/10.1007/978-3-319-25457-9\\_2](https://doi.org/10.1007/978-3-319-25457-9_2).
- [56] Jaydeep Palep. “Robotic assisted minimally invasive surgery”. In: *Journal of minimal access surgery* 5 (Feb. 2009), pp. 1–7. DOI: 10.4103/0972-9941.51313.
- [57] C. Pham et al. “Analysis of a moving remote center of motion for robotics-assisted minimally invasive surgery”. In: *2015 IEEE/RSJ International Conference on Intelligent Robots and Systems (IROS)* (2015), pp. 1440–1446.
- [58] Morgan Quigley et al. “ROS: an open-source Robot Operating System”. In: *ICRA Workshop on Open Source Software*. 2009.
- [59] R. Woods R. Gonzalez. *Ψηφιακή Επεξεργασία Εικόνας*. Εκδόσεις ΤΖΙΟΛΑΣ, 2018.
- [60] S. Roh et al. “Development of the SAIT single-port surgical access robot slave arm based on RCM Mechanism”. In: *2015 37th Annual International Conference of the IEEE Engineering in Medicine and Biology Society (EMBC)* (2015), pp. 5285–5290.
- [61] *ROS/Concepts - ROS Wiki*. URL: <https://wiki.ros.org/ROS/Concepts> (visited on 09/19/2020).
- [62] Benoît Rosa et al. “Estimation of optimal pivot point for remote center of motion alignment in surgery”. In: *International Journal of Computer Assisted Radiology and Surgery* 10.2 (Feb. 2015), pp. 205–215. ISSN: 1861-6429. DOI: 10.1007/s11548-014-1071-3. URL: <https://doi.org/10.1007/s11548-014-1071-3>.
- [63] Hamid Sadeghian, Fatemeh Zokaei, and Shahram Hadian Jazi. “Constrained Kinematic Control in Minimally Invasive Robotic Surgery Subject to Remote Center of Motion Constraint”. In: *Journal of Intelligent & Robotic Systems* (2019), pp. 1–13.
- [64] H. Shao et al. “A New CT-Aided Robotic Stereotaxis System”. In: 1985.
- [65] Bruno Siciliano et al. *Robotics: Modelling, Planning and Control*. 1st. Springer Publishing Company, Incorporated, 2008. ISBN: 1846286417, 9781846286414.
- [66] I. A. Sucan and S. Chitta. *Moveit!* URL: <https://moveit.ros.org/> (visited on 04/28/2020).
- [67] Ioan Alexandru Sucan and Sachin Chitta. “Motion planning with constraints using configuration space approximations”. In: *2012 IEEE/RSJ International Conference on Intelligent Robots and Systems* (2012), pp. 1904–1910.
- [68] V. Vitiello et al. “Emerging Robotic Platforms for Minimally Invasive Surgery”. In: *IEEE Reviews in Biomedical Engineering* 6 (2013), pp. 111–126.
- [69] Go Watanabe, ed. *Robotic Surgery*. Springer Japan, 2014. DOI: 10.1007/978-4-431-54853-9. URL: <https://doi.org/10.1007/978-4-431-54853-9>.
- [70] Haiwang Xu et al. “Laparoscopic Robot Design and Kinematic Validation”. In: Jan. 2007, pp. 1426–1431. DOI: 10.1109/ROBIO.2006.340138.

- [71] Tao Yang et al. “Mechanism of a Learning Robot Manipulator for Laparoscopic Surgical Training”. In: *Intelligent Autonomous Systems 12*. Ed. by Sukhan Lee et al. Berlin, Heidelberg: Springer Berlin Heidelberg, 2013, pp. 17–26. ISBN: 978-3-642-33932-5.
- [72] L. Yu et al. “Research on the Trajectory Planning of the Minimally Invasive Surgical Robot 6-DOF Manipulator”. In: *2010 International Conference on Biomedical Engineering and Computer Science*. Apr. 2010, pp. 1–4. DOI: 10.1109/ICBECS.2010.5462451.
- [73] Xiaoqin Zhou et al. “New remote centre of motion mechanism for robot-assisted minimally invasive surgery”. In: *BioMedical Engineering OnLine* 17 (2018).
- [74] Νίκος Ασπράγκαθος. *Ρομποτική*. Τμήμα Μηχανολόγων & Αεροναυπηγών Μηχανικών, Πανεπιστήμιο Πατρών, 2018.
- [75] Ζωή Δουλγέρη. *Ρομποτική*. Κριτική, 2007. ISBN: 978-960-218-502-5.
- [76] Κωνσταντίνος Μουστάκας. *Υπολογιστική Γεωμετρία και Εφαρμογές 3Δ Μοντελοποίησης*. Ανακτήθηκε την Κυριακή, 19 Ιουλίου 2020 από <https://eclass.upatras.gr/courses/EE844/>.