

RELIEF DEVICE SHOP TEST CERTIFICATE

Document No.	NHT-PSV-2026-121	Revision	0
Unit	Unit 24 - Naphtha Hydrotreater (NHT)	Date	08-Mar-2026

Tag Number	PSV-2422
Protects	E-2404 Feed / Effluent Exchanger, shell side
Manufacturer / Type	Anderson Greenwood, conventional spring loaded
Size / Orifice	1.5" x 2.5", Orifice 'H'
Set Pressure (nameplate)	12.0 barg
Applicable Tolerance	API 527 / ASME Sec VIII, +/- 3% of set pressure
Test Medium	Nitrogen
Test Date	08-Mar-2026

AS-FOUND TEST RESULTS

Pop No.	As-Found Popping Pressure (barg)
Pop 1	12.60
Pop 2	12.64
Pop 3	12.58
Governing as-found value	12.60

REMARKS

Heavy deposit found on the disc and nozzle seat. As-found popping pressure is elevated relative to the nameplate set pressure. Valve cleaned and lapped; as-left testing deferred pending disposition. Refer Non-Conformance Report raised by the Inspection Department.

NOTE: The acceptance band has deliberately not been arithmetically evaluated on this certificate. Acceptance is to be determined by the Inspection Engineer against the applicable tolerance stated above.

Tested by: Valve Workshop, MRPL

Witnessed by: D. Shenoy, Inspection Department