

NITROGEN PURGING AND ISOLATION PROCEDURE - NHT REACTOR LOOP

Document No.	NHT-SOP-114	Revision	Rev 2
Unit	Unit 24 - Naphtha Hydrotreater (NHT)	Date	22-Aug-2024

Revision Status	SUPERSEDED
Superseded On	15-Jan-2026
Superseded By	NHT-SOP-114 Rev 3
Retention	Held for record only. NOT for field use.

4. NITROGEN PURGING REQUIREMENTS (Rev 2)

Parameter	Rev 2 Requirement
Minimum nitrogen purge duration	2 hours
Oxygen acceptance criterion	less than 8.0 vol%
Number of blind (spade) points	4
LEL criterion	Not specified in Rev 2
Gas test frequency during entry	Every 4 hours

5. BLIND LIST (Rev 2)

BL-01 Reactor feed inlet | BL-02 Reactor effluent outlet | BL-03 Hydrogen make-up line | BL-04 Flare header tie-in

THIS REVISION IS SUPERSEDED. Refer to NHT-SOP-114 Rev 3 for all field execution.