

DHDS-SOP-210 Rev 5 - Nitrogen Purging (CURRENT)

STATUS: CURRENT. Effective 01-Feb-2027. This revision supersedes DHDS-SOP-210 Rev 4 and shall be used for all work dated on or after that date.

5.1 Oxygen acceptance criterion

Oxygen content shall be less than 3.5 vol%.

(Reduced from 6 vol% in Rev 4 following the 2026 reactor entry review.)

5.2 Purge duration

Purge shall run for not less than 6 hours.

5.3 Blind points

8 blind points are required, BL-01 to BL-08.

6. Isolation of V-3302 for entry

Positive isolation requires closure of the two hand valves HV-3351 (inlet) and HV-3352 (outlet), followed by insertion of blinds BL-11 and BL-12.

PSV-3312 is the relief device protecting V-3302 and shall NOT be closed, gagged or isolated as part of any isolation activity.