

Relief Device Shop Test Certificate - PSV-3312

Certificate: DHDS-PSV-2027-081

Unit: Unit 33 - Diesel Hydrodesulphuriser (DHDS)

Tag: PSV-3312

Protects: V-3302 HP Separator

Manufacturer / Type: Anderson Greenwood, conventional

Set Pressure (nameplate), PSV-3312 = 64 barg

Applicable Tolerance, PSV-3312 = API 527 / ASME Sec VIII, +/- 3% of set pressure

Test Date: 02-Apr-2027

Test Medium: Nitrogen

AS-FOUND TEST RESULTS

Governing as-found value = 65.2 barg

AS-LEFT TEST RESULTS

Governing as-left value = 64 barg

Valve re-set to nameplate set pressure and sealed.

NOTE: The acceptance band has deliberately NOT been arithmetically evaluated on this certificate. Acceptance is determined by the Inspection Engineer against the tolerance stated above.