

VESSEL THICKNESS SURVEY REPORT - V-2405 FEED SURGE DRUM

Document No.	NHT-INSP-2026-031	Revision	0
Unit	Unit 24 - Naphtha Hydrotreater (NHT)	Date	12-Mar-2026

1. EQUIPMENT PARTICULARS

Tag Number	V-2405
Service	Naphtha Feed Surge Drum
Material of Construction	SA-516 Gr. 70
Design Pressure	18.5 barg
Design Temperature	315 degC
Year of Manufacture	2011
Nominal Shell Thickness	16.00 mm
Corrosion Allowance	3.00 mm
Minimum Required Thickness (t-min)	9.50 mm
Inspection Code	API 510

2. ULTRASONIC THICKNESS READINGS - SHELL COURSE 1

All readings in millimetres. Same CML grid used on both surveys. Equipment: Olympus 38DL Plus, 5 MHz dual element probe.

CML Point	Survey A 10-Mar-2023	Survey B 10-Mar-2026	Loss (mm)
CML-01	14.55	13.10	1.45
CML-02	14.20	12.70	1.50
CML-03	14.80	13.35	1.45
CML-04	15.10	13.72	1.38
CML-05	14.62	13.18	1.44
CML-06	14.91	13.50	1.41
MINIMUM	14.20	12.70	1.50

3. REMARKS

Governing (thinnest) location is CML-02 on both surveys. The interval between Survey A and Survey B is exactly 3.000 years. No repairs, weld overlay or re-rating has been carried out on this vessel between the two surveys. Corrosion rate and remaining life have NOT been calculated in this report and are to be determined by the Inspection Engineer.

Internal visual inspection on 10-Mar-2026 found light uniform wall loss, no pitting, no cracking. Nozzle N3 and manway gasket faces are in acceptable condition.

Surveyed by: A. Bhandary, ASNT Level II UT (Cert. 4471)

Reviewed by: S. Nayak, Inspection Engineer