

TEMPORARY DEVIATION APPROVAL

Document No.	DEV-2026-017	Revision	0
Unit	Unit 24 - Naphtha Hydrotreater (NHT)	Date	14-Mar-2026

1. SCOPE OF DEVIATION

Deviation Number	DEV-2026-017
Equipment Covered	E-2404 (shell side) ONLY
Equipment NOT Covered	V-2405, PSV-2418, PSV-2422, TK-2410, P-2402A/B
Code Minimum Thickness (t-min)	8.50 mm
Approved Temporary Minimum Thickness	7.80 mm
Valid From	14-Mar-2026
Valid Until (Expiry)	30-Nov-2026
Status	APPROVED - IN FORCE

2. BASIS

A fitness-for-service assessment to API 579-1 Level 2 was carried out for the shell of E-2404 at the measured minimum thickness of 8.20 mm against the shell design pressure of 21.0 barg. The assessment demonstrates an acceptable remaining strength factor at thicknesses down to 7.80 mm. On that basis a temporary reduced minimum thickness of 7.80 mm is approved.

3. CONDITIONS

- (a) Ultrasonic thickness monitoring of CML-03 at quarterly intervals, first due 14-Jun-2026.
- (b) The exchanger shell shall be replaced or permanently repaired at or before the next planned shutdown.
- (c) This deviation expires on 30-Nov-2026 and is NOT automatically renewable. Continued operation beyond that date without a fresh approval is not permitted.
- (d) This deviation applies to E-2404 only and shall not be cited for any other equipment.

Prepared by: S. Nayak, Inspection Engineer

Approved by: K. R. Prabhu, Head - Technical Services

Concurrence: Process Safety Department