

RELIEF DEVICE SHOP TEST CERTIFICATE

Document No.	NHT-PSV-2026-118	Revision	0
Unit	Unit 24 - Naphtha Hydrotreater (NHT)	Date	08-Mar-2026

Tag Number	PSV-2418
Protects	V-2405 Feed Surge Drum
Manufacturer / Type	Anderson Greenwood, conventional spring loaded
Size / Orifice	2" x 3", Orifice 'J'
Set Pressure (nameplate)	24.0 barg
Applicable Tolerance	API 527 / ASME Sec VIII, +/- 3% of set pressure
Test Medium	Nitrogen
Test Date	08-Mar-2026

AS-FOUND TEST RESULTS

Pop No.	As-Found Popping Pressure (barg)
Pop 1	24.50
Pop 2	24.48
Pop 3	24.52
Governing as-found value	24.50

AS-LEFT TEST RESULTS

Pop No.	As-Left Popping Pressure (barg)
Pop 1	24.02
Pop 2	23.98
Governing as-left value	24.00

REMARKS

Seat tightness to API 527 satisfactory. Bellows not fitted. Spring, disc and nozzle in serviceable condition; no evidence of corrosion or deposit. Valve re-set to nameplate set pressure and sealed.

NOTE: The acceptance band has deliberately not been arithmetically evaluated on this certificate. Acceptance is to be determined by the Inspection Engineer against the applicable tolerance stated above.

Tested by: Valve Workshop, MRPL

Witnessed by: D. Shenoy, Inspection Department