

MRPL UNIT 24 NHT - SHIFT LOG SHEET

DOC: NHT-LOG-2026-03-09

SHIFT: NIGHT (22:00 - 06:00)

DATE: 09-MAR-2026

SHIFT IN-CHARGE: R. KAMATH

TIME ENTRY

22:10 Took over charge. Unit stable at 82% throughput.
V-2405 level 55%, pressure 16.2 barg. Normal.

02:15 P-2402B tripped on HIGH VIBRATION.
Vibration recorded 7.8 mm/s RMS at DE bearing.
Trip setpoint is 7.1 mm/s RMS.
Standby pump P-2402A started immediately.
No process upset. Throughput maintained.
Mechanical Maintenance informed at 02:25.

03:40 TK-2410 slop tank level 62%. Routine transfer
to slop recovery lined up. No abnormality.

04:05 E-2404 shell outlet temperature 238 degC,
within normal operating band.

05:50 Handover to day shift. P-2402B REMAINS OUT OF
SERVICE pending vibration investigation.

SIGNED: R. KAMATH

SHIFT IN-CHARGE UNIT 24