

National Load Despatch Centre POWER SYSTEM OPERATION CORPORATION LIMITED

(A Government of India Enterprise)
CIN No.: U40105DL2009GOI188682
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016

Ref: POSOCO/NLDC/SO/Weekly Report

Date: 03rd Jul 2020

To

1. कार्यपालक निदेशक, पू. क्षे. भा. प्रे. के., 14, गोल्फ क्लब रोड , कोलकाता - 700033 Executive Director, ERLDC, 14 Golf Club Road, Tolleygunge, Kolkata, 700033

2. कार्यपालक निदेशक, ऊ. क्षे. भा. प्रे. के., 18/ ए , शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016 Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016

3. कार्यपालक निदेशक, प. क्षे. भा. प्रे. के., एफ-3, एम आई डी सी क्षेत्र , अंधेरी, मुंबई – 400093 Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093

4. कार्यपालक निदेशक, ऊ. पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह , लापलंग, शिलोंग – 793006 Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya

5. कार्यपालक निदेशक, द. क्षे. भा. प्रे. के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु – 560009 Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Weekly Status Report 21st June 2020 to 27th June-2020.

महोदय/Dear Sir,

आई॰ई॰जी॰सी॰-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, 21 जून-2020 से 27 जून-2020, सप्ताह की अखिल भारतीय प्रणाली की ग्रिड निष्पादन रिपोर्ट रा॰भा॰प्रे॰के॰ की वेबसाइट पर निम्न लिंक पर उप्लब्ध है :-

As per article 5.5.1 of the Indian Electricity Grid Code, the weekly status report pertaining power supply position report of All India Power System for the week 21st June 2020 to 27th June-2020 is available at the NLDC website.

Thanking You.

Yours faithfully,

Sr.DGM (SO)

WEEKLY REPORT 21-Jun-2020 - 27-Jun-2020

(आई॰ ई॰ जी॰ सी॰ की धारा संख्या-5.5.1 के अंतर्गत) 1. अधिकतम मांग आपूर्ति और अधिकतम कमी (मे॰वा॰)

REGION	N	IR	w	/R	s	R	ER		NER		TOTAL	
Date	अधिकतम मांग आपूर्त	आधिकतम कमी	अधिकतम मांग आपूर्त	आधकितम कमी	अधिकतम मांग आपूर्त	आधिकतम कमी						
	(मे॰वा॰)	(मे॰वा॰)										
21-06-20	53929	420	39211	0	34679	0	19987	0	2688	3	150,494.0	423.0
22-06-20	57128	480	40537	0	36830	0	20046	0	2777	6	157,318.0	486.0
23-06-20	56929	488	40689	0	37302	0	20902	0	2767	8	158,589.0	496.0
24-06-20	55544	1017	42004	0	36910	0	21526	0	2717	9	158,701.0	1,026.0
25-06-20	55390	492	43095	0	36873	0	19133	0	2551	223	157,042.0	715.0
26-06-20	56521	452	41917	0	37026	0	19563	0	2483	347	157,510.0	799.0
27-06-20	58209	438	41995	0	36513	0	19492	0	2411	12	158,620.0	450.0

2. ऊर्जा आपूर्ति और पनबिजली उत्पादन (मि०यू०)

REGION	N	R	WR		SI	R	EI	R	NE	:R	тот	ΓAL
Date	ऊर्जा आपूर्ति	पनबजिली उत् पाद न	ऊर्जा आपूर्ति	पनबजिली उत्पादन	ऊर्जा आपूर्ति	पनबजिली उत् पाद न	ऊर्जा आपूर्ति	पनबजिली उत्पादन	ऊर्जा आपूर्ति	पनबजिली उत् पाद न	ऊर्जा आपूर्ति	पनबजिली उत् पाद न
	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)	(मि॰यू॰)
21-06-20	1270	358	949	55	861	71	418	132	50	22	3549	637
22-06-20	1294	367	980	69	881	80	419	143	52	22	3626	680
23-06-20	1351	369	995	72	901	85	436	140	51	24	3734	691
24-06-20	1314	371	1015	84	907	88	455	142	50	27	3741	712
25-06-20	1282	373	1042	76	895	85	438	137	46	27	3703	698
26-06-20	1310	363	1012	66	883	73	420	138	45	26	3669	666
27-06-20	1350	356	1007	65	883	76	424	136	43	27	3707	661

3. आवृत्ति (प्रतिशत समय में)

<u>-</u>						
Date	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05	FVI	Average
	ऑo इंo (GRID)	ऑo ईo (GRID)	ऑo इंo (GRID)	ऑo ईo (GRID)	ऑo इंo (GRID)	ऑo इंo (GRID)
21-JUN-20	0.75	0.75	55.97	43.28	0.07	50.048
22-JUN-20	7.00	7.14	83.24	9.62	0.03	49.987
23-JUN-20	10.42	10.42	84.11	5.47	0.04	49.975
24-JUN-20	12.05	12.07	81.32	6.61	0.04	49.976
25-JUN-20	2.16	2.16	85.41	12.43	0.02	50.009
26-JUN-20	0.87	0.91	86.41	12.67	0.02	50.009
27-JUN-20	3.76	3.76	77.18	19.06	0.03	50.008

4. NEW ELEMENTS COMMISSIONED

WEEKLY REPORT 21-Jun-2020 - 27-Jun-2020

5. Maximum Demand Met during the day & Peak Hour Shortage in States (in MW)

Region	Date	21-06	-2020	22-06	-2020	23-06	-2020	24-06	-2020	25-06	-2020	26-06	-2020	27-06	-2020
Region	States	Max.Demand Met during the day	Peak hr Shortage	Max Demand Met during the day	Peak hr Shortage	Max.Demand Met during the day	Peak hr Shortage	Max.Demand Met during the day	Peak hr Shortage						
	J&K(UT) & Ladakh(UT)	2041	510	2156	539	2156	539	2084	521	2197	549	2076	519	2013	503
	Punjab	11902	0	12430	0	12513	0	11352	0	10806	0	11765	0	12120	0
	Haryana	8493	0	8968	0	9012	0	8878	0	9098	0	9221	0	9479	0
	Rajasthan	11219	0	11746	0	11826	0	10912	0	10270	0	10434	0	11104	0
	Delhi	5214	0	5351	0	5457	0	5318	0	5328	0	5371	0	5556	0
NR	UP	20088	0	20100	270	20166	0	20317	270	20203	0	20160	0	20610	170
	Uttarakhand	1683	0	1865	0	1806	0	1826	0	1883	0	1888	0	1942	0
	НР	1267	0	1297	0	1367	0	1269	0	1345	0	1423	0	1266	57
	Chandigarh	286	0	291	0	320	0	289	0	293	0	305	0	318	0
	AMNSIL	792	0	872	0	743	0	720	0	801	0	725	0	836	0
	Chhattisgarh	2977	0	2921	0	3020	0	3403	0	3612	0	3676	0	3632	0
	Gujarat	13325	0	14532	0	14740	0	14449	0	14708	0	14883	0	15239	0
	МР	7750	0	7804	0	7657	0	7810	0	8097	0	7798	0	7576	0
WR	Maharashtra	16396	0	17788	0	18294	0	19030	0	19422	0	17403	0	17115	0
	Goa	410	0	436	0	406	0	423	0	468	0	435	0	431	0
	DD	193	0	231	0	244	0	251	0	243	0	255	0	245	0
	DNH	517	0	559	0	566	0	579	0	589	0	578	0	576	0
	Andhra Pradesh	7767	0	8278	0	8640	0	8812	0	8270	0	8470	0	8336	0
	Telangana	7210	0	7471	0	7663	0	8167	0	8723	0	8681	0	8721	0
SR	Karnataka	9886	0	9860	0	9982	0	10670	0	10437	0	8908	0	8800	0
	Kerala	2689	0	2975	0	3179	0	3226	0	3185	0	3134	0	3044	0
	Tamil Nadu	13111	0	13072	0	13558	0	13499	0	12401	0	12493	0	12916	0
	Pondy	351	0	380	0	368	0	350	0	351	0	364	0	381	0
	Bihar	5175	0	5298	0	5420	0	5571	0	5501	0	5102	0	5269	0
	DVC	2814	0	2707	0	2818	0	2761	0	2693	0	2807	0	2836	0
	Jharkhand	1327	0	1327	0	1327	146	1325	0	1298	0	1334	0	1321	0
ER	Odisha	4004	0	3928	0	4051	0	4361	0	4306	0	4079	0	3949	0
	West Bengal	7751	0	7881	0	7969	0	8267	0	8100	0	7631	0	7427	0
	Sikkim	78	0	83	0	94	0	95	0	94	0	94	0	90	0
	Arunachal Pradesh	119	1	108	1	109	1	107	1	103	0	103	0	102	1
	Assam	1700	14	1760	17	1695	0	1641	0	1567	173	1477	273	1473	10
	Manipur	178	1	181	0	195	1	188	1	186	2	177	1	179	1
NER	Meghalaya	368	0	336	0	318	0	332	0	316	0	334	0	308	0
	Mizoram	88	0	94	1	93	1	96	2	91	0	96	0	95	1
	Nagaland	127	0	139	2	137	1	132	1	123	1	117	0	118	2
	Tripura	267	3	286	5	298	3	293	4	294	2	287	3	263	1

WEEKLY REPORT 21-Jun-2020 - 27-Jun-2020

6. Energy Consumption in States (MUs)

gion	States	21-06-2020	22-06-2020	23-06-2020	24-06-2020	25-06-2020	26-06-2020	27-06-2020
	J&K(UT) & Ladakh(UT)	44.7	44.5	43.1	41.4	42.4	41.8	43.0
	Punjab	264.4	249.1	275.4	259.3	241.8	256.1	273.1
	Haryana	175.1	180.6	201.7	202.4	198.8	203.2	206.3
	Rajasthan	248.1	253.9	254.5	241.5	229.5	233.6	242.7
	Delhi	97.9	101.9	107.3	107.3	106.6	108.4	106.6
NR	UP	373.7	390.1	394.0	388.8	389.6	391.6	401.7
	Uttarakhand	34.0	40.0	40.2	39.9	40.6	41.3	42.9
	НР	27.0	27.9	28.9	27.5	27.2	28.4	27.7
	Chandigarh	5.0	5.5	6.1	5.7	5.7	6.0	6.2
	AMNSIL	17.0	17.3	15.8	15.5	17.9	16.0	17.1
	Chhattisgarh	72.2	65.1	69.0	76.6	85.8	86.2	87.1
	Gujarat	296.1	306.1	311.3	311.5	311.2	317.6	321.5
	МР	172.8	176.5	171.1	171.6	179.2	174.5	166.2
WR	Maharashtra	367.4	388.6	400.5	412.3	420.1	389.8	387.0
	Goa	8.2	8.9	8.7	8.9	9.3	9.2	9.2
	DD	3.5	4.6	5.3	5.4	5.4	5.5	5.4
	DNH	12.1	12.5	12.9	13.0	13.2	13.2	13.2
	Andhra Pradesh	170.4	169.7	176.6	176.9	171.8	173.8	173.6
	Telangana	149.4	157.6	159.9	168.6	174.9	179.0	175.3
SR	Karnataka	183.3	190.7	196.1	196.0	192.5	173.2	174.9
	Kerala	57.7	61.8	64.4	66.9	67.2	65.6	63.1
	Tamil Nadu	293.1	293.4	296.2	291.2	281.5	283.4	288.1
	Pondy	7.3	7.8	7.7	7.4	7.4	7.7	7.9
	Bihar	99.4	99.0	102.8	109.3	93.4	89.6	99.2
	DVC	59.2	56.8	62.0	61.5	58.4	59.0	61.7
	Jharkhand	24.3	25.2	25.8	25.8	25.3	24.8	26.8
ER	Odisha	85.5	83.5	84.3	89.1	91.7	87.9	84.9
	West Bengal	148.9	153.4	159.8	168.0	167.2	157.3	150.5
	Sikkim	0.9	1.2	1.3	1.3	1.5	1.3	1.3
	Arunachal Pradesh	2.1	2.0	2.0	1.9	2.0	2.1	2.1
	Assam	31.7	33.3	32.2	30.7	26.9	25.7	24.7
	Manipur	2.6	2.5	2.7	2.6	2.5	2.6	2.6
NER	Meghalaya	5.6	5.7	5.7	5.6	5.6	5.5	5.3
	Mizoram	1.5	1.6	1.7	1.7	1.7	1.7	1.7
	Nagaland	2.2	2.2	2.3	2.2	2.3	2.3	2.4
	Tripura	4.8	4.8	4.9	5.2	5.2	5.0	4.3
ALI I	NDIA TOTAL	3549.0	3625.3	3734.0	3740.3	3703.0	3669.7	3707.2

WEEKLY REPORT 21-Jun-2020 - 27-Jun-2020

(आई० ई० जी० सी० की धारा संख्या-5.5.1 के अंतर्गत) 7. अंतर्क्षेत्रीय विनिमय [प्रथम क्षेत्र से द्वितीय क्षेत्र को आयात (+) / निर्यात (-)]

दिनांक	21-06-2020	22-06-2020	23-06-2020	24-06-2020	25-06-2020	26-06-2020	27-06-2020
East to North	-85.6	-96.0	-99.3	-96.7	-101.0	-105.5	-104.1
East to West	44.8	40.0	36.1	39.9	39.0	42.2	41.1
East to South	-77.3	-90.3	-98.6	-108.1	-109.9	-111.1	-107.3
East to North-East	-5.6	-7.6	-5.3	-1.2	-3.1	-4.4	-4.1
North-East to North	-12.2	-12.3	-11.9	-13.0	-14.0	-14.3	-16.1
West to North	-156.3	-162.4	-183.3	-168.1	-145.5	-166.8	-174.6
West to South	-56.8	-61.0	-62.2	-83.6	-90.8	-96.6	-80.8

भूटान , नेपाल एवं बांग्लादेश के साथ अंतरराष्ट्रीय विद्युत विनिमय INTERNATIONAL EXCHANGE WITH BHUTAN, NEPAL AND BANGLADESH

WEEKLY REPORT 21-Jun-2020 - 27-Jun-2020 अंतरराष्ट्रीय विद्युत विनिमय [भारत से दूसरे देश को आयात (+) / निर्यात (-)] Transnational Exchange from India (Import=(+ve) /Export =(-ve))

A 10									
दिनांक	भूटान в	HUTAN		नेपाल NEPAL		बांग्लादेश BANGLADESH			
Date	Energy Exchange (In MU)	Day Average (MW)	Energy Exchange (In MU)	Day Peak (MW)	Day Average (MW)	Energy Exchange (In MU)	Day Peak (MW)	Day Average (MW)	
21-06-2020	48.7	2030	-1.8	-181	-77	-25.1	-1096	-1048	
22-06-2020	49.3	2056	-1.6	-207	-66	-24.6	-1129	-1026	
23-06-2020	47.2	1965	-1.8	-177	-74	-25.7	-1130	-1069	
24-06-2020	47.3	1972	-2.3	-303	-97	-26.4	-1123	-1098	
25-06-2020	48.1	2003	-2.3	-173	-95	-26.4	-1124	-1098	
26-06-2020	52.2	2175	-1.5	-127	-63	-25.7	-1118	-1072	
27-06-2020	53.0	2208	-0.6	-138	-27	-25.7	-1117	-1070	
TOTAL	345.79		-11.9			-179.6			

L.,			T			Major Gr	id Incide	nce(Provisio	onal)		1	
S.No.	Region	Name of Elements	Owner / Agency	Outage		Revi	val	Outage Duration	Event	Generation	Load Loss(MW)	Category as per
5.140.	region	(Tripped/Manually opened)	Owner / Agency	Date	Time	Date	Time	Time	(As reported)	Loss(MW)	Load Loss(MW)	CEA Grid Standards
1	WR	Tripping of 1.220 kV Pithampur Bus 1 2.220 kV Pithampur-Pithampur I/C1 3.220 kV Pithampur-Pithampur Sector1 4.400/220 kV Pithampur I/C1 1.82	MPPTCL	23-Jun-20	23:50	24-Jun-20	02:08	02:18	At 400/220 kV Pithampur substation, R phase PT of 220 kV Bus 1 blasted and resulted in tripping of all the elements connected to 220 kV Pithampur Bus 1. 400/220 kV Pithampur ICT 2 connected to 220 kV Bus 2, also tripped during the event.	Nil	Nil	GI-1
2	WR	Tripping of 1.400 N v Jepur Bus 2 2.400 N v Jepur Aus 2 2.400 N v Jepur Aus 2 3.400 N v Coft - Jepur 2 4.400 (220 N v Jepur KTS 18.2	GETCO	29-Jun-20	15:02	29-Jun-20	16:59	01:57	At 400 kV Jetpur substation, 400 kV Bus 2 and all connected elements tripped on 88 protection operation due to 8-E phase fault created by external conductive wire(lite thread) near 400 kV Amreli 1 bay.	Nil	Nil	GI-2
3	WR	Tripping of 1.400 kV Essar Vadinar-Hadals 1 2.600 kW Essar Vadinar Unit 1	Essar	30-Jun-20	12:58	30-Jun-20	13:35	00:37	At 400 kV Essar Vadinar station, while test charging 400kV Essar Vadinar-Hadala 2 from Hadala end at 12-58hrs, 400kV Essar Vadinar- Hadala 1 tripped from Vadinar end. Due to tripping of both the lines, the station got black out. 600MW Essar Vadinar Unit 1 tripped due to the loss of evacuation path.	485	NII	GD-1
4	WR	Tripping of 1.220 kV Talegoon(MH) Bus 1 1.220 kV Talegoon(MH) Bus 1 1.220 kV Talegoon(MH)-Talegoon(FG) 1 1.220 kV Talegoon(MH)-Unse 1 1.220 kV Talegoon(MH)-Unse 1 1.220 kV Talegoon(MH)-Unse 1 1.220 kV Talegoon(MH) KT 2 1.220 kV Talegoon(MSETCL	30-Jun-20	21:52	30-Jun-20	22:50	00:58	At 220 kV Talegaon(MH), 220 kV side Y phase CT of 220/22 kV ICT 2 blasted and resulted in tripping of 220 kV Bus 1 and all the connected elements on 88 operation.	NII	10	GI-1
5	SR	L 400/220X VCT-1 E 400/220X VCT-3 E 400/220X VCT-3 E 20X Versign - Bernava an V 20X Versign - Bernava an V 20X Versign - Some -	APTRANSCO	22-Jun-20	06:22	22-Jun-20	06:44	00:22	Tripping of 220kV Bus-1 at 400/220kV Vemagiri station: Triggering incident was B-ph to ground fault in 220kV Vemagiri - Sommuru Line-2 in 220kV Vemagiri - Vijjeswaram feeder. As reported, an alluminum lead fell on B-Phase Bus-1 siolator dropper connected to 220kV Vijjeswaram feeder: Bus bar protection of 220kV Bus-1 operated and all elements connected to the bus tripped.			GI-1
6	SR	L 230kV Myvadi - Kadamparai line-18. 2 II. 230kV Myvadi - Kadamparai line-18. 2 III. 230kV Myvadi - Omnapuram line-18. 2 IV. 230kV Myvadi - Olimandapaum V. 230kV Myvadi - Olimandapaum V. 230kV Myvadi - Sembathy Vil 230kV Myvadi - Karikathy Vil 230kV Myvadi - Analkathy Vil 230k	TANTRANSCO	22-Jun-20	23:47	23-Jun-20	02:11	02:24	Complete outage of 230kV Mywadi substation of TANTRANSCO: During antecedent conditions, 230kV Mwyadi SS was under single bus operation. Triggering incident was failure of 8 phase CT of 230kV Mywadi-Ponnapuram line; 2 at 230kV Mywadi end. 230 kV Bus-1 bus bar protection operated resulting in the tripping of all the connected elements at 230kV Mywadi . 400kV/230kV Udumalpet ICT-1, 2 and 3 also got tripped during the event.			GD-1
7	SR	I. 220kV Pavagada - KSOPCL3	KSPDCL	25-Jun-20	02:43	25-Jun-20	03:28	00:45	Complete outage of 220/33kV KSPDCL SS-3: Triggering incident was tripping of 220kV Pavagada – KSDPCL3 line due to overvoltage at 220kV Pavagada end. Since the only connected fedeet ripped, there was complete outage at 220/33kV KSDPCL SS-3. Solar generation was not there since the event happened during night hours.			GD-1
8	SR	L 220kV Pavagada - Thriumani (KSPOCLS)	KSPDCL	29-Jun-20	18:01	29-Jun-20	18:55	00:54	Complete outage of 220/33kV KSPDCL SS-5 (Thirumani): Triggering incident was tripping of 220kV Pavagada - Thirumani line due to overvoltage at Thirumani end only. Line did not trip at Pavagada en This resulted in complete outage of 220/33kV KSPDCL SS-5 since the only connected feeder tripped.	25 MW		GD-1
9	ERLDC	220 KV Joda — TTPS D/C 220 KV Ramchandrapur – Joda S/C 220 KV Joda Jindia S/C	OPTCL	23-Jun-20	11:58	23-Jun-20	12:29	00:31	At 11:41 hrs 220 kV Joda – TTPS D/C tripped on 8 phase to earth fault. At 11:57 hrs, 220 kV Ramchandrapur – Joda 5/C tripped on overload. Prior to the tripping, power flow was 160 MW. At Same time 20 kV Joda 15/L (jilidal) – Jamshedwr 5/C tripped at same time from Ramchandrapur and Jamshedpur end respectively in overcurrent protection	0	160	GD-1
10	ERLDC	220 kV Muzziffarpur - Dhalkebar D/C	ISTS	24-Jun-20	18:23	24-Jun-20	19:12	00:49	220 kV Muzaffarpur Dhalkebar D/C tripped at 18:23 hrs from Muzaffarpur end on R phase directional earth fault. Prior to the tripping schedule of Nepal drawal over this link was 74 MW and it would increase to 163 MW w.e.f. 18:30 hrs. There was no generation or load loss reported in Indian grid at the time of the event.	0	0	GI-1
11	ERLDC	400 NV Allpurduar - Rigmelling D/C Unit 1 and 2 at Mangdechu	ISTS	25-Jun-20	02:47	25-Jun-20	04:02	01:15	400 kV Alipurduar-Jigmelling D/C tripped at 02:47 Hrs due to R phase to earth fault. At Alipurduar, auto reclose was successful for both circuits. But both the circuits tripped from Jigmelling. Around 590 MW generation loss was reported at the time of the event. There was no generation or load loss reported in Indian grid at the time of the event.	0	0	GI-2
12	ERLDC	400 kV Alipurduar - Rigmelling D/C Unit 1 and 2 at Mangdechu	ISTS	26-Jun-20	15:40	26-Jun-20	17:07	01:27	400 kV Jigmelling - Alipurduar - 1 along with all four running units (generating around 770 MW) of Mangdechu tripped at 15:40 hrs. D1 signal was received at Alipurduar end of 400 kV Jigmelling Alipurduar - 1 at the time of the tripping, Later, at 15:53 hrs. 400 kV Jigmelling - Alipurduar - 2 also tripped due to B phase to earth fault. 400 kV Jigmelling - Alipurduar - 1 was extended from Alipurduar end at 16:24 hrs. But while synchronising at Jigmelling end, it tripped again at 16:64 brs with D1 Treeved at received at Alipurduar. There was no generation or load loss reported in Indian grid at the time of the event.	0	0	GI-2
13	ERLDC	400 kV GMR – Meramundall S/C GMR unit #3	OPTCL	26-Jun-20	18:43	26-Jun-20	20:21	01:38	GMR unit # 3 was connected to 400/220 kV Meramundali S/S of OPTCL STU network through 400 kV GMR – Meramundali S/C. At 1843 hrs, 400 kV GMR Meramundali S/C tripped due to DT received at Meramundali GMR is caused total power failure at 61MR (OPTCL) section and GMR unit #3 tripped. In PMU data, no fault was observed at the time of event	180	0	GD-1
14	ERLDC	400 NV Rangpo — Kishanguni S/C Uset 1 and 2 Ar Dikchu HEP Uset 1 at J.HEP	PG/Greenko/JLHEP	27-Jun-20	14:48	27-Jun-20	15:08	00:20	At 14:48 hrs 400 kV Rangpo – Kishangunj S/C tripped due to 8 phase to earth fault. At same time, unit 1 and 2 at Dikchu HEP and unit 2 at Jorethang tripped due to operation of differential relay.	161	0	GI-2
15	ERLDC	400 kV BRBCL - Sasaram - 1 Unit 1 and 2 at BRBCL	BRBCL	29-Jun-20	21:53	29-Jun-20	22:25	00:32	400 kV BRBCL – Sasaram – 2 was under break down due to rectification of tower bending. Unit 1 and 2 were in running condition at BRBCL At 21:53hrs., 400kV Sasaram-BRBCL #1 tripped on R and Y phase fault. Both the units g	422	0	GD-1

16	NER	132 NV Polatama-Surajmaninagar line, 132 NV Agartale-Surajmaninagar line 132 NV Budhjungsagar-Surajmaninagar I 8. Il lines	TSECL , PGCB POWERGRID	22-Jun-20	10:23	22-Jun-20	10:38		Surjamaninagar Area of Tripura Power System and Comilla Load of Bangladesh Power System were connected with the rest of NER Grid through 132 kV Palatana-Surajmaninagar I & Illine W Agartala Surajmaninagar I & Illinea and 132 kV Budlungnagar-Surajmaninagar I & Illinea At 10.23 Hrs on 22.06.2000, 132 kV Palatana-Surajmaninagar II. & Illinea At 10.28 Hrs on 22.06.2000, 132 kV Palatana-Surajmaninagar II. all Index Surajmaninagar III. allinea and 132 kV Budlungnagar-Surajmaninagar II. all Index Hrs. 132 kV Agartala-Surajmaninagar III. allinea and 132 kV Budlungnagar-Surajmaninagar III. allinea and 132 kV Budlungnagar-Surajmaninagar II. allinea and Comilla Load of Bangladesh Power System were separated from the rest of NER Grid and subsequently coalspared due to no source in this series.	0	132	GD-1
17	NR	1550AV LCT 3 a 400VV biologyph 1530 VA company 6 coloning pin 1530 VA company 6 coloning pin 1530 VA sampur 1540 Sampur 1540 VA sampur 1540 Sampur 1540 Sampur 1540 VA sampur 1540 Sampur 1540 Z 200 VA sampur 1540 Z 200 VA sampur 1540 Z	ввмв	29-Jun-20	09:28	29-Jun-20	10:48	01:20	As reported by BBMB, Bus bar protection operated at Samaypur station resulting in tripping of Bus-1 and elements connected with it.	Nil	141	GD-1
18	NR	NUPC Line (\$250 MW) Rampor Line (\$250 MW) Rampor Line (\$250 MW) Rampor Line (\$260 MW) Rampor Line (\$260 MW) Rampor Line (\$460 MW) Rampor Line (\$460 MW)	NJPC/SJVNL	28-Jun-20	04:23	28-Jun-20	05:20	00:57	NJPC Units tripped due to "GHC PLC" problem (48 V DC Failure).Rampur units tripped as running in tandem with NJPC.Generation loss of 980 MW(approx) as per SCADA. Generation was revived by 06-41Hrs	980	Nil	GD-1