III. Results: Answers to Research Questions

This section synthesizes findings from the reviewed studies to answer the five research questions guiding GridMind.

A. RQ1 (State of the Art): What research and solutions exist for AI-based telemetry reconstruction, demand and renewable forecasting, event diagnosis, cascade-risk prediction, and corrective-action recommendation?

Telemetry recovery uses measurement history and network relationships to reconstruct missing values. The STGNI graph model supports state estimation, auxiliary-task learning recovers voltage phasors from phasor measurement units (PMUs), and physics-guided recovery handles voltage, current, and power together [1]–[3]. These methods address random and consecutive losses, although their different measurement types limit direct substitution.

Forecasting research compares separate predictions with joint models. Bolusteve et al. predict net load directly or calculate it from separate demand, wind, and solar forecasts [4]. Voyant et al. use a multi-output extreme learning machine (ELM), while Wang et al. link wind, solar, and load through attention and multi-task learning [5], [6]. Each approach uses relationships among energy variables differently.

Diagnosis separates unreliable measurements from physical disturbances. Forecasting-aided state estimation distinguishes bad data from sudden load changes [7]. Other studies detect, classify, and locate electrical events using recurrent models, staged random-forest/convolutional neural network (CNN) diagnosis, or separate classification and localization models [8]–[10]. A measurement anomaly and an electrical fault therefore require different interpretations.

Cascade research includes both outcome prediction and vulnerability ranking. Learned interaction graphs describe dependencies between line failures and final states [11]; graph attention and temporal Transformers predict cascading faults [12]. Weighted natural connectivity identifies critical transmission lines [13]. Ranking a line as vulnerable does not specify when it will fail.

Corrective actions depend on the controls available. Learned decision rules manage congestion through topology changes, while hybrid particle-swarm/grey-wolf optimization adjusts generator outputs [14], [15]. Learning-based optimal power flow (OPF) methods also differ in how they enforce operating constraints [16]. Results from switching and redispatch consequently concern different interventions.

Integration studies assess how predictions influence decisions. AIOpti shows that lower forecasting error can accompany poorer optimization outcomes [17]. The Cascade-Aware Risk Index (CARI) combines fault likelihood, propagation, vulnerability, and impact to prioritize maintenance [18]. These studies connect specific tasks; neither evaluates all five capabilities within one platform.

B. RQ2 (Methods): Which models, datasets, technologies, and evaluation approaches support these capabilities, and what tradeoffs do they present?

Reconstruction methods combine spatial and temporal learning with different assumptions. STGNI models relationships between nodes and edges; auxiliary-task learning adds low-rank online adaptation; physics-guided recovery introduces physical correction [1]–[3]. Tests use NREL-118 and provincial measurements, 50-Hz simulated phasors from a 145-bus system, and IEEE 33-node OpenDSS data based on European load profiles. Reconstruction error and downstream state-estimation performance assess different aspects of recovery.

Forecasting comparisons depend on horizon and data resolution. The ERCOT study uses hourly data from 2021 to 2024, renewable-capacity features, and NLDAS weather inputs. With a chronological 90%/5%/5% training/validation/test split and 1,754 common test timestamps, indirect long short-term memory (LSTM) achieves 2.46% mean absolute percentage error (MAPE), versus 2.73% for direct LSTM, one hour ahead [4]. The Corsican ELM study compares persistence and LSTM using hourly EDF generation-mix data from 2018 to 2023 [5]. Wang et al. instead forecast day-ahead using one year of 15-minute records from eight wind farms, six solar plants, and nearby city load [6].

Diagnosis results depend on the output being assessed. Shadi et al. test recurrent models on IEEE 14-bus, New England 39-bus, and modified IEEE 118-bus systems; missing PMUs impair localization more than classification [8]. Riaz et al. use simulated three-phase currents from a modified IEEE 14-bus system [9]. On IEEE 9-bus simulated faults, XGBoost achieves 99.82% classification accuracy, while CNN-LSTM localization has MAPE below 1% [10]. Precision, recall, and F1 measure classification performance [8]. The Stedin 50-kV Real Time Digital Simulator case additionally compares extended and unscented Kalman filters through estimation accuracy and runtime [7].

Cascade methods use different targets and benchmarks. Inverse-Ising and boosted-tree models analyze final states from 50,000 IEEE 118-bus cascade trajectories [11]. Graph attention, temporal modeling, and self-supervision are evaluated on modified IEEE 39-bus AC/DC and Chinese-grid cases [12]. Natural-connectivity rankings are compared with critical-line indices across IEEE networks and a Mexican 400-kV system [13]. Agreement between rankings and predictive discrimination provide different evidence.

For corrective actions, the L2RPN-WCCI-2022 IEEE 118-bus benchmark measures score, survival, cost, and inference time [14]. IEEE 30-bus redispatch experiments compare congestion cost, adjusted power, and losses [15]; OPF evaluation also considers feasibility and optimality [16]. Cost-aware CARI reduces its normalized action-cost proxy from 50.2 to 33.4 with approximately unchanged energy-not-served benefits [18]. These maintenance results use simulation proxies. AIOpti evaluates downstream decision quality alongside prediction error [17].

Confidential feeder and wind, solar, and load data restrict exact replication [3], [6]. Named benchmarks help identify test settings, but network access alone does not reproduce scenario generation or training. Simulation supports controlled comparisons; transfer to another topology or utility needs separate validation. The auxiliary-task reconstruction and ERCOT studies are preprints [2], [4]. Differences in tasks, horizons,

and evaluation conditions prevent a universal ranking of the reported scores.

REFERENCES

[1] P. Li, Z. Dai, Z. Wang, and Y. Yu, "Spatio-temporal dynamic graph neural network-based missing measurement recovery method for power system state estimation," *Applied Energy*, 2026. [Online]. Available: https://doi.org/10.1016/j.apenergy.2026.127604

[2] B. Li, Z. Chen, H. Zhong, D. Cao, and G. Ruan, "A Graph Neural Network with Auxiliary Task Learning for Missing PMU Data Reconstruction," *arXiv preprint*, 2025, arXiv:2512.24542. [Online]. Available: https://arxiv.org/abs/2512.24542

[3] W. Wei, P. Huang, T. Xu, L. Guo, X. Huang, and Y. Wang, "Measurement data recovery for power distribution systems based on physics-guided spatio-temporal graph neural network and online data fusion," *Energy and AI*, 2026. [Online]. Available: https://doi.org/10.1016/j.egyai.2026.100754

[4] O. S. Bolusteve, L. Fang, and X. Li, "Net Load Forecasting with Renewable Capacity Features: A Comparison of Direct and Indirect Neural Network Methods," *arXiv preprint*, 2026, arXiv:2604.17012v2. [Online]. Available: https://arxiv.org/abs/2604.17012v2

[5] C. Voyant, M. Despotovic, L. Garcia-Gutierrez, M. Asloune, Y.-M. Saint-Drenan, J.-L. Duchaud, G. A. Faggianelli, and E. Magliaro, "Short-term forecasting of energy production and consumption using extreme learning machine: A comprehensive MIMO based ELM approach," *Applied Energy*, 2026. [Online]. Available: https://doi.org/10.1016/j.apenergy.2026.127599

[6] H. Wang, J. Yan, J. Zhang, S. Liu, Y. Liu, S. Han, and T. Qu, "Short-term integrated forecasting method for wind power, solar power, and system load based on variable attention mechanism and multi-task learning," *Energy*, 2024. [Online]. Available: https://doi.org/10.1016/j.energy.2024.132188

[7] N. Veerakumar, D. Ćetenović, K. Kongurai, M. Popov, A. Jongepier, and V. Terzija, "PMU-based Real-time Distribution System State Estimation Considering Anomaly Detection, Discrimination and Identification," *International Journal of Electrical Power & Energy Systems*, 2023. [Online]. Available: https://doi.org/10.1016/j.ijepes.2022.108916

[8] M. R. Shadi, M.-T. Ameli, and S. Azad, "A real-time hierarchical framework for fault detection, classification, and location in power systems using PMUs data and deep learning," *International Journal of Electrical Power & Energy Systems*, 2022. [Online]. Available: https://doi.org/10.1016/j.ijepes.2021.107399

[9] Z. Riaz, A. Q. Khan, S. Habib, M. Saad, F. Zaman, S. M. Alghamdi, and A. Yousef, "Hybrid machine learning and deep learning framework for multi-stage fault diagnosis in modern power systems," *Energy Reports*, 2026. [Online]. Available: https://doi.org/10.1016/j.egyr.2026.109558

[10] N. Q. Minh, N. T. Khiem, and V. H. Giang, "Fault classification and localization in power transmission line based on machine learning and combined CNN-LSTM models," *Energy Reports*, 2024. [Online]. Available: https://doi.org/10.1016/j.egyr.2024.11.061

[11] A. Ghasemi, H. de Meer, and H. Kantz, "Interaction graph learning of line cascading failure in power networks and its statistical properties," *Energy Informatics*, 2023. [Online]. Available: https://doi.org/10.1186/s42162-023-00285-0

[12] W. Qin, X. Liu, and Y. Tao, "The research on cascading failure prediction in AC-DC hybrid power grids based on deep learning," *Discover Computing*, 2026. [Online]. Available: https://doi.org/10.1007/s10791-026-10130-z

[13] F. Rivas-Dávalos, J. Sánchez-Jaime, P. Acosta-Reyes, and L. Alvarez-Farias, "Identifying critical transmission lines in cascading outages using the natural connectivity index," *Discover Electronics*, 2024. [Online]. Available: https://doi.org/10.1007/s44291-024-00035-w

[14] F. Moaidi and R. J. Bessa, "Evolving power system operator rules for real-time congestion management," *Energy and AI*, 2026. [Online]. Available: https://doi.org/10.1016/j.egyai.2025.100672

[15] A. Gautam, P. Sharma, and Y. Kumar, "Mitigating congestion by optimal rescheduling of generators applying hybrid PSO-GWO in deregulated environment," *SN Applied Sciences*, 2021. [Online]. Available: https://doi.org/10.1007/s42452-020-04084-0

[16] H. Khaloie, M. Dolányi, J.-F. Toubeau, and F. Vallée, "Review of machine learning techniques for optimal power flow," *Applied Energy*, 2025. [Online]. Available: https://doi.org/10.1016/j.apenergy.2025.125637

[17] G. Wang, Z. Lin, Y. Chen, H. Ji, D. Chen, H. Zhang, P. Li, and J. Yan, "AI-Optimized Decision-Making in Energy Systems: Toward a Decision-Aware Machine Learning Framework," *Engineering*, 2025, in press. [Online]. Available: https://doi.org/10.1016/j.eng.2025.06.037

[18] K. T. Worou, A. Guenoukpati, and A. A. Salami, "A cascade-aware risk index for digital-twin-based, cost-sensitive predictive maintenance in power grids," *e-Prime - Nexus of Electrical, Electronic, and Intelligent Engineering*, 2026. [Online]. Available: https://doi.org/10.1016/j.eprime.2026.201225