

Project:

Location:

Contract:

Engineer:

Filename: first_project

ETAP

19.0.1C

Bus FDR Loading-1

Loading Category: Design

Page: 1

Date: 06-05-2026

SN:

Revision: Base

Config.: Normal

Bus ID:	Bus5									
Voltage:	230.00 kV			Rating: 0 A, 0 kVA						
Connected Feeders & Loads	Description	Status	Connected Loads			Operating Loads				
			kW	kvar	kVA	kW	kvar	kVA	% PF	% EFF
step_down_transformer		C	64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	80.00	
		I	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
		S	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Bus Summary	Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00		
	Intermittent		0.00	0.00	0.00	0.00	0.00	0.00		
	Spare		0.00	0.00	0.00	0.00	0.00	0.00		
	Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00	

Operating Loads = Connected Loads X % Loading
Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor (Bus Diversity Factors are applied to directly connected loads only.)
Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads
Diversity Factors: C: None, I: None, S: None
Nodes are not reported.

Project:	ETAP	Page:	2
Location:	19.0.1C	Date:	06-05-2026
Contract:		SN:	
Engineer:	Bus FDR Loading-1	Revision:	Base
Filename: first_project	Loading Category: Design	Config.:	Normal

Bus ID: Bus6

Voltage: 13.80 kV Rating: 0 A, 0 kVA

Connected Feeders & Loads	Description	Status	Connected Loads			Operating Loads			
			kW	kvar	kVA	kW	kvar	kVA	% PF % EFF
underground_cable		C	64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	80.00
		I	0.00	0.00	0.00	0.00	0.00	0.00	0.00
		S	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus Summary	Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	
	Intermittent		0.00	0.00	0.00	0.00	0.00	0.00	
	Spare		0.00	0.00	0.00	0.00	0.00	0.00	
	Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00

Operating Loads = Connected Loads X % Loading

Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor (Bus Diversity Factors are applied to directly connected loads only.)

Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads

Diversity Factors: C: None, I: None, S: None

Nodes are not reported.

Project:	ETAP	Page:	3
Location:	19.0.1C	Date:	06-05-2026
Contract:		SN:	
Engineer:	Bus FDR Loading-1	Revision:	Base
Filename: first_project	Loading Category: Design	Config.:	Normal

Bus ID: Bus7

Voltage: 13.80 kV

Rating: 0 A, 0 kVA

Connected Feeders & Loads	Description	Status	Connected Loads			Operating Loads				
			kW	kvar	kVA	kW	kvar	kVA	% PF	% EFF
Feeder1		C	32000.00	24000.00	40000.00	32000.00	24000.00	40000.00	80.00	100.00
Feeder2		C	32000.00	24000.00	40000.00	32000.00	24000.00	40000.00	80.00	100.00
Bus Summary	Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00		
	Intermittent		0.00	0.00	0.00	0.00	0.00	0.00		
	Spare		0.00	0.00	0.00	0.00	0.00	0.00		
	Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00	

Operating Loads = Connected Loads X % Loading

Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor (Bus Diversity Factors are applied to directly connected loads only.)

Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads

Diversity Factors: C: None, I: None, S: None

Nodes are not reported.

Project:	ETAP	Page:	4
Location:	19.0.1C	Date:	06-05-2026
Contract:		SN:	
Engineer:	Bus FDR Loading-1	Revision:	Base
Filename: first_project	Loading Category: Design	Config.:	Normal

Bus ID: TX_substation

Voltage: 230.00 kV Rating: 0 A, 0 kVA

Connected Feeders & Loads	Description	Status	Connected Loads			Operating Loads			
			kW	kvar	kVA	kW	kvar	kVA	% PF % EFF
Transmission_Line		C	64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	80.00
		I	0.00	0.00	0.00	0.00	0.00	0.00	0.00
		S	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus Summary	Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	
	Intermittent		0.00	0.00	0.00	0.00	0.00	0.00	
	Spare		0.00	0.00	0.00	0.00	0.00	0.00	
	Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00

Operating Loads = Connected Loads X % Loading

Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor (Bus Diversity Factors are applied to directly connected loads only.)

Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads

Diversity Factors: C: None, I: None, S: None

Nodes are not reported.