

Bus ID: Bus5

Voltage: 230.00 kV Rating: 0 A, 0 kVA

Connected Feeders & Loads	Description	Status	Nameplate Rating	Operating Load	Unit	Connected Loads			Operating Loads				
						kW	kvar	kVA	kW	kvar	kVA	% PF	% EFF
step_down_transformer		C				64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	80.00	
		I				0.00	0.00	0.00	0.00	0.00	0.00	0.00	
		S				0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Bus Summary				Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00		
				Intermittent		0.00	0.00	0.00	0.00	0.00	0.00		
				Spare		0.00	0.00	0.00	0.00	0.00	0.00		
				Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00	

Operating Loads = Connected Loads X % Loading
Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor Bus Diversity Factors are applied to directly connected loads.
Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads
Diversity Factors: C: None, I: None, S: None

Bus ID: Bus6

Voltage: 13.80 kV Rating: 0 A, 0 kVA

Connected Feeders & Loads	Description	Status	Nameplate Rating	Operating Load	Unit	Connected Loads			Operating Loads				
						kW	kvar	kVA	kW	kvar	kVA	% PF	% EFF
underground_cable		C				64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	80.00	
		I				0.00	0.00	0.00	0.00	0.00	0.00	0.00	
		S				0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Bus Summary				Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00		
				Intermittent		0.00	0.00	0.00	0.00	0.00	0.00		
				Spare		0.00	0.00	0.00	0.00	0.00	0.00		
				Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00	

Operating Loads = Connected Loads X % Loading
Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor Bus Diversity Factors are applied to directly connected loads.
Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads
Diversity Factors: C: None, I: None, S: None

Project:
Location:
Contract:
Engineer:
Filename: first_project

ETAP
19.0.1C

Bus FDR Loading-3
Loading Category: Design

Page: 3
Date: 06-05-2026
SN:
Revision: Base
Config.: Normal

Bus ID: Bus7

Voltage: 13.80 kV Rating: 0 A, 0 kVA

Connected Feeders & Loads	Description	Status	Nameplate Rating	Operating Load	Unit	Connected Loads			Operating Loads				
						kW	kvar	kVA	kW	kvar	kVA	% PF	% EFF
Feeder1		C	40000.00	40000.00	kVA	32000.00	24000.00	40000.00	32000.00	24000.00	40000.00	80.00	100.00
Feeder2		C	40000.00	40000.00	kVA	32000.00	24000.00	40000.00	32000.00	24000.00	40000.00	80.00	100.00
Bus Summary				Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00		
				Intermittent		0.00	0.00	0.00	0.00	0.00	0.00		
				Spare		0.00	0.00	0.00	0.00	0.00	0.00		
				Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00	

Operating Loads = Connected Loads X % Loading
Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor Bus Diversity Factors are applied to directly connected loads.
Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads
Diversity Factors: C: None, I: None, S: None

Bus ID: TX_substation

Voltage: 230.00 kV Rating: 0 A, 0 kVA

Connected Feeders & Loads	Description	Status	Nameplate Rating	Operating Load	Unit	Connected Loads			Operating Loads				
						kW	kvar	kVA	kW	kvar	kVA	% PF	% EFF
Transmission_Line		C				64000.00	48000.00	80000.00	64000.00	48000.00	80000.00	80.00	
		I				0.00	0.00	0.00	0.00	0.00	0.00	0.00	
		S				0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Bus Summary				Continuous		64000.00	48000.00	80000.00	64000.00	48000.00	80000.00		
				Intermittent		0.00	0.00	0.00	0.00	0.00	0.00		
				Spare		0.00	0.00	0.00	0.00	0.00	0.00		
				Bus Totals		64000.00	48000.00	80000.00	64000.00	47999.99	79999.99	80.00	

Operating Loads = Connected Loads X % Loading
Bus Total Operating Loads include Connected Loads X % Loading X Demand Factor X Diversity Factor Bus Diversity Factors are applied to directly connected loads.
Status: C=Continuous, I=Intermittent, S=Spare, NC=Non-Continuous Panel Loads
Diversity Factors: C: None, I: None, S: None