

EDIP/BÜS COMMUNICATION SHEET

	Yes	No
System time		
Internal clock (runs without power)		x
External clock (stopped without power)		x
Consume actual time automatically (after restart)		x
DIP-Switch for address settings		x
Transferable memory		
SIM-Card		x
SD-Card		x
ConfigClient	x	
ConfigProvider		x
Store values on power loss	x	
CANopen		
Heartbeat producer time	500ms	
Emergency messages	x	
Auto Boot-Up		x
LSS	x	
Dynamic mapping	x	
Save communication settings persistent	x	
SDO blockdownloaded		x

Baudrate	Busload in %	Maximum recommended number of device of this type in a network
1000 kbits/s	0,6	66
500 kbits/s	1,2	33
250 kbits/s	2,41	16
125 kbits/s	4,81	8

Process value			Format		Measurement specification		Communication parameter		
Name	Index	Sub	Data type	UNIT	Precision	Interval [ms]	PDO No	Event time [ms]	Inhibit time [ms]
Measure values - Output values - Transmit PDOs									
Valve Output	2500	1	UINT8	no unit	-	2	1	2000	100
Current	2501	1	REAL32	Ampere	-	2	2	5000	10
Namur Status	2502	1	UINT8	no unit	-	event driven	1	2000	100
Channel 1	2503	1	REAL32	adjustable	-	10	3	5000	100
Channel 1 Digital	2504	1	UINT8	no unit	-	10	3	5000	100
Channel 2	2505	1	REAL32	adjustable	-	10	4	5000	100
Channel 2 Digital	2506	1	UINT8	no unit	-	10	4	5000	100

Process value			Format		Measurement specification		Communication parameter		
Name	Index	Sub	Data type	UNIT	Precision	Interval [ms]	PDO No	Event time [ms]	Inhibit time [ms]
Control values - Input values - Receive PDOs									
Valve Input Binary	2540	1	UINT8	no unit	-	-	1	-	-
Valve Input Float	2541	1	REAL32	adjustable	-	-	2	-	-
Reset Time Controller	2542	1	UINT8	no unit	-	-	3	-	-