

(P2)

Martin Continued

- * Dust = Conductive.?
 - * Assess risk of.
-

N2 UG of 12, 3, Gloria

N3 UG m/Sub: — Seal foam
Gloria deface

Jonathan Thermal & Flow Tests / Survey

- 784 main N.
 - NCH3 Decline OH Lines = High Rn
 - Y85 - Main Sub. HOT SPOTS
-

FLOW & PRESSURE

Demarcation for hydrant
— hose boxes

— N13. Pump Jags.

. Pressure + Flow.

1200 @ 300 kPa

passed.

— N12 ✓

meet req^s 3x hydr.

— SOT ✓

Meet req^s 2x

— Gloria ✓

pass 1.
fail @ 2.