



GENERAL NOTES:-

1. ALL PIPE SIZES ARE IN NB (mm).
2. 25NB HIGH POINT VENT & LOW POINT DRAIN TO BE PROVIDED FOR ALL UTILITY/PROCESS PIPING AS REQUIRED
3. EARTHING CONTINUITY SHALL BE MADE FOR ALL SOLVENT PIPING.
4. FOR STANDARD SYMBOLS & LEGEND REFER TO DRAWING NO C2C-21160-PIA-001.
5. ALL REACTOR TEMPERATURE INDICATOR DUAL COMPARTMENT SHALL BE CONSIDERED FOR MASS & VAPOUR TEMPERATURE.

NOTES:-

1. WASH WATER SHALL BE PUMPED TO HTDS TANK THROUGH PORTABLE AODD PUMP.

HOLDS:-

[illegible]

CLIENT:



M/s. ANJAN DRUGS PVT LTD.

Plot No.85 to 88,105,106,115 & 116,
SIPCOT Industrial Estate,
EPIP Park,Gummidipoondi,
Tamil Nadu-601201.



C2C Engineering Pvt. Ltd.

Plot No.30 & 31, Sri Padmavathy Nagar Extn.,
Manapakkam Main Road, Kolapakkam,
Chennai - 600 128.
Website : www.c2cengineering.co.in

PROJECT : ANJAN DRUGS-BLOCK 5 & BLOCK 6

TITLE : P&ID FOR AHU FILTER CLEANING & WASH ROOM FOR VALPORIC ACID

PROJECT No : 21160		DWG No : C2C-21160-PIA-119	
SIZE A1	SCALE NTS	SHEET 1 OF 1	REV 6

This drawing & the design it covers are the property of **C2C Engineering Pvt Ltd**. They are merely loaned and on the borrower's expressed agreement that they neither will be reproduced, copied, loaned, exhibited nor used except in the limited way and private use permitted by any written consent given by the lender to the borrower.