Nivaasa community documents

Water Tank Cleaning Certificate

Service details

Vendor: AquaPure Services. Date of cleaning: 12 August 2026. Tanks covered: overhead tanks for Towers A, B and C, plus the underground sump. Method: drain, pressure clean, chlorination and refill.

Quality checks

Residual chlorine after refill: 0.5 mg/L. pH: 7.2. TDS: 312 mg/L. Visual inspection: clear, no sediment. Samples retained for 48 hours.

Certification

We certify that the cleaning was carried out in accordance with the society’s water safety protocol and that the tanks were returned to service only after satisfactory quality checks.