

# इंडियनऑयल कॉर्पोरेशन लिमिटेड IndianOil Corporation Ltd.

ग्राम : करसुआ, खैर रोड, पो.ओ. : लोधा, अलीगढ़-202140 (उ.प्र.)  
Vill-Karsua, Khair Road, P.O. Lodha, Aligarh - 202140 (U.P.)  
Ph. : 05724-286358, Fax : 05724-286450



विपणन प्रभाग  
(Marketing Division)

Dated : 06.09.2017

Amritasa Green Pvt. Ltd. Make Battery life Enhancer was installed by Elixir Engineers and Consultant at Indian Oil Bottling Plant at Aligarh in a battery Bank, individual battery of Fire Engines and PMCC. The total 43 batteries were installed on 06.07.2017. The Battery back up before installation of Enhancer was one hour fifteen minutes. After 2 months of installation the battery back have been improved from one hour fifteen minutes to four hours 30 minutes. The performance is satisfactory.

  
Chief Plant Manager  
Aligarh BP  
  
6.9.17

सौरभ तिवारी  
सहायक प्रबन्धक (एम्बीबी जी लेसी )  
इण्डियन ऑयल बॉटलिंग प्लान्ट अलीगढ़  
इंडियन ऑयल कॉर्पोरेशन लिमिटेड  
ग्राम-करसुआ, गोआग्जा, अलीगढ़(उत्तरप्रदेश)



VOLTAGE	STATUS	SAE	SOH	SOC
13.36	12.320	R4R G/P	2.16	2.80
13.35	13.320	R4R G/P	2.11	2.01
13.35	13.292	R4R G/P	2.16	2.03
13.35	13.288	R4R G/P	2.10	2.08
13.30	13.28	R4R G/P	2.11	2.08
13.30	13.416	R4R G/P	2.11	2.08
13.23	13.247	R4R G/P	2.06	2.75
13.52	13.40	R4R G/P	2.01	2.50
13.38	13.355	R4R G/P	1.80	2.17
13.37	13.40	R4R G/P	2.03	2.49
13.30	13.33	R4R G/P	1.50	2.16
13.40	13.31	R4R D/R	1.70	1.93
13.40	13.42	R4R G/P	1.90	2.23
13.40	13.39	R4R G/P	2.20	2.27
13.38	13.393	R4R G/P	2.33	2.54
13.38	13.35	R4R G/P	2.51	2.45
13.33	13.32	R4R G/P	2.10	2.55
13.30	13.24	R4R G/P	2.09	2.45
13.37	13.32	R4R G/P	2.09	2.56
52				
53				
54				
55				
56				
57				
58				
59				
60				
61				
62				
63				
64				

Roofdeck

26/11/11

Total No of Enhance fitted at roof site is 45

for ONGC  
(Authorised Signatory)

2/2