



छत्तीसगढ़ राज्य अक्षय ऊर्जा विकास अभिकरण(क्रेडा)

प्रधान कार्यालय, रायपुर

वी.आई.पी.रोड, ऊर्जा पार्क के समीप फुण्डहर, रायपुर (छ.ग.)

फोन नं. 8370008692, 8370008699 ई-मेल creda.om@gmail.com

Date:-12.09.16

Test Report

SMF 12V, 150 Ah Battery was indischarged Condition

Time:-01:12 P.M. Reading Titme

Battery E Volt-11.93

SAE -282

SAE (Society of automobile Engineers)

SOH -40%

SOH (State of Health)

SOC -16%

SOC (State of Charge)

Time :-2:47 P.M. Reading Time

Battery E Volt-12.52

After Charging for 1 hours 30 Min. with Enhancer (Battery Life Enhancer) the result area as under.

SAE -318

SAE

SOH -64%

SOH

SOC -82%

SOC

Above test result were measured by a battery analyger.

Dinesh Awasthi
12/09/16

(Dinesh Awasthi)
Superintending Engineer