

System Overview Report

Project	ALDEE\Sales7.jwm 90:Raj Water				
Case	1 New Case				
Revision	0 New Revision				
Feed Water Type	Brackish Well, Note: Auto Balance is ON				
Errors, Warnings, Cautions and Notices	Errors:0, Warnings	s:0,Cautions:0,Notices:0. See Important Notes at end /E			
Database Info :	,	Project Database : C:\Users\sales7.jwm\Documents\TorayDS2\App_Data\DS2.sdf(Ver:2.6) Membrane Database (V.20154) :.			

				Overall		Pass 1		
Raw water TDS		mg/l				270.9		
Feed EC @25C / @25.00C		uS		528.8 / 528.8			528.8 / 528.8	
Feed Pressure		bar		0.0			9.908	
Temperature		deg C		25.00				
Total DP		bar		1.364			1.364	
Brine Pressure		bar		8.543			8.543	
FLow Allowance		3.00 yrs					0.848	
SP % Increase (Max)		3.00 yrs					33.10%	
Recovery		%		70.00%			70.0%	
Feed Flow		m3/hr		14.286			14.286	
Product Flow		m3/hr		10.000			10.000	
Average Flux		l/m2/hr		26.81			26.81	
Concentrate Flow		m3/hr		4.286			4.286	
Product TDS		mg/l		2.551			2.551	
Concentrate TDS		mg/l		902.2			902.2	
Primary HP Pump kW		kilowatt		4.912			4.912	
Power Consumption		kWh/m^3		0.491			0.491	
lons			Feed		Net Feed	Cond		Product
Ca	mg/l		20.00		20.00	66.57		0.0416
Mg	mg/l		5.100		5.100	16.97		0.0106
Na	mg/l		66.56		66.56	221.1		0.330
K	mg/l		0.0		0.0	0.0		0.0
Ва	mg/l		0.0		0.0	0.0		0.0
Sr	mg/l		0.0		0.0	0.0		0.0
NH4	mg/l		0.0		0.0	0.0		0.0
Fe	mg/l		0.0		0.0	0.0		0.0
HCO3	mg/l		12.700		12.700	44.34		1.422
CI	mg/l		125.0		125.0	415.6)	0.428
SO4	mg/l		0.0		0.0	0.0		0.0
NO3	mg/l		35.90		35.90	119.0)	0.264
F	mg/l		0.0		0.0	0.0		0.0
Br	mg/l		0.0		0.0	0.0		0.0
B(Boron)	mg/l		0.0		0.0	0.0		0.0
SiO2	mg/l		5.600		5.600	18.53	34	0.0562
PO4	mg/l		0.0		0.0	0.0		0.0
CO3	mg/l		0.0003		0.0003	0.003		2.70E-06
CO2	mg/l		59.56		59.56	58.61		59.31
TDS	mg/l	270.9			270.9	902.2		2.551
Feed EC @25C / @25.00C	uS	529 / 529			529 / 529		0 / 1,679	12.4 / 12.4
рН	pН	5.520			5.520	6.045		4.611
Osmotic Press (DS1 / Pitzer)	bar		0.197 / 0.21		0.197 / 0.21		0 / 0.61	0.001 / 0.03
LSI / SDSI			-3.48 / -3.48		-3.48 / -3.48		/ -1.94	-9.40 / -10.37
CaSO4 / SrSO4 %	%		0.0% / 0.0%		0.0% / 0.0%		/ 0.0%	0.0% / 0.0%
BaSO4 / SiO2 %	%		0.0% / 4.6%	6	0.0% / 4.6%		/ 16.2%	
Pitzer % Solubility	Calcite/Dolom		0% / 0%		0% / 0%	1% /		
Pitzer % Solubility	CaSO4/SrSO4	1	0% / 0%		0% / 0%	0% /	0%	

Stage/Bank Data	Pass1	Stage 1	Stage 2
Lead Element Type		TM720D-400	TM720D-400
Last Element Type		TM720D-400	TM720D-400

Total Elements	10	5	5
Total Vessels	2	1	1
Elements per Vessel		5	5
Feed Flow	m3/hr	14.286	9.030
Product Flow	m3/hr	5.256	4.744
Average Flux	l/m2/hr	28.18	25.44
Brine Flow	m3/hr	9.030	4.286
Recovery %	%	36.79 %	52.54 %
Feed Pressure	bar	9.908	8.967
dP Elements	bar	0.941	0.424
Boost Pressure	bar	0.0	0.0
Piping Loss	bar	0.0	0.0
Net (Boost - dP piping)	bar	0.0	0.0
Brine Pressure	bar	8.967	8.543
Permeate Pressure	bar	0.0	0.0
Feed TDS	mg/l	270.9	428.4
Perm TDS	mg/l	2.179	2.964
Lead Element	Pass1	Stage 1	Stage 2
Feed Flow	m3/hr	14.286	9.030
Product Flow	m3/hr	1.101	0.986
Product TDS	mg/l	2.003	2.542
Flux	l/m2/hr	29.51	26.44
Last Element	Pass1	Stage 1	Stage 2
Product Flow	m3/hr	1.006	0.909
Product TDS	mg/l	2.395	3.576
Brine/Product Ratio	ratio	8.978	4.714
Brine Flow	m3/hr	9.030	4.286
Net Driving Pressure	bar	8.695	7.844
Beta		1.165	1.231

Chemicals 100%. Disclaimer: These estimated dose rates are provided as a courtesy to Toray DS2 users and are not guaranteed.

No Chemicals Added

Errors

Warnings

Cautions

Notices

Disclaimer: The program is intended to be used by persons having technical skill, at their own discretion and risk. The projections, obtained with the program, are the expected system performance, based on the average, nominal element-performance and are not automatically guaranteed. Toray shall not be liable for any error or miscalculation in the program. The obtained results cannot be used to raise any claim for liability or warranty. It is the users responsibility to make provisions against fouling, scaling and chemical attacks, to account for piping and valve pressure losses, feed pump suction pressure and permeate backpressure. For questions please contact us:

Toray Industries, Inc., Water Treatment Division, RO Membrane Products Dept. 1-1, Nihonbashi-muromachi 2-chome, Chuo-ku, Tokyo 103-8666, Japan TEL +81-3-3245-4540 FAX +81-3-3245-4913

Toray Membrane USA, Inc. 13435 Danielson St., Poway, CA, 92064, USA TEL +1-858-218-2390 FAX +1-858-486-3063

Toray Membrane Europe AG Grabenackerstrasse 8 P.O. Box 832 CH-4142 Munchenstein 1, Switzerland TEL +41-61-415-8710 FAX +41-61-415-8720

Toray Asia Pte. Ltd. / TEL +65-6226-0525 FAX +65-6226-0509

111 Somerset Road, #14-01, Singapore 238164


Toray Bluestar Membrane Co., Ltd. /Tel +86-10-80485216 Fax +86-10-80485217 Zone B, Tianzhu Airport Industrial Zone, Beijing 101318, China

http://www.toraywater.com/

Date/Time :	23-05-2019 12:32:29
Project	ALDEE\Sales7.jwm 90:Raj Water
Case:	1:New Case
Revision :	0:New Revision
User name :	ALDEE\Sales7.jwm
Prepared for :	
Notes :	10m3 /hr

Membrane Database				
Version Number:	20154			
ReleaseDate:	09-04-2019			
UpdateBy:	YK			
Toray DS2 version :	2.1.7.166(1.0.6.109)			

Flow Diagram:



Stream Details					
Stream Number	Flow	Pressure	TDS	Est uS	рН
20. Final Product	10.000	0.0	2.551	12.4	4.611
4. Feed Net	14.286	0.0	270.9	528.8	5.520
10. Feed to Pass 1	14.286	9.908	270.9	528.8	5.520
30. Conc to brine	4.286	8.543	902.2	1,679.1	6.045
Flement Details in Pass 1	·				

Pass 1 Stage 1	Element 1	Element 2	Element 3	Element 4	Element 5
Model	TM720D-400	TM720D-400	TM720D-400	TM720D-400	TM720D-400
Area m^2 / dia inch	37.30 / 8	37.30 / 8	37.30 / 8	37.30 / 8	37.30 / 8
Age	3	3	3	3	3
SPI %/yr	10	10	10	10	10
SPI Applied	33.10	33.10	33.10	33.10	33.10
FLow Allowance	0.848	0.848	0.848	0.848	0.848
Recovery %	7.706	8.144	8.662	9.280	10.022
Feed Flow(m3/hr)	14.286	13.185	12.111	11.062	10.035
Perm Flow(m3/hr)	1.101	1.074	1.049	1.027	1.006
Conc Flow(m3/hr)	13.185	12.111	11.062	10.035	9.030
Flux(I/m2/hr)	29.51	28.79	28.13	27.52	26.96
Beta	1.145	1.149	1.153	1.159	1.165
Feed Press(bar)	9.908	9.669	9.458	9.271	9.108
DP(bar)	0.238	0.212	0.187	0.163	0.141
Conc Press(bar)	9.670	9.458	9.271	9.108	8.967
Perm Press(bar)	0.0	0.0	0.0	0.0	0.0
Pi_Feed(bar)	0.197	0.213	0.232	0.254	0.280
Pi_Memb(bar)	0.234	0.255	0.280	0.308	0.343
Pi_Conc(bar)	0.213	0.232	0.254	0.280	0.310
Pi_Perm(bar)	0.001	0.0011	0.0011	0.0012	0.0013
Net Press(bar)	9.555	9.309	9.086	8.882	8.695

Element 3

0.0283

Element 4

0.0319

Element 2

0.0253

Element 1

0.0228

Perm mg/l Pass 1 Stage 1

Ca

Element 5

0.0361

Mg	0.0058	0.0065	0.0072	0.0081	0.0092
Na	0.181	0.201	0.225	0.253	0.286
K	0.0	0.0	0.0	0.0	0.0
Ва	0.0	0.0	0.0	0.0	0.0
Sr	0.0	0.0	0.0	0.0	0.0
NH4	0.0	0.0	0.0	0.0	0.0
Fe	0.0	0.0	0.0	0.0	0.0
HCO3	1.384	1.391	1.398	1.407	1.414
Cl	0.235	0.261	0.292	0.328	0.372
SO4	0.0	0.0	0.0	0.0	0.0
NO3	0.145	0.161	0.180	0.203	0.230
F	0.0	0.0	0.0	0.0	0.0
Br	0.0	0.0	0.0	0.0	0.0
В	0.0	0.0	0.0	0.0	0.0
SiO2	0.0301	0.0334	0.0372	0.0418	0.0472
PO4	0.0	0.0	0.0	0.0	0.0
CO3	2.53E-06	2.56E-06	2.59E-06	2.63E-06	2.66E-06
CO2	59.56	59.53	59.49	59.50	59.45
рН	4.598	4.600	4.603	4.605	4.608
TDS	2.003	2.080	2.168	2.272	2.395
Feed mg/l Pass 1 Stage 1	Element 1	Element 2	Element 3	Element 4	Element 5
Ca	20.00	21.67	23.59	25.82	28.46

Feed mg/l Pass 1 Stage 1	Element 1	Element 2	Element 3	Element 4	Element 5
Ca	20.00	21.67	23.59	25.82	28.46
Mg	5.100	5.525	6.015	6.584	7.257
Na	66.56	72.10	78.48	85.90	94.66
К	0.0	0.0	0.0	0.0	0.0
Ва	0.0	0.0	0.0	0.0	0.0
Sr	0.0	0.0	0.0	0.0	0.0
NH4	0.0	0.0	0.0	0.0	0.0
Fe	0.0	0.0	0.0	0.0	0.0
HCO3	12.700	13.797	15.076	16.492	18.241
CI	125.0	135.4	147.4	161.4	177.8
SO4	0.0	0.0	0.0	0.0	0.0
NO3	35.90	38.89	42.32	46.32	51.03
F	0.0	0.0	0.0	0.0	0.0
Br	0.0	0.0	0.0	0.0	0.0
В	0.0	0.0	0.0	0.0	0.0
SiO2	5.600	6.065	6.600	7.222	7.957
PO4	0.0	0.0	0.0	0.0	0.0
CO3	0.0003	0.0003	0.0003	0.0004	0.0005
CO2	59.56	59.53	59.49	59.50	59.45
pH	5.520	5.553	5.590	5.628	5.670
TDS	270.9	293.5	319.5	349.7	385.4

Pass 1 Stage 2	Element 1	Element 2	Element 3	Element 4	Element 5
Model	TM720D-400	TM720D-400	TM720D-400	TM720D-400	TM720D-400
Area m^2 / dia inch	37.30 / 8	37.30 / 8	37.30 / 8	37.30 / 8	37.30 / 8
Age	3	3	3	3	3
SPI %/yr	10	10	10	10	10
SPI Applied	33.10	33.10	33.10	33.10	33.10
FLow Allowance	0.848	0.848	0.848	0.848	0.848
Recovery %	10.923	12.033	13.422	15.192	17.502
Feed Flow(m3/hr)	9.030	8.043	7.076	6.126	5.195
Perm Flow(m3/hr)	0.986	0.968	0.950	0.931	0.909
Conc Flow(m3/hr)	8.043	7.076	6.126	5.195	4.286
Flux(I/m2/hr)	26.44	25.95	25.46	24.95	24.38
Beta	1.173	1.183	1.196	1.211	1.231
Feed Press(bar)	8.967	8.846	8.745	8.662	8.595
DP(bar)	0.120	0.101	0.0833	0.0668	0.0518
Conc Press(bar)	8.846	8.745	8.662	8.595	8.543
Perm Press(bar)	0.0	0.0	0.0	0.0	0.0
Pi_Feed(bar)	0.310	0.348	0.396	0.456	0.537
Pi_Memb(bar)	0.386	0.439	0.508	0.600	0.728

Pi_Conc(bar)	0.348	0.395	0.456	0.537	0.650
Pi_Perm(bar)	0.0014	0.0015	0.0017	0.0017	0.0021
Net Press(bar)	8.522	8.358	8.197	8.030	7.844
Perm mg/l Pass 1 Stage 2	Element 1	Element 2	Element 3	Element 4	Element 5
Ca	0.0413	0.0479	0.0564	0.0578	0.0773
Mg	0.0105	0.0122	0.0144	0.0147	0.0197
Na	0.328	0.379	0.447	0.458	0.612
(0.0	0.0	0.0	0.0	0.0
За	0.0	0.0	0.0	0.0	0.0
Sr .	0.0	0.0	0.0	0.0	0.0
NH4	0.0	0.0	0.0	0.0	0.0
e ·	0.0	0.0	0.0	0.0	0.0
HCO3	1.420	1.442	1.448	1.453	1.475
Cl	0.425	0.492	0.580	0.594	0.794
604	0.0	0.0	0.0	0.0	0.0
NO3	0.262	0.304	0.358	0.366	0.489
=	0.0	0.0	0.0	0.0	0.0
3r	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0
SiO2	0.0539	0.0623	0.0732	0.088	0.109
PO4	0.0	0.0	0.0	0.0	0.0
CO3	2.69E-06	2.78E-06	2.81E-06	2.84E-06	2.94E-06
CO2	59.35	59.22	59.07	58.96	58.77
ЭН	4.610	4.618	4.620	4.623	4.630
rds	2.542	2.740	2.976	3.032	3.576
Feed mg/l Pass 1 Stage 2	Element 1	Element 2	Element 3	Element 4	Element 5
Ca	31.62	35.50	40.35	46.59	54.93
Лg	8.064	9.052	10.288	11.881	14.007
Na	105.2	118.0	134.1	154.8	182.5
(0.0	0.0	0.0	0.0	0.0
Ва	0.0	0.0	0.0	0.0	0.0
Sr .	0.0	0.0	0.0	0.0	0.0
NH4	0.0	0.0	0.0	0.0	0.0
e	0.0	0.0	0.0	0.0	0.0
HCO3	20.40	23.08	26.43	30.67	36.41
	197.6	221.8	252.0	291.0	343.0
604	0.0	0.0	0.0	0.0	0.0
NO3	56.69	63.61	72.27	83.42	98.30
:	0.0	0.0	0.0	0.0	0.0
Br	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0
8:03	0.00	0.015	11.262	12.007	15 210

0.0

12.997

0.0015

58.96

5.890

631.4

0.0

11.262

0.0011

59.07

5.827

546.8

0.0

15.310

0.0022

58.77

5.962 744.5

SiO2

PO4

CO3

CO2

pH TDS

0.0

8.838

0.0006

59.35

5.718

428.4

0.0

9.915

0.0008

59.22

5.770

480.9