GSTIN: 24AAECR3013M1ZJ



Water Technology (Guj.) Pvt. Ltd

MUMBAI OFFICE:

116-D, Govt. Industrial Estate, Charkop, Kandiwali (West), Mumbai - 400067,

Maharashtra.

Cell: <u>+91 73595 95577</u> E-mail: <u>inquiry@rajwater.com</u>

info@rajwater.com

AHMEDABAD OFFICE: B/9, Sumel-7, Business Park,

Opp. Soni ni Chal, BRTS Bus Stop, N.H.-8 Ahmedabad - 382325.

Cell: <u>+91 70432 55777</u> E-mail: <u>inquiry@rajwater.com</u>

info@rajwater.com

HEAD OFFICE:

Plot No.: 27, Survey No. 47, Jivraj Industrial Area, Nr. Falcon Pump, Vavdi, Gondal Road, Rajkot - 360004.

Tel : <u>+91 281 - 2922777</u> Telefax : <u>+91 281 - 2922481</u>

Cell : <u>+91 74050 50444 / +91 70439 55777</u>

Website: www.rajwater.com

Email: inquiry@rajwater.com / info@rajwater.com

200-Ton Chiller Machine Specification

The chiller is controlled with the following salient features:

Temperature sensing of chilled water in and out, evaporating and ambient temperature.

Pressure transducer based low and high pressure alarms.

Compressor : Screw Compressor

Expansion Valve : Thermostatic Expansion valve used which is interlocked with

The PID based temperature controller

Capacity Control: Fully Automatic, Seamless from 25% to 100% Electronic

thermistor Based, with heat sensor

Motor Protection : Embedded in The Stator coil.

Revers Rotation: In-built in to the chiller

Protection

Oil Laval Protection : In-built in to the compressor

Compressor On/Off : At on Load

TECHNICAL SPECIFICATIONS (200.00 TR, WATER COOLED SCREW CHILLER)

A) CHILLER

Sr. No	Item	Description
1	SYSTEM	INDUSTRIAL WATER CHILLER
2	MODEL	FC/200WC
3	FLOW RATE	120.35 m3 / hr.
4	INLET TEMPERATURE TO CHILLER	3* C
5	OUTLET TEMPERATURE FROM CHILLER	-5* C.
6	REFIGERATION LOAD	200 TON
7	CHILLER TYPE	SHELL 'N' TUBE
8	CONDENSOR TYPE	WATER COOLED Type
9	CONTROL	FULLY AUTOMATIC
10	SAFETY INTERLOCKS	L.P. SWITCH & GAUGE H.P. SWITCH & GAUGE DIGITAL TEMPERATURE CONTROLLER WATER FLOW FAILURE TRIP COMPRESSOR OVERLOAD TRIP VOLTAGE SCANNER WITH UV/ OV / SPP / RP OIL FAILURE SWITCH

II Shree Umiya Matay Namah II



Water Technology (Guj.) Pvt. Ltd

GSTIN: 24AAECR3013M1ZJ

MUMBAI OFFICE: 116-D, Govt. Industrial Estate, Charkop, Kandiwali (West), Mumbai - 400067.

Maharashtra.

Cell : <u>+91 73595 95577</u> E-mail : <u>inquiry@rajwater.com</u>

info@rajwater.com

AHMEDABAD OFFICE: B/9, Sumel-7, Business Park,

Opp. Soni ni Chal, BRTS Bus Stop, N.H.-8 Ahmedabad - 382325. Cell : +91 70432 55777

E-mail: <u>hguiry@rajwater.com</u>

info@rajwater.com

HEAD OFFICE:

Plot No.: 27, Survey No. 47, Jivraj Industrial Area, Nr. Falcon Pump, Vavdi, Gondal Road, Rajkot - 360004.

Tel : <u>+91 281 - 2922777</u> Telefax : +91 281 - 2922481

Cell : +91 74050 50444 / +91 70439 55777

Website: www.rajwater.com

Email: inquiry@rajwater.com / info@rajwater.com

B) COMPRESSOR

1. MAKE : BITZER / REFCOMP

2. NO. OF COMPRESSOR : 2 Nos.3. TYPE : SCREW

4. POWER INPUT : 95.65 Kw / each Compressor

C) ELECTRICAL SPECIFICATION

1. POWER SUPPLY : 400 V +/- 10% / 3 PH. / 50 Hz +/- 5 %

2. CONNECTED LOAD CAPACITY : 230.32 kW.

D) **GENERAL CONDITION**

1. DESIGN TEMPERATURE : 48 DEG. C. AMBIENT

2. NOISE LEVEL : LESS THAN 85 dB at 1.0 MTR DISTANCE

3. CONDENSER FAN CONTROL : N. A.
4. CONDENSER FAN TYPE : N. A.
5. REFIGERANT REQUIRED : R – 407

1. MAKE OF ITEMS: WATER CHILLER

SR. NO.	ITEM	MAKE
1.	COMPRESSOR	BITZER / REFCOMP
2.	CONDENSOR	Self
3.	CHILLER	Self
4.	BASE FRAME	Self
5.	EXPANSION VALVE	EMERSON / SPORLANE
6.	LP / HP SWITCH	DANFOSS
7.	OIL LEVEL SWITCH	N. A.
8.	CONTROL PANEL	LANDMARK
9.	ELECTRICALS	L & T / SCHENIDER
10.	VALVE	IMPORTED
11.	ISOLATION VALVES	IMPORTED
12.	FILTER / DRIER	DANFOSS (DENMARK)
13.	VOLTAGE SCANNER	MINILEC / L & T
14.	MICRO PROCESSOR	SUBZERO
15.	COOLING TOWER	VIRAT FIBRE
16.	EXHAUST FAN	N. A.