

Priedas 1 – Rezultatų lentelė pagal FNA metodikos apibrėžimus

System needs – RES integration results tables

lentelė 1 System needs - RES integration [ERAA]

Type	Flexibility needs	Indicator	Subindicator	Unit	Value	Target year	Scenario
System needs	RES integration (as per FNA Methodology, Article 8)	RES integration target	-	%	5	2028, 2030,2033,2035	ERAA
System needs	RES integration (as per FNA Methodology, Article 8)	RES generation curtailment	RES generation curtailment	GWh	346,5	2028	ERAA
System needs	RES integration (as per FNA Methodology, Article 8)		RES generation curtailment	GWh	21,6	2030	ERAA
System needs	RES integration (as per FNA Methodology, Article 8)		RES generation curtailment	GWh	143,6	2033	ERAA

System needs	RES integration (as per FNA Methodology, Article 8)		RES generation curtailment	GWh	1277,0	2035	ERAA
---------------------	--	--	-------------------------------	-----	--------	------	------

lentelė 2 System needs - RES integration [LTrSc]

Type	Flexibility needs	Indicator	Subindicator	Unit	Value	Target year	Scenario
System needs	RES integration (as per FNA Methodology, Article 8)	RES integration target	-	%	5	2028, 2030,2033,2035	LTrSc
System needs	RES integration (as per FNA Methodology, Article 8)	RES generation curtailment	RES generation curtailment	GWh	71,1	2028	LTrSc
System needs	RES integration (as per FNA Methodology, Article 8)		RES generation curtailment	GWh	30,6	2030	LTrSc
System needs	RES integration (as per FNA Methodology, Article 8)		RES generation curtailment	GWh	55,7	2033	LTrSc

System needs	RES integration (as per FNA Methodology, Article 8)		RES generation curtailment	GWh	379,2	2035	LTrSc
---------------------	--	--	-------------------------------	-----	-------	------	-------

System needs – ramping needs results table

lentelė 3 System needs - ramping needs [ERAA]

Type	Flexibility needs	Indicator	Subindicator	Unit	Value	Target year	Scenario	Comments (i.e. up/downward, covered/uncovered, etc.)
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Average	MW	99,11	2028	Applicable to all	Upward
					101,57	2030		
					116,45	2033		
					135,78	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Maximum	MW	1750,23	2028		
					1827,50	2030		
					1810,12	2033		
					3983,81	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Minimum	MW	0	2028		
					0	2030		
					0	2033		
					0	2035		
System needs	Ramping needs			MW	483,21	2028		

	(as per FNA Methodology, Article 9)	Residual load ramping need	Relevant percentile of upward ramp [P95]		484,62	2030		
					553,86	2033		
					645,75	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Average	MW	99,99	2028		Downward
					101,42	2030		
					116,24	2033		
					135,76	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Maximum	MW	1833,87	2028		
					2004,39	2030		
					3110,01	2033		
					2380,94	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Minimum	MW	0	2028		
					0	2030		
					0	2033		
					0	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Relevant percentile of upward ramp [P95]	MW	445,83	2028		
					453,76	2030		
					514,58	2033		
					602,08	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Upward uncovered ramping needs - average	MW	125,0	2028	„Be jungčiq ir P2X”	
					119,4	2030		
					140,7	2033		
					158,0	2035		
System needs	Ramping needs	Upward uncovered ramping needs	Upward uncovered	MW	126,1	2028	„Be jungčiq”	
					121,0	2030		
					113,9	2033		

	(as per FNA Methodology, Article 9)		ramping needs - average		141,0	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Relevant percentile of uncovered upward need [P95]	MW	399,9	2028	„Be jungčią ir P2X”	
					356,3	2030		
					457,6	2033		
					541,0	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Relevant percentile of uncovered upward need [P95]	MW	440,2	2028	„Be jungčią“	
					360,1	2030		
					372,6	2033		
					474,5	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Equivalent total uncovered energy - upward	GWh	18,87	2028	„Be jungčią ir P2X”	
					14,68	2030		
					16,18	2033		
					16,12	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Equivalent total uncovered energy - upward	GWh	15,26	2028	„Be jungčią“	
					11,49	2030		
					5,35	2033		
					6,35	2035		

lentelė 4 System needs - ramping needs [LTrSc]

Type	Flexibility needs	Indicator	Subindicator	Unit	Value	Target year	Scenario	Comments (i.e. up/downward, covered/uncovered, etc.)
System needs	Ramping needs	Residual load ramping need	Average	MW	80,53	2028	Applicable to all	Upward
					91,14	2030		
					110,71	2033		

	(as per FNA Methodology, Article 9)				119,01	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Maximum	MW	1329,23	2028		
					2380,79	2030		
					2428,00	2033		
					3311,48	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Minimum	MW	0	2028		
					0	2030		
					0	2033		
					0	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Relevant percentile of upward ramp [P95]	MW	384,97	2028		
					428,56	2030		
					528,17	2033		
					563,81	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Average	MW	80,43	2028		Downward
					91,01	2030		
					110,66	2033		
					118,92	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Maximum	MW	1409,32	2028		
					3562,58	2030		
					2674,90	2033		
					3380,95	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Minimum	MW	0	2028		
					0	2030		
					0	2033		
					0	2035		

System needs	Ramping needs (as per FNA Methodology, Article 9)	Residual load ramping need	Relevant percentile of upward ramp [P95]	MW	357,187	2028		
					398,27	2030		
					505,31	2033		
					545,29	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Upward uncovered ramping needs - average	MW	87,0	2028	„Be jungčią ir P2X”	
					125,4	2030		
					128,3	2033		
					126,6	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Upward uncovered ramping needs - average	MW	88,3	2028	„Be jungčią“	
					118,9	2030		
					112,0	2033		
					137,8	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Relevant percentile of uncovered upward need [P95]	MW	284,3	2028	„Be jungčią ir P2X”	
					291,0	2030		
					416,0	2033		
					413,1	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Relevant percentile of uncovered upward need [P95]	MW	282,0	2028	„Be jungčią“	
					279,1	2030		
					416,0	2033		
					480,1	2035		
System needs	Ramping needs (as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Equivalent total uncovered energy - upward	GWh	9,13	2028	„Be jungčią ir P2X”	
					14,42	2030		
					16,04	2033		
					6,46	2035		
System needs	Ramping needs			GWh	8,91	2028	„Be jungčią“	
					12,85	2030		

	(as per FNA Methodology, Article 9)	Upward uncovered ramping needs	Equivalent total uncovered energy - upward		9,52	2033		
					3,58	2035		

System needs – short-term needs results table

lentelė 5 System needs - short term needs

Type	Flexibility needs	Indicator	Subindicator	Timeframe	Unit	Value	Target year	Scenario	Comments (i.e. up/downward, covered/uncovered, etc.)
System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	546-869	2028	ERAA Bazinis ERAA Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	610-982	2030	ERAA Bazinis ERAA Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	755-1236	2033	ERAA Bazinis ERAA Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	892-1415	2035	ERAA Bazinis ERAA Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs	Downward residual load forecast errors	Relevant percentile of	Slow (1h – D-1) timeframe	MW	494-901	2028	ERAA Bazinis ERAA Realistinis	Downward residual load forecast errors

	(as per FNA Methodology, Article 10)		the forecast error (0,1)						(i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Downward residual load forecast errors	Relevant percentile of the forecast error (0,1)	Slow (1h – D-1) timeframe	MW	555-985	2030	ERAA Bazinis ERAA Realistinis	Downward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Downward residual load forecast errors	Relevant percentile of the forecast error (0,1)	Slow (1h – D-1) timeframe	MW	706-1227	2033	ERAA Bazinis ERAA Realistinis	Downward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Downward residual load forecast errors	Relevant percentile of the forecast error (0,1)	Slow (1h – D-1) timeframe	MW	832-1433	2035	ERAA Bazinis ERAA Realistinis	Downward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	467-751	2028	LTrSc Bazinis LTrSc Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	537-865	2030	LTrSc Bazinis LTrSc Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	620-1001	2033	LTrSc Bazinis LTrSc Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)

System needs	Short term needs (as per FNA Methodology, Article 10)	Upward residual load forecast errors	Relevant percentile of the forecast error (99,9)	Slow (1h – D-1) timeframe	MW	702-1139	2035	LTrSc Bazinis LTrSc Realistinis	Upward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Downward residual load forecast errors	Relevant percentile of the forecast error (0,1)	Slow (1h – D-1) timeframe	MW	415-754	2028	LTrSc Bazinis LTrSc Realistinis	Downward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Downward residual load forecast errors	Relevant percentile of the forecast error (0,1)	Slow (1h – D-1) timeframe	MW	474-856	2030	LTrSc Bazinis LTrSc Realistinis	Downward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Downward residual load forecast errors	Relevant percentile of the forecast error (0,1)	Slow (1h – D-1) timeframe	MW	550-990	2033	LTrSc Bazinis LTrSc Realistinis	Downward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Downward residual load forecast errors	Relevant percentile of the forecast error (0,1)	Slow (1h – D-1) timeframe	MW	631-1110	2035	LTrSc Bazinis LTrSc Realistinis	Downward residual load forecast errors (i.e. Short-term flexibility needs)
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	775,2	2028	ERAA Bazinis	
System needs	Short term needs	Uncovered short-term	Average capacity per	-	MWh	328,7	2030	ERAA Bazinis	

	(as per FNA Methodology, Article 10)	flexibility needs	uncovered short-term flexibility need event						
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	912,1	2033	ERAA Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	664,4	2035	ERAA Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	1166,8	2028	ERAA Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	2071,1	2030	ERAA Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	3180,0	2033	ERAA Realistinis	

System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	2558,1	2035	ERAA Realistinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	0	2028	LTrSc Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	0	2030	LTrSc Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	0	2033	LTrSc Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	0	2035	LTrSc Bazinis
System needs	Short term needs	Uncovered short-term flexibility needs	Average capacity per uncovered short-term	-	MWh	341,5	2028	LTrSc Realistinis

	(as per FNA Methodology, Article 10)		flexibility need event						
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	845,3	2030	LTrSc Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	925,5	2033	LTrSc Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Average capacity per uncovered short-term flexibility need event	-	MWh	776,3	2035	LTrSc Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event		Hours	108	2028	ERAA Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event		Hours	39	2030	ERAA Bazinis	

System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	54	2033	ERAA Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	18	2035	ERAA Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	1111	2028	ERAA Realistinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	1969	2030	ERAA Realistinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	2170	2033	ERAA Realistinis
System needs	Short term needs	Uncovered short-term flexibility needs	Number of hours with uncovered short-term	Hours	1550	2035	ERAA Realistinis

	(as per FNA Methodology, Article 10)		flexibility need event					
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	0	2028	LTrSc Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	0	2030	LTrSc Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	0	2033	LTrSc Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	0	2035	LTrSc Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	337	2028	LTrSc Realistinis	

System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	559	2030	LTrSc Realistinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	720	2033	LTrSc Realistinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Number of hours with uncovered short-term flexibility need event	Hours	659	2035	LTrSc Realistinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	20,9	2028	ERAA Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	4,9	2030	ERAA Bazinis
System needs	Short term needs	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-	GWh	17,3	2033	ERAA Bazinis

	(as per FNA Methodology, Article 10)		term flexibility needs events					
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	4,7	2035	ERAA Bazinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	40,64	2028	ERAA Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	55,79	2030	ERAA Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	180,46	2033	ERAA Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	80,74	2035	ERAA Realistinis	

System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	0	2028	LTrSc Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	0	2030	LTrSc Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	0	2033	LTrSc Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	0	2035	LTrSc Bazinis
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	40,64	2028	LTrSc Realistinis
System needs	Short term needs	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-	GWh	55,79	2030	LTrSc Realistinis

	(as per FNA Methodology, Article 10)		term flexibility needs events					
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	180,46	2033	LTrSc Realistinis	
System needs	Short term needs (as per FNA Methodology, Article 10)	Uncovered short-term flexibility needs	Total expected energy from uncovered upward short-term flexibility needs events	GWh	80,74	2035	LTrSc Realistinis	

Network needs – DSO and TSO network needs results table¹

lentelė 6 DSO needs NacSc

Line number	Direction of need	Target year	Time block	Spatial granularity	Voltage level of congestion or voltage issue	Type of value	Network flexibility needs	Share of downward flexibility needs pertaining to RES generation curtailment	Expected contractual means to access flexibility
-------------	-------------------	-------------	------------	---------------------	--	---------------	---------------------------	--	--

¹ This table suggests a consolidation of results. In the case of DSOs, please note that the section “DSO input data to the FNA process” (as per FNA Methodology, Annex 2 -Tables 15, 16, 17 and 18) defines the set of data and format that shall be provided by the DSO(s) to the designated body (pursuant to the provisions of FNA Methodology, Articles 3, 4, 6 and 11). Tables from Annex 2 of the FNA Methodology could also be reported in annexes in the FNA report.

1	Upward	2028	Annual	Bidding zone	110 kV	total energy over the year	13756 MWh	Data not available	Not available
2						summation of maximum power	29 MW	Data not available	Not available
3	Downward	2028	Annual	Bidding zone	110 kV	total energy over the year	69207 MWh	Data not available	Not available
4						summation of maximum power	343 MW	Data not available	Not available
5	Upward	2030	Annual	Bidding zone	110 kV	total energy over the year	22131 MWh	Data not available	Not available
6						summation of maximum power	41 MW	Data not available	Not available
7	Downward	2030	Annual	Bidding zone	110 kV	total energy over the year	76557 MWh	Data not available	Not available
8						summation of maximum power	410 MW	Data not available	Not available
9	Upward	2033	Annual	Bidding zone	110 kV	total energy over the year	44735 MWh	Data not available	Not available
10						summation of maximum power	77 MW	Data not available	Not available
11	Downward	2033	Annual	Bidding zone	110 kV	total energy over the year	76895 MWh	Data not available	Not available
12						summation of maximum power	455 MW	Data not available	Not available
13	Upward	2035	Annual	Bidding zone	110 kV	total energy over the year	69576 MWh	Data not available	Not available
14						summation of maximum power	108 MW	Data not available	Not available
15	Downward	2035	Annual	Bidding zone	110 kV	total energy over the year	73023 MWh	Data not available	Not available
16						summation of maximum power	458 MW	Data not available	Not available

lentelė 7 DSO needs LTrSc

Line number	Direction of need	Target year	Time block	Spatial granularity	Voltage level of congestion or voltage issue	Type of value	Network flexibility needs	Share of downward flexibility needs pertaining to RES generation curtailment	Expected contractual means to access flexibility
1	Upward	2028	Annual	Bidding zone	110 kV	total energy over the year	13756 MWh		
2						summation of maximum power	29 MW	Data not available	Not available
3	Downward	2028	Annual	Bidding zone	110 kV	total energy over the year	26975 MWh	Data not available	Not available
4						summation of maximum power	167 MW	Data not available	Not available
5	Upward	2030	Annual	Bidding zone	110 kV	total energy over the year	22131 MWh	Data not available	Not available
6						summation of maximum power	41 MW	Data not available	Not available
7	Downward	2030	Annual	Bidding zone	110 kV	total energy over the year	27340 MWh	Data not available	Not available
8						summation of maximum power	181 MW	Data not available	Not available
9	Upward	2033	Annual	Bidding zone	110 kV	total energy over the year	44735 MWh	Data not available	Not available
10						summation of maximum power	77 MW	Data not available	Not available
11	Downward	2033	Annual	Bidding zone	110 kV	total energy over the year	23758 MWh	Data not available	Not available
12						summation of maximum power	182 MW	Data not available	Not available
13	Upward	2035	Annual	Bidding zone	110 kV	total energy over the year	69576 MWh	Data not available	Not available
14						summation of maximum power	108 MW	Data not available	Not available

15	Downward	2035	Annual	Bidding zone	110 kV	total energy over the year	21339 MWh	Data not available	Not available
16						summation of maximum power	181 MW	Data not available	Not available