

#ReopenStrong: School Building Readiness Checklist

DC Public Schools (DCPS) is committed to a safe and successful return to in-person learning for our students and staff. DCPS' work to prepare for a strong reopening is grounded in prioritizing the health and safety of our entire school community. Using guidance from DC Health, the Office of the State Superintendent of Education (OSSE), Centers for Disease Control and Prevention (CDC), and union partners, we developed a set of building

readiness standards that meet public health requirements to mitigate the spread of COVID-19. This School Building Readiness Checklist is intended to ensure that DCPS facilities meet those stringent standards.
Each member of the walkthrough team shall be provided a copy of this checklist to individually complete during the walkthrough.
In order to safely reopen, a school building must have the following in place:
☐ 1. Personal Protective Equipment (PPE) & Hygiene Supplies
School has the necessary general and enhanced PPE and hygiene supplies to support the first two months of programming and has been oriented to the standardized inventory monitoring protocol established by central office for all schools to ensure timely supply replenishment. A review of the school's inventory indicates that the following items are onsite:
Adult face masks Face shields Child face masks Communicator masks, as applicable
Additionally, the following enhanced PPE supplies will be provided to staff whose roles increase the likelihood of being in closer or more frequent proximity to other staff and students:
Gloves Medical gowns
Regarding hygiene supplies, school has received: Toilet paper, soap, and disposable towels for student and staff bathrooms that do not have hand dryers Hand sanitizer for placement in the arrival space, hallways, classrooms, offices, and other shared spaces Disposable towels, hand sanitizer and disinfectant wipes available in all classrooms
Notes:

Final Draft
DCPS shall provide evidence that:
Direct Outside Air System (DOAS) with MERV-13 filters installed
OR High-Efficiency Particulate Air (HEPA) filters placed in the building
If school is served by a DOAS system:
☐ Is evidence available to show that MERV-13 filters have been timely installed and replaced in line with ASHRAE guidelines?
If school is using High-Efficiency Particulate Air (HEPA) filters:
Are they placed in appropriate locations in the building per the outcome of the evaluation?
Do they have the proper capacity for the size of the spaces in which they are placed?
Is evidence available that the filters are functional?
Notes:
☐ 7. Plumbing Systems
School has a prioritization process established with DCPS Strategic School Operations and Facilities teams, partnership with DGS, to address plumbing work orders related to bathrooms.
Bathrooms
Are all sinks operable in all bathrooms with running water? If no, has work order been submitted and operational plan been adjusted during the interir period to ensure continuity of operations? Are all toilets operable in all bathrooms? If no, has work order been submitted and operational plan been adjusted during the interir period to ensure continuity of operations?
Notes:

Form to Confirm Completion of Items on School Readiness Checklist

(to be completed at the end of the walkthrough)

school: Truesdell Elementary School

Walkthrough Date: 9/15/21

Name	Signature	Title (scac, lsat,	Comments
		Custodian, Nurse, etc.)	
Alphonso Blaker	MARV	MSL	
Eboni M. Han	Slinkly	Building rep	
Catelyn Bockn	Yatlln Bolk	3rd Grade Teacher	
Ben Vaughn	J. Bysel & A	Instructional Coach	
Jara Havok	CZ8	5th grade tedener	
JRACT HATCH	DiHater	Parent	