Coolant flow sensor calibration procedure

The FL-200 coolant flow sensor must be calibrated every 30 days. Calibration ensures accurate flow measurement across the operating range.

The maximum permissible deviation after calibration is listed below. Sensors exceeding the deviation limit must be replaced.

Sensor	Range (l/min)	Max deviation (%)
FL-200	5-50	0.5
FL-350	20-120	0.8