



Address the original alarm

Does this solve the problem?

1] Yes

2] No

3] I don't know

- [Explanation](#)

This warning will be active if an alarm has caused the turbine to be shut down for at least 6 hours. It will clear when the turbine is placed back into run.