

Check U03 power net and measure input voltage for 230VAC and output 24VDC, replace if output measures 0V

Does this solve the problem?

1] Yes

2] No

3] I don't know

- **Explanation**

Check the power supply output voltage and replace, if output voltage is not measuring 24VDC

Relevant spare parts	
Description	Item No.
PS ADC 5183R-4 5A – 27.4VDC	188451