

Check the current transformers in the AT1 cabinet

**Does this solve the problem?**

- 1] Yes
- 2] No
- 3] I don't know

- [Explanation](#)

That TAC computer uses three current transformers to read the current from each of the phases. If one of these CTs

Check the current reading while the turbine is in pause and consuming as little power as possible (no motors or heaters on). If there is a current imbalance at this point, confirm that it is not being caused by the grid or transformer and test the AT1:T01.

If the T01 is shorted or open, it should be replaced.

Relevant spare parts	
Description	Item No.
TRAFO CURRENT 2000/1A 25VA	<a href="#">60007164</a>

Check the AT1:R01 shunt resistor

**Does this solve the problem?**

- 1] Yes
- 2] No
- 3] I don't know

- [Explanation](#)

The current transformers have a shunt resistor to lower the current sent to the TAC.

With the current transformer disconnected, measure the resistance from AT1:R01:01 to AT1:R01:10. If it is not 2.5 ohms then the resistor may be bad.

Relevant spare parts	
Description	Item No.
RESISTOR SHUNT 3x2.5 OHM	<a href="#">51700501</a>

987 - Cut-in avg. current L1 - V82



Check the gen speed readings, replace sensor if bad

**Does this solve the problem?**

- 1] Yes
- 2] No
- 3] I don't know

- [Explanation](#)

Check the generator speed in the alarm snapshot and compare it to the rotor speed. If the generator speed sensor is defective, replace it. If the sensor works but is misaligned, realign it.

Relevant spare parts	
Description	Item No.
PROXI S 1A18DLF05PO Ø18	<a href="#">60009263</a>



Perform a generator test and report findings

**Does this solve the problem?**

1] Yes

2] No

3] I don't know

- [Explanation](#)

This alarm may indicate a generator is failing. Check the turbine log for other generator related alarms.

Perform a motor test and an insulation test on the generator. Use work instruction 959335 to insure the procedure is performed correctly.

Relevant documentation	
Description	DMS No.
Electrical measurements on generator	<a href="#">959335</a>

987 - Cut-in avg. current L1 - V82



Check the circuit for shorts and opens

**Does this solve the problem?**

1] Yes

2] No

3] I don't know

- [Explanation](#)

The signal from the current transformers must pass through six connections before it reaches the TAC computer. If any of these connections are loose or corroded, the signal could be altered and the current measurement would be unreliable.

Check the circuit with a multimeter and thoroughly inspect the Amphenol connections.

Relevant spare parts	
Description	Item No.
Amphenol Plug Service Kit	<a href="#">60025069</a>

987 - Cut-in avg. current L1 - V82



Inspect thyristor circuit, repair any damage

**Does this solve the problem?**

- 1] Yes
- 2] No
- 3] I don't know

- [Explanation](#)

If the alarm is occurring during start up, when the thyristors are active, it could indicate a problem with one of the thyristors or the TAC 40.

Relevant spare parts	
Description	Item No.
THYRISTOR MODULE	<a href="#">60001041</a>
TRIGGER BOARD TAC 40 690V	<a href="#">51700901</a>

987 - Cut-in avg. current L1 - V82



Replace the TAC

**Does this solve the problem?**

- 1] Yes
- 2] No
- 3] I don't know

- [Explanation](#)

If the TAC II is malfunctioning, it could raise this error by mistake.  
Check for voltage on terminal AT2:U2:P1.1, you should have about 19 volts  
If there is no voltage there, the TAC II should be replaced.

If you suspect the TAC II is bad for other reasons, always try to re-upload the software before you replace the TAC computer.

Relevant spare parts	
Description	Item No.
TAC II/F NEGM 1500c/71/82	<a href="#">51707301</a>