

Task 1

Using the diagrams given in the presentation calculate how much (%) is the effect of applying different modifications (changing the gas, adding an extra pane, using a low emissivity coating) on the U value with respect to a benchmark case of double layer with air and no coating ? (keep the gap thickness to be 13 mm)

From the diagram, when the thickness of the gap is 13, and by changing the gas to Argon from air, the u-value of glass reduces from 2.8 W/m²K to 2.65 W/m²K. The U value decreases by 6.43%

When the gas is changes to Krypton the U value reduces to 2.6 W/m²K, which is a 7.14% decreases

The U_{centre} , changes by adding an extra pane, from the diagram, by adding an extra pane, the U value decreases from 2.8 W/m²K to 1.8 W/m²K, which is a 55.6% reduction in U-Value.

By cooling the glass surfaces with the files of low emissivity, by observing the diagram, when the thickness of the air gap is 13 mm and coating the glass surface with a low emissivity film of 0.1, the U value of the centre of the glass decreases from 2.8 W/m²K to 1.8 W/m²K which is a 55.6% reduction in U value.

Task2

Consider the house that we analysed in the alst two examples, calculate the heating and cooling load of the other windows which are fixed 14.4 m² on the west, fixed 3.6 m² on the south and an operable 3.6 m² on the south (the same window and frame type). How much does the total value change if I change the frame of the window from wooden one to aluminium ?

$T_{\text{cooling}} = 24^{\circ}\text{C} \Rightarrow$ cooling design temperature

$T_{\text{heating}} = 20^{\circ}\text{C} \Rightarrow$ Heating design temperature

Therefore,

$$\Delta T_{\text{cooling}} = 31.9^{\circ}\text{C} - 24^{\circ}\text{C} = 7.9^{\circ}\text{C}$$

$$\Delta T_{\text{heating}} = 20^{\circ}\text{C} - (-4.8^{\circ}\text{C}) = 24.8^{\circ}\text{C}$$

From the table,

$$DR = 11.9^{\circ}\text{C}$$

$$q_{\text{West window}} = A \times CF_{\text{west window}}$$

$$A = 14.4\text{m}^2$$

$$CF_{\text{west window}} = U_{\text{west}} (\Delta T_{\text{cooling}} - 0.46 \text{ DR})$$

Therefore the window has a fixed heat absorbing double layer glass with a wooden frame

$$U_{\text{window}} = 2.84 \text{ W/m}^2\text{K}$$

$$\text{i.e. } CF_{\text{west window}} = 6.89 \text{ W/m}^2$$

$$P \times L_{\text{ww}} = E_D + E_d = 559 + 188 = 747$$

$$\text{SHGC} = 0.54$$

No internal shading so IAC = 1

$$FF_s = 0.56$$

$$CF_{\text{ww}}(\text{Irradiation}) = P \times I + \text{SHGC} + \text{AC} + FF_s$$

$$q_{\text{ww}} = A \times CF_{\text{ww}} = A \times (CF_{\text{ww}} (\text{Heat transfer}) + CF_{\text{ww}}(\text{Irradiation}))$$

$$= 14.4 \times (6.89 + 747 \times 0.5 \times 1 \times 0.8)$$

$$= 3.352.07 \text{ W}$$

Calculating the heat load of the fixed window on west,

$$q_{\text{window west}} = A \times HF_{\text{ww}} = A \times U_{\text{ww}} \Delta T_{\text{heating}}$$

$$= 14.4 \times 2.84 \times 24.8 = 1014.22 \text{ W}$$

When frame is aluminum

$$U_{\text{ww}} = 3.61, \text{ HSGC} = 0.56$$

$$CF_{\text{ww}}^1(\text{Heat transfer}) = U_{\text{ww}}^1 (\Delta T_{\text{cooling}} - 0.46 \text{ DR})$$

$$= 3.61 \times (7.9 - 0.46 \times 11.9)$$

$$= 8.76 \text{ W/m}^2$$

$$\text{Cooling load } q_{\text{ww}}^1 = A \times (CF_{\text{ww}}^1 (\text{heat transfer}) + CF_{\text{ww}}^1 (\text{Irradiation}))$$

$$= 3499.48 \text{ W}$$

$$\text{Heating load } q_{\text{ww}}^1 = A \times HF_{\text{ww}}^1 = A \times U_{\text{ww}}^1 \Delta T_{\text{heating}} = 14.4 \times 3.6 \times 24.8 = 1289.2 \text{ W}$$

Calculating the cooling load of the fixed window on south

$$q_{\text{sw}} = A \times HF_{\text{ws}} = A \times U_{\text{sw}} \Delta T_{\text{heating}}$$

$$= 3.6 \times 2.8 \times 24.8 = 256.56 \text{ W}$$

When the frame is aluminum, $U_{ws} = 3.6$, $HSU = 0.56$

$$CF_{sw}^{1st}(\text{Heat Transfer}) = U_{sw}(\Delta T_{cooling} - 0.46 \text{ DR}) = 3.61 \times (7.9 - 0.46 \times 11.9) = 8.76 \text{ W/m}^2$$

$$\text{Cooling load } q_{sw}^{1st} = A \times CF_{sw}^{1st} = 559.3 \text{ W}$$

$$\text{Heating load} = A \times HF_{sw}^{1st} = 322.3 \text{ W}$$

Calculating the cooling load on south window

$$q_{sw} = A \times CF_{sw}$$

$$CF_{sw}(\text{Heater transfer part}) = 6.96 \text{ W/m}^2$$

$$P \times I_{sw} = ED + Ed = 348 + 209 = 557$$

$$SHGC = 0.46$$

No internal shading w, $IAC = 1$

$$FFs = 0.47$$

$$CF_{sw}(\text{irradiation past}) = P \times I \times SHGC + IAC + FFs = 553.98$$

$$q_{sw} = 256.23$$

When frame is aluminum

$$U_{sw} = 4.62 \text{ W/m}^2\text{K}, \text{ HSGC} = 0.55$$

$$CF_{sw}^{1st}(\text{Heating transfer past}) = U_{sw}(\Delta T_{cooling} - 0.46 \text{ DR}) = 11.21 \text{ W/m}^2$$

$$\text{Cooling load } q_{sw}^{1st} = A \times CF_{sw}^{1st} = 558.7 \text{ W}$$

$$\text{Heating load } q_{sw} = A \times HF_{sw}^{1st} = 412.47 \text{ W}$$