



PROVIDING WORLD CLASS SERVICE
BACKFLOW PREVENTER ASSEMBLY TEST AND MAINTENANCE REPORT

DATE: 06/15/2026 BRANCH: _____ AUTHORITY HAVING JURISDICTION: Test

CUSTOMER / SITE NAME: Test

STREET ADDRESS: Test

LOCATION OF ASSEMBLY: _____

BACKFLOW INFORMATION	SERIAL NUMBER: _____	SIZE: _____
	MANUFACTURER: <u>Test</u>	☒ FIRE
	MODEL: _____	☐ DOMESTIC
	TYPE OF ASSEMBLY: ☒ RP ☐ DC	SYSTEM SERVICE: ☐ IRRIGATION
	☐ PVB ☐ SVB	☐ ATTRACTION
		BYPASS? YES ☐ NO ☒

	CHECK VALVE #1	RELIEF VALVE	CHECK VALVE #2	PVB or SVB
TESTING INFORMATION	☒ CLOSED TIGHT	☐ OPENED AT PSI	☒ CLOSED TIGHT	☐ CLOSED TIGHT
	☐ LEAKED	☐ DID NOT OPEN ☐ N/A	☐ LEAKED	☐ OPENED AT PSI
	☐ N/A	-----	☐ N/A	-----
	DIFFERENTIAL PRESSURE ACROSS CV1: PSI <u>2.0</u>	OUTLET SHUT-OFF VALVE: ☐ CLOSED ☐ LEAKED	OPTIONAL TEST DIFFERENTIAL PRESSURE ACROSS CV2: PSI <u>2.0</u>	CHECK VALVE ☐ LEAKED
		☐ CLOSED ☐ LEAKED		☐ HELD AT PSI

TEST DATE: 06/15/2026 THIS ASSEMBLY: ☒ PASSED ☐ FAILED

REPAIRS	DESCRIPTION OF REPAIRS (INCLUDING PART #)	☐ CHECK VALVE ASSEMBLY	☐ FLUSH & REMOVE DEBRIS
		☐ RELIEF VALVE ASSEMBLY	☐ CLEAN INTERNAL
		☐ AIR INLET VALVE ASSEMBLY	☐ OS&Y REPAIR ☐ RE-PACKING
		☐ RUBBER REPAIR KIT	☐ NEW BACKFLOW
PLEASE NOTE: ALL REPAIRS SHALL BE COMPLETED UPON CUSTOMER APPROVAL.			
REMARKS / REPAIRS NEEDED: <u>Test</u>			

TESTER	GAUGE MANUFACTURER <u>Test</u>	SERIAL #: <u>Test</u>	DATE CALIBRATED: <u>Test</u>
	TECHNICIAN <u>Wes Winkle</u>	CERTIFICATION NO. <u>Test</u>	RE-CERT DUE DATE <u>Test</u>