



PROVIDING WORLD CLASS SERVICE
BACKFLOW PREVENTER ASSEMBLY TEST AND MAINTENANCE REPORT

DATE: 06/14/2026 BRANCH: Test AUTHORITY HAVING JURISDICTION: Test

CUSTOMER / SITE NAME: Test

STREET ADDRESS: Test

LOCATION OF ASSEMBLY: Test

BACKFLOW INFORMATION	SERIAL NUMBER: <u>Test</u>	SIZE: <u>1.0</u>
	MANUFACTURER: <u>Test</u>	☒ FIRE
	MODEL: <u>Test</u>	☐ DOMESTIC
	TYPE OF ASSEMBLY: ☒ RP ☐ DC	SYSTEM SERVICE: ☐ IRRIGATION
	☐ PVB ☐ SVB	☐ ATTRACTION
		BYPASS? YES ☐ NO ☒

TESTING INFORMATION	CHECK VALVE #1	RELIEF VALVE	CHECK VALVE #2	PVB or SVB
	☒ CLOSED TIGHT ☐ LEAKED ☐ N/A DIFFERENTIAL PRESSURE ACROSS CV1: PSI <u>2.0</u>	☐ OPENED AT PSI ☐ DID NOT OPEN ☐ N/A ----- OUTLET SHUT-OFF VALVE: ☐ CLOSED ☐ LEAKED INLET SHUT-OFF VALVE: ☐ CLOSED ☐ LEAKED	☒ CLOSED TIGHT ☐ LEAKED ☐ N/A <u>OPTIONAL TEST</u> DIFFERENTIAL PRESSURE ACROSS CV2: PSI <u>2.0</u>	☐ CLOSED TIGHT ☐ OPENED AT PSI ----- ☐ LEAKED ☐ HELD AT PSI

TEST DATE: 06/14/2026 THIS ASSEMBLY: ☒ PASSED ☐ FAILED

REPAIRS	DESCRIPTION OF REPAIRS (INCLUDING PART #)	☐ CHECK VALVE ASSEMBLY	☐ FLUSH & REMOVE DEBRIS
		☐ RELIEF VALVE ASSEMBLY	☐ CLEAN INTERNAL
		☐ AIR INLET VALVE ASSEMBLY	☐ OS&Y REPAIR ☐ RE-PACKING
		☐ RUBBER REPAIR KIT	☐ NEW BACKFLOW
	PLEASE NOTE: ALL REPAIRS SHALL BE COMPLETED UPON CUSTOMER APPROVAL.		
REMARKS / REPAIRS NEEDED: <u>Test</u>			

TESTER	GAUGE MANUFACTURER <u>Test</u>	SERIAL #: <u>Test</u>	DATE CALIBRATED: <u>Test</u>
	TECHNICIAN <u>Wes Winkle</u>	CERTIFICATION NO. <u>Test</u>	RE-CERT DUE DATE <u>Test</u>