



PROVIDING WORLD CLASS SERVICE
BACKFLOW PREVENTER ASSEMBLY TEST AND MAINTENANCE REPORT

DATE: 06/13/2026 BRANCH: ORLANDO AUTHORITY HAVING JURISDICTION: _____

CUSTOMER / SITE NAME: Test1

STREET ADDRESS: 123 main st

LOCATION OF ASSEMBLY: Building 1

BACKFLOW INFORMATION	SERIAL NUMBER: <u>Test123</u>	SIZE: <u>2.0</u>
	MANUFACTURER: <u>Febco</u>	☒ FIRE
	MODEL: <u>8000</u>	☐ DOMESTIC
	TYPE OF ASSEMBLY: ☒ RP ☐ DC	SYSTEM SERVICE: ☐ IRRIGATION
	☐ PVB ☐ SVB	☐ ATTRACTION

	CHECK VALVE #1	RELIEF VALVE	CHECK VALVE #2	PVB or SVB
TESTING INFORMATION	☒ CLOSED TIGHT	☐ OPENED AT PSI	☒ CLOSED TIGHT	☐ CLOSED TIGHT
	☐ LEAKED	☐ DID NOT OPEN ☐ N/A	☐ LEAKED	☐ OPENED AT PSI
	☐ N/A	-----	☐ N/A	-----
	DIFFERENTIAL PRESSURE ACROSS CV1: PSI <u>2.0</u>	OUTLET SHUT-OFF VALVE: ☐ CLOSED ☐ LEAKED	OPTIONAL TEST	☐ LEAKED
		INLET SHUT-OFF VALVE: ☐ CLOSED ☐ LEAKED	DIFFERENTIAL PRESSURE ACROSS CV2: PSI <u>1.6</u>	CHECK VALVE
				☐ HELD AT PSI

TEST DATE: 06/13/2026 THIS ASSEMBLY: ☒ PASSED ☐ FAILED

REPAIRS	DESCRIPTION OF REPAIRS (INCLUDING PART #)	☐ CHECK VALVE ASSEMBLY	☐ FLUSH & REMOVE DEBRIS
		☐ RELIEF VALVE ASSEMBLY	☐ CLEAN INTERNAL
		☐ AIR INLET VALVE ASSEMBLY	☐ OS&Y REPAIR ☐ RE-PACKING
		☐ RUBBER REPAIR KIT	☐ NEW BACKFLOW
PLEASE NOTE: ALL REPAIRS SHALL BE COMPLETED UPON CUSTOMER APPROVAL.			
REMARKS / REPAIRS NEEDED:			

TESTER	GAUGE MANUFACTURER <u>Test</u>	SERIAL #: <u>Test</u>	DATE CALIBRATED: <u>Test</u>
	TECHNICIAN <u>Wes Winkle</u>	CERTIFICATION NO. <u>Test</u>	RE-CERT DUE DATE <u>Test</u>