

HealthOS™ Facility Operational Specifications

Document ID: HOS-SPEC-2026-V1 | Facility Type: Regional Medical Center

1. Facility Room & Layout Standards

This specification document outlines room operational guidelines, HVAC airflow requirements, and power specifications for primary medical care zones. All facility managers must ensure strict compliance with cleanroom ISO class 7 parameters in surgical areas.

2. Operational Room Parameters

Room ID	Zone Name	Target Temp (°C)	Air Exchanges/Hr	Backup Power
ICU-101	Intensive Care Unit	21.5°C	12 exchanges	UPS + Generator
OR-202	Surgical Operating Room	19.0°C	20 exchanges	Dual UPS Isolated
LAB-305	Diagnostic Pathology Lab	22.0°C	8 exchanges	Standard Generator
RAD-401	Radiology MRI Suite	18.5°C	15 exchanges	Dedicated Line

3. Emergency Protocol & Maintenance Schedule

Emergency oxygen shut-off valves are positioned adjacent to primary nurse station consoles on levels 1 through 4. Comprehensive HVAC filter inspections and HEPA filter replacements must occur bi-monthly (every 60 days).