

Universidade Federal de Minas Gerais
Escola de Engenharia
Curso de Graduação em Engenharia de Controle e Automação



EHDA closed loop control system based on real time non-visual spray mode classification

Relatório de Atividades 3
Projeto Final de Curso

Orientador: Vitor Angelo
Supervisor: Luewton L F Agostinho
Aluno: João Pedro Miranda Marques
Matricula: 2017050495

March 3, 2023

1 Summary

Electrohydrodynamic Atomization (EHDA), also known as Electrospray (ES), is a way to disintegrate a liquid into droplets by exposing it to a strong electric field. EHDA surveys have contributed as an important tool for the development of water technology (thermal desalination and metal recovery), material sciences (nanofibers and nano spheres fabrication, metal recovery, selective membranes, and batteries), and biomedical application (droplet encapsulation). Besides that, the project is merged with the Energy Transition strategy and Innovation Agenda Agriculture, Water, and Food, Key Enabling Technologies (KETs). Although, there are EHDA applications in industry, stabilizing the cone-jet spray mode is done empirically and based on mean current measurements.

The electric current flowing transported by the spray reveals characteristic shapes for different spray modes. Those shapes cannot simply be summarized by its mean value. In figure one we can see an example of cone-jet mode electrospray.




Figure 1: EHDA

Signal processing techniques can allow a non-visual classification of the spray mode based on the electric current shape. The spray process imposes noise and random sequences on the measured signal making its classification not a trivial task.

Industrial applications demand automated stabilization of a spray mode. This can be achieved by a closed-loop control system. Figure 2 shows the control model implemented in this project.




Figure 2: Control model implemented in software

The setup used for this project can be seen in the Figure 3 and 4. To run the experiment automatically it is used a computational processing machine to integrate the peripherals and run their routines, system sensors such as the oscilloscope and the high speed camera and also the system actuators which is represented by the high voltage power supply and the syringe pump.




Figure 3: System Diagram




Figure 4: System Automation Diagram

Automated classification of the spray mode is a crucial part of a control system same as the development of an appropriate control algorithm. Signal processing implementations of previous projects of the NHL Stenden Water Technology group are showing good classification results. Further research is necessary to improve the classification accuracy and research and implementation of a suitable classification algorithm. Because of that, this work is being done by the Water Technology Group at NHL Stenden University of Applied Sciences and in combination with Dutch companies to match analysis possibilities with knowledge and infrastructure availability.

2 Metodology and Results

The following subsections are about the work done in this 3rd part of the project.

2.1 Pump Integration

The pump integration in the automation algorithm bring us a new controllable variable, the Flowrate. Now we can control the spraying mode with the two main variables that affect the system. It will bring more complexity for the system since now we are dealing with multivariable control. Controlling also the flowrate gives to this project a new dimension in the system giving us freedom to explore the flowrate properties. Our control model is now a MISO¹ system. The crossover (couple) between the controlled variables will be evaluated in further reports.

¹MISO: Multiple Inputs Single Output.

About the pump interface. As I could not find a good ready-to-use library for this pump I developed an simple and intuitive interface to be our software routine. The communication protocol used is RS-232. In the software routine the communication used is python serial interface. The pump commands list were found in the user manual.

2.2 Exploring Flowrate

As a first test with the new controlled variable, Flowrate a new procedure was developed. With the goal to scan the stability region of the cone jet mode through the voltage and flowrate variables. This procedure was implemented in the controller thread routine as a new sequence that can be configured in the setup file before an experiment. The algorithm of this sequence in the controller thread is shown below.

Algorithm 1 MAP sequence in controller thread

```

procedure MAP(flowrate_values)
  for all flowrate_values do                                     ▷ scanning in the flowrate range
    SEND_FLOWRATE_COMMAND(flowrate)
    voltage  $\leftarrow$  voltage_start
    while voltage  $\leq$  voltage_stop do                             ▷ scanning in the voltage range
      SEND_VOLTAGE_COMMAND(voltage)
      SLEEP(step_time)
      voltage  $\leftarrow$  voltage + step_size
    end while
  end for
end procedure

```

In the figures 5 and 6 we can see the results of this mapping experiments. The liquid used is pure ethanol. Each figure has 3 graphs with shared x axis representing the samples collected. The first is the current values collected through all the experiment. The second is the voltage values applied in each window of data collected. The colors represent the spraying classification defined by our routine. The third graph shows the current mean value of each data sample. Note that the experiment is composed of loops that increase voltage, change flowrate and repeat.




Figure 5: Mapping Experiment example 1




Figure 6: Mapping Experiment example 2

2.3 Manual experiments

For better understand the effects of both voltage and flowrate in the spraying dynamics manual experiments were made. Also in order to find the stability region of cone jet mode for the liquid and setup used.




Figure 7: exp25-01-1 (V x Q)

experiment 26/01 - 1




Figure 8: exp-26-01-1 (V x Q)

experiment 26/01 - 2




Figure 9: exp-26-01-2 (V x Q)

2.4 Automatic experiments

With the desired voltage and flowrate range defined for the automatic experiment the next part is to define how many datapoints will be collected in both x and y axis. Since we are introducing a new dimension for our experiment it is also increasing fast the amount of data collected. The goal of this part is to find the ideal combination of voltage step size, voltage step time and flowrate step size in order to get the most accurate results without exceeding the separate memory for each experiment.

In the further improvements of the routine it's ideal to apply a real time file writing with all experiment data. This will prevent that any crashes in the program lose all data and not overflow the memory allocated for the program.




Figure 10: First mapping trial




Figure 11: Second mapping trial




Figure 12: third map - better result

2.5 Manual x Automatic Cone Jet stability island maps

For validation of the automatic system and classification some experiments were made having both manual and automatic data collecting.

The Figure 13 shows a printscreen of how the experiment looks like in real time. We can see the image generated by the camera in the back. The routine code running in pycharm software on the right. And also real time signal plottings of the current data on the left.




Figure 13: running experiment print screen

In Figure 14 we can see a result of the map generated by the automatic classification in this experiment.




Figure 14: exp-26-01-23

Figures 15 and 16 shows that we could achieve a stable cone jet region map with similar shape and values in both manual and automatic classification of the same experiment.




Figure 15: exp-26-01 manual classification




Figure 16: exp-26-01 automatic classification

2.6 Pump machine and stepper motor noise

It was noticed that the motor of the pump in certain speed generate a noise caused by the stepping from the stepper motor. This noise from the motor was being acquired by the current data and was interfering in the classification method. Because of that the firsts results of the map have a lot of undefined or incorrect classifications. This can be reduced inserting a air bubble in the syringe to attenuate mechanical noises applied. Also was found a command that can be send to the pump machine to activate microstepping in the stepper motor. Both of this changes were made in order to add the pump machine to the system.

2.7 Capacitance of the system in step response

We had discussions if the voltage step implies in a transient state in the current acquired. If yes, the data acquired in this transient should not be used in the classification step. Since we want to analyse the spraying in a constant dynamics.

For that I reprocessed all raw data acquired cutting the head of the data window. The new classification map is showed in the figure 10. Also tested cutting the tail of the data window to see if have improvements in the classification.




Figure 17: map3 reprocessed data head




Figure 18: map reprocessed data tail

After noticing that cutting out the data collected in the transient of the step voltage did not bring any improvements to the classification. In the Figure 20 we see 3 random samples of current data in the experiment and there's no transient shown in the current data.




Figure 19: 3 samples of current data

As a conclusion of this discussion we got that with voltage steps under 250V the system does not show a transition dynamic. For steps above this value we can see a capacitance curve in the current data. This is explained by the system capacitance which resists to fast changes in electric potential. This threshold value of 250V will vary depending on the resultant capacitance of setup used.

2.8 Temperature and Humidity influences

During this time it was noticed that breaks in between the experiments was getting different results for the same setup. This can be caused by the temperature and humidity effects on the system. For that I included the sensor DHT11 in the system setup and software routine to collect data of this two variables. Also closed the system chamber and sprayed purified air to decrease the humidity inside.

3 Conclusion

The integration with the pump machine in the automatic system brings a new dimension of possibilities in this project. The goal at the moment is to improve the algorithm in order to be capable of scanning the stable region of cone jet mode in the Voltage X Flowrate map. After that define the middle point in the stability island to set as a setpoint to our control system. The control system will be capable of rejecting noises and disturbance in the system in order to keep always in the stable cone jet spraying mode.

For further goals we have:

- Save the experiment data in a file while running the experiment. This will prevent lost of data if the program crashes and also not overflowing the program memory.
- Install and run the experiments in a raspberry pi portable computer running Linux.
- Study about the fourier transform peaks and how it can be used in the classification and in the mapping.
- Improve the classification and routine performance.
- Optimize the controller.

Until the moment the project has been shown good results. The map routine, the control routine and the classification are already implemented and working. Now its more about improvements to get better accuracy in results.