

BALCOMM LIMITED

Commissioning, Ductwork Cleaning
& Water Treatment

HWS Blending Valves

| | |
|---|--|
| Project: High Hill Tower Project | Ref: High Hill commWaterHwsBlend Refefernce |
| System: system1 | Sheet: 1 of 2 |

| Valve Ref | Blending Valve Temperature Range 41 to 43 | Fail Safe Operation | Comments |
|------------------|--|----------------------------|-----------------|
| valref123 | 42. | Set Correctly/Operational | good |

Comments:

Superb Performance

| | |
|-------------------------------|---------------------------|
| Engineer: Elgin Thomas | Date: 06 Jan, 2018 |
|-------------------------------|---------------------------|

BALCOMM LIMITED

Commissioning, Ductwork Cleaning
& Water Treatment

HWS Blending Valves

| | |
|---|----------------------|
| Project: High Hill Tower Project | Ref: ref789 |
| System: system1 | Sheet: 2 of 2 |

| Valve Ref | Blending Valve Temperature Range 41 to 43 | Fail Safe Operation | Comments |
|------------------|--|----------------------------|-----------------|
| 45 | 454. | Set Correctly/Operational | good |

| |
|-------------------------------------|
| Comments: jhgfjghfdjhgjkh |
|-------------------------------------|

| | |
|-------------------------------|---------------------------|
| Engineer: Elgin Thomas | Date: 06 Jan, 2018 |
|-------------------------------|---------------------------|