BALCOMM LIMITED

Commissioning, Ductwork Cleaning & Water Treatment

Water Treatment Check List

Project: 1234	Ref: 123
System: Test3	Sheet: 1 of 1

Clients Check List	
System Complete & Pressure tested	YES
Mains/Boosted Water Available	YES
Adequate flushing Water Pressure	NO
Adequate Flushing/Drains Connections	YES
Adequate Site Drainage	YES
System Drawings Available	YES
Power Available	YES

Check List		
Coils Back Flushed if Applicable	YES	
Dirt Pockets Cleared	YES	
Drain Cocks Cleared	YES	
Strainers Cleaned	YES	
System Vented	YES	
Full Circulation Proved	YES	
System Dosed With Inhibitor	YES	

Mains Water Quality	
TDS:	10
Iron:	1
Appearance:	0
TDS:	10

System Water Quality	
TDS:	10
Iron:	10
Appearance:	10
TDS:	10

Chemicals Used:	1		
Inhibitor Dosage:	gfdg	Biocide Dosage:	gfdg

Comments:

Engineer: Elgin Thomas	Date: 28 Dec, 2017