

VICINITY MAP
NOT TO SCALE



SITE MAP
NOT TO SCALE

BUILDING	FUNCTION
2,3,4,5,6,7	QUARTERS
9	VACANT
11	LINEN
12	LABOR DEPT.
14	ADMINISTRATION
15	ADMINISTRATION
24	CREDIT UNION
27,28,29 30,31	QTRS. CARAGES
32,33,58	STORAGE
47	MAIN HOSPITAL
62	NURSING HOME
63	BLDG.15 BOILER
64	HAZARDOUS WASTE STORAGE
65	BLDG.15 CHILLER
70	MENTAL HEALTH

INDEX OF DRAWINGS

DRAWING NO.	TITLE
G001	COVER SHEET
AE101	BASEMENT BOILER ROOM FLOOR PLAN
AE103	FIRST FLOOR PLANS
AE104	FIRST AND SECOND FLOOR PLANS
AE105	SECOND FLOOR PLAN
AE106	ROOF PLAN
AE107	ROOF PLAN
AE401	DETAILS
AE402	ROOF DETAILS
AE403	ROOF DETAILS
FA100	GENERAL NOTES AND LEGENDS
FA103	ROOF FIRE ALARM PLAN
FP001	FIRE PROTECTION GENERAL NOTES, SYMBOLS, LEGENDS & DETAILS
FP100	BASEMENT FIRE PROTECTION PLANS
FP101	FIRST FLOOR FIRE PROTECTION PLAN
FP102	SECOND FLOOR FIRE PROTECTION PLAN
MH001	LEGENDS, ABBREVIATIONS AND GENERAL NOTES
MD101	FIRST FLOOR DEMOLITION PLAN
MD102	SECOND FLOOR DEMOLITION PLAN
MH101	FIRST FLOOR DUCT PLAN
MH102	SECOND FLOOR DUCT PLAN
MH103	ROOF PLAN
MH104	ROOF PLAN
MH301	MECHANICAL ROOM FLOOR PLAN
MH302	MECHANICAL ROOM FLOOR PLAN
MP101	FIRST FLOOR PIPING PLAN
MP102	SECOND FLOOR PIPING PLAN
MP103	OVERALL FIRST FLOOR PIPING PLAN
MH501	DETAILS
MH502	DETAILS
MH503	DETAILS
MH504	DETAILS
MH601	SCHEDULES
MI701	CONTROLS SCHEMATICS
MI702	CONTROLS SCHEMATICS AND POINTS
EG001	LEGENDS, GENERAL NOTES, AND SCHEDULES
EE100	BASEMENT ELECTRICAL PLAN
EE101	FIRST FLOOR ELECTRICAL PLAN
EE102	SECOND FLOOR ELECTRICAL PLAN
EE103	ELECTRICAL ROOF PLAN
EE501	ELECTRICAL DETAILS
EE502	ELECTRICAL DETAILS
EE601	BLDG #47 RISER DIAGRAM
EE602	ACA EXPANSION RISER DIAGRAM
EE701	PANEL BOARD SCHEDULES
EE702	PANEL BOARD SCHEDULES

CHIEF OF STAFF, APPROVED: _____

ASSOCIATE DIRECTOR, APPROVED: _____

INFECTION CONTROL COORDINATOR, APPROVED: _____

SAFETY MANAGER, APPROVED: _____

M & O FOREMAN, APPROVED: _____

AFGE, REVIEWED: _____

Revision Number	Revisions:	Date:



C1 BASEMENT FLOOR PLAN
SCALE: 1/4" = 1'-0"

(4'-0" X 7'-2"X 6" Thick) Concrete Mechanical Equipment Pad	1.0 EA
(2'-0" X 2'-4" X 6" Thick) Concrete Mechanical Equipment Pad	1.0 EA
(1'-9" X 6'-2" X 6" Thick) Concrete Mechanical Equipment Pad	1.0 EA
(5'-0" X 6'-0" X 6" Thick) Concrete Mechanical Equipment Pad	1.0 EA

Revision Number	Revisions:	Date:



C1 FIRST FLOOR PLAN
SCALE: 1/4" = 1'-0"

C3 FIRST FLOOR PLAN
SCALE: 1/4" = 1'-0"



D3 FIRST FLOOR PLAN
SCALE: 1/4" = 1'-0"



D4 FIRST FLOOR PLAN
SCALE: 1/4" = 1'-0"

(6'-0" X 4'-2" X 14" Thick) Concrete Electrical Equipment Pad **1.0 EA**

Remove & Reinstall Existing Grid & Tiles to Install New Duct Work (Rep... **2561.8 SQ FT**

Revision Number	Revisions:	Date:

SAMPLE
SAMPLE
SAMPLE
SAMPLE

Remove & Reinstall Existing Grid & Tiles to Install New Duct Work (Replace ...	47.8 SQ FT
24" X 24" Access Panel	2.0 EA
(2) (16" X 16") Saw Cut Portion of Elevated Slab For Duct Penetration	3.3 SQ FT
New Partation Wall : Detail (B1/AE104)	5.4 FT



B2 FIRST FLOOR PLAN
SCALE: 1/4" = 1'-0"



B1 PARTITION TYPE
SCALE: 1" = 1'-0"



D2 SECOND FLOOR PLAN
SCALE: 1/4" = 1'-0"

Revision Number	Revisions:	Date:



D2 SECOND FLOOR PLAN
SCALE: 1/8" = 1'-0"

Remove & Reinstall Existing Grid & Tiles to Install New Duct Work (Replace ... **9091.0 SQ FT**

Revision Number	Revisions:	Date:

FIRST FLOOR ROOF
Remove Existing Roofing & Insulation & Re-Roof & Repair Existing Roof
717.6 SQ FT
8-1/2" DIA AND 7" DIA PIPE
44"X16" DUCT
28"X16" DUCT
12"X12" DUCT
14"X14" DUCT
22"X16" DUCT
24"X16" DUCT
D1 ROOF PLAN
SCALE: 1/8" = 1'-0"
Revision Number
Revisions:
Date:


FIRST FLOOR ROOF
FIRST FLOOR ROOF
SECOND FLOOR ROOF
20"X20" DUCT
9" PIPE AND 7-1/4" PIPE
18"X18" DUCT
46"X20" DUCT
38"X20" DUCT
Remove Existing Roofing & Insulation & Re-Roof & Repair Existin...
819.7 SQ FT
D1 ROOF PLAN
SCALE: 1/8" = 1'-0"
Revision Number
Revisions:
Date:



C1 FIRST FLOOR DEMOLITION PLAN
SCALE: 1/4" = 1'-0"

C3 FIRST FLOOR DEMOLTION PLAN
SCALE: 1/4" = 1'-0"



R DEMOLITION PLAN

Demolish All Existing Ductwork, Grilles,Diffusers, Valves & Da...	293.0 SQ FT
14 X6 Mechanical Duct to be Removed	28.8 FT
22 X10 Mechanical Duct to be Removed	12.0 FT
16 X10 Mechanical Duct to be Removed	6.2 FT
34 X10 Mechanical Duct to be Removed	11.5 FT
10 X6 Mechanical Duct to be Removed	3.4 FT
(10"-20") Dia Mechanical Duct to be Removed	15.5 FT
(3"-10") Dia Mechanical Duct to be Removed	69.1 FT
8 X6 Mechanical Duct to be Removed	4.5 FT
Flexible Duct to be Removed	13.0 FT
Air Grille/Register to be Removed	7.0 EA
Existing Thermostate to Be Removed	2.0 EA



D2 SECOND FLOOR DEMOLITION PLAN

SCALE: 1/8" = 1'-0"

8 X10 Mechanical Duct to be Remov...	159.1 FT
(3"-10") Dia Mechanical Duct to be ...	282.4 FT
6 X12 Mechanical Duct to be Removed	24.9 FT
14X8 Mechanical Duct to be Removed	70.6 FT
14 X10 Mechanical Duct to be Remov...	18.6 FT
24 X12 Mechanical Duct to be Remov...	29.2 FT
12 X12 Mechanical Duct to be Remov...	18.0 FT
12 X14 Mechanical Duct to be Remo...	27.7 FT
(10"-20") Dia Mechanical Duct to be ...	14.2 FT
Air Grille/Register to be Removed	19.0 EA

Revision Number	Revisions:	Date:



C1 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"



C2 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"



B4 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"



D2 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"

Revision Number	Revisions:	Date:



C1 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"



C2 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"



B4 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"



D2 FIRST FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"

Legend

Description	Quantity	Unit
10 X 12 Mechanical Duct	13.1414	ft
10" Dia Mechanical Duct	5.9584	ft
10" Dia Mechanical Duct	7.1201	ft
14 X 8 Mechanical Duct	5.7184	ft
14X 14 Duct Riser (24' H)	1	Count
16 X 16 Duct Riser (24' H)	1	Count
18 X 12 Duct Riser (24' H)	1	Count
20 X 12 Duct Riser (24' H)	1	Count
24 X 12 Duct Riser (24' H)	1	Count
40 X 12 Duct Riser (24' H)	1	Count
Tag A: (24 x24) Diffuser (Mfr: Naailor, Model: UNI-RC, 6" Dia Neck Size)	2	Count
Tag A: (24 x24) Diffuser (Mfr: Naailor, Model: UNI-RC, 8" Dia Neck Size)	3	Count
Tag A: (24 x24) Diffuser (Mfr: Naailor, Model: UNI-RC, 10" Dia Neck Size)	14	Count
Tag A: (24 x24) Diffuser (Mfr: Naailor, Model: UNI-RC, 12" Dia Neck Size)	3	Count
Tag P: (24 x24) Diffuser (Mfr: Naailor, Model: 5010R-CTD, 10" Dia Neck Size)	5	Count
Tag P: (24 x24) Diffuser (Mfr: Naailor, Model: 5010R-CTD, 12" Dia Neck Size)	1	Count
TU-ENT 1	1	Count
TU-ENT 2	1	Count
TU-ENT 3	1	Count
TU-ENT 4	1	Count
TU-ENT 5	1	Count
TU-ENT 6	1	Count
TU-MSURG-1	1	Count
TU-MSURG-2	1	Count
TU-MSURG-3	1	Count
TU-MSURG-4	1	Count
Volume Damper	24	Count

Revision Number	Revisions:	Date:

6" Dia Mechanic...	68.8 FT
8" Dia Mechanic...	87.8 FT
10 x 8 Mechanic...	37.8 FT
42 x 16 Mechani...	10.5 FT
40 x 16 Mechani...	50.3 FT
34 x 16 Mechani...	17.6 FT
30 x 16 Mechani...	31.7 FT
48 x 16 Mechani...	11.4 FT
14 x 14 Mechanic...	7.0 FT
12" Dia Mechani...	58.3 FT
10" Dia Mechani...	49.9 FT
10 x 10 Mechani...	18.2 FT
8 x 8 Mechanical...	15.0 FT
Tag A: (24 x24) Di...	5.0 EA
Tag A: (24 x24) Di...	7.0 EA
Tag P: (24 x24) Di...	6.0 EA
Tag P: (24 x24) Di...	2.0 EA
Tag P: (24 x24) Di...	1.0 EA
Volume Damper	20.0 EA
TU-ENDO 1	1.0 EA
TU-ENDO 2	1.0 EA
TU-ENDO 3	1.0 EA
TU-ENDO 4	1.0 EA
AFCV-1	1.0 EA
AFCV-2	1.0 EA
AFCV-3	1.0 EA
AFCV-4	1.0 EA
14 X 14 Mechanic...	2.0 EA
34 X 16 Mechanic...	1.0 EA
42 X 16 Mechanic...	1.0 EA
16 X 16 Mechanic...	1.0 EA



OOR DUCT PLAN



D3 SECOND FLOOR DUCT PLAN
SCALE: 1/4" = 1'-0"



24 x 12 Mechanical Duct	9.7 FT
40 x 12 Mechanical Duct	16.1 FT
2" Dia MPS	143.6 FT
2-1/2" Dia MPS	26.5 FT
3/4" Dia MPR	142.7 FT
1" Dia MPR	25.6 FT
2-1/2" CHR	61.3 FT
2" Dia CHR	83.8 FT
3" Dia CHR	21.5 FT
3" Dia CWS	22.2 FT
2-1/2" Dia CWS	63.5 FT
2" Dia CWS	82.6 FT
8 x 8 Mechanical Duct	110.4 FT
10 x 10 Mechanical Duct	107.3 FT
20 X 12 Mechanical Duct	11.1 FT
26 x 12 Mechanical Duct	2.1 FT
18 x 12 Mechanical Duct	4.8 FT
AHU-ENT	1.0 EA
ACC-ENT	1.0 EA
AHU-MSURG	1.0 EA
Globe Valve	8.0 EA



3/4" Dia MPR	31.7 FT
1-1/2" Dia MPS	29.8 FT
1-1/4" Dia MPR	4.0 FT
1" Dia MPR	128.1 FT
2-1/2" Dia MPS	129.5 FT
3" Dia MPS	3.1 FT
3" Dia CWS	14.7 FT
3" Dia CHR	12.9 FT
2" Dia CHR	66.4 FT
2-1/2" CHR	83.9 FT
2-1/2" Dia CWS	85.0 FT
2" Dia CWS	66.3 FT
14 x 14 Mechanical Duct	10.3 FT
16 x 16 Mechanical Duct	13.0 FT
42 x 16 Mechanical Duct	27.7 FT
34 x 16 Mechanical Duct	40.3 FT
AHU-POD	1.0 EA
ACC-ENT	1.0 EA
AHU-ENDO	1.0 EA
EF-ENDO	1.0 EA
Globe Valve	8.0 EA



BASEMENT FLOOR PLAN
SCALE: 1/4" = 1'-0"

2" Dia HWS	23.5 FT
2" Dia HWR	48.6 FT
1" Dia MPR	11.4 FT
2" Dia MPR	11.6 FT
2-1/2" Dia MPS	42.2 FT
3" Dia MPS	1.9 FT
1" Dia HPS	20.3 FT
3" Dia HPS	25.8 FT
ET-1	1.0 EA
AS-1	1.0 EA
Pressure Reducing Station ...	1.0 EA
Pressure Reducing Station ...	1.0 EA
HWP-1	1.0 EA
HWP-2	1.0 EA
HX-1	1.0 EA
HX-2	1.0 EA
HX-V1	1.0 EA
HX-V2	1.0 EA
New Steam Condensate P...	1.0 EA
2-1/2" Dia MPS Riser (24' H)	1.0 EA
1" Dia MPR Riser (24' H)	1.0 EA
2" Dia HWS Riser (24' H)	1.0 EA
2" Dia HWR Riser (24' H)	1.0 EA
2" Automatic Isolation Valve	1.0 EA
3" Gate Valve	1.0 EA
2" Gate Valve	1.0 EA



D1 BASEMENT FLOOR PLAN
SCALE: 1/4" = 1'-0"

Revision Number	Revisions:	Date:



C1 FIRST FLOOR PIPING PLAN
SCALE: 1/4" = 1'-0"



C2 FIRST FLOOR PIPING PLAN
SCALE: 1/4" = 1'-0"



B4 FIRST FLOOR PIPING PLAN
SCALE: 1/4" = 1'-0"



D2 FIRST FLOOR PIPING PLAN
SCALE: 1/4" = 1'-0"

2" Dia HWS	22.7 FT
1-1/2" Dia HWS	190.6 FT
2" Dia HWR	22.4 FT
1-1/2" Dia HWR	194.2 FT
3" Dia MPS	9.4 FT
1-1/4" Dia MPR	15.8 FT
1-1/4" Dia HWR	9.7 FT
1-1/4" Dia HWS	8.6 FT
Thermostate	8.0 EA





D3 SECOND FLOOR PIPING PLAN

SCALE: 1/4" = 1'-0"

1-1/4" Dia HWS	124.7 FT
1-1/4" Dia HWR	125.2 FT
1" Dia HWR	6.5 FT
1" Dia HWS	6.1 FT
3/4" Dia HWR	19.3 FT
3/4" Dia HWS	21.7 FT
Thermostate	6.0 EA

D1 FIRST FLOOR PIPING PLAN
SCALE: 1/16" = 1'-0"

1-1/2" Dia HWS	502.8 FT
1-1/2" Dia HWR	499.8 FT

Revision Number	Revisions:	Date: