



RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	PR-1032300385 REPLACEMENT OF DAMAGED	1	G01				
			THERMAL INSULATION FOR SUPPLY & RETURN AIR						
			DUCTS AT E-STATION, PHASE-1 H1 BUILDING,						
			PLANT-1,						
			JEBEL ALI. 1.#SCOPE OF WORK: A)#REMOVAL OF						
			EXISTING OLD DUCT INSULATION. B)#CLEANING						
			AND REPAIRING OF EXISTING DUCT. C)#SUPPLY						
			THE I						
			NSULATION MATERIAL AND RE-INSULATE IN						
			SUPPLY & RETURN AIR DUCTS REQUIRED WITH 1"						
			GLASS WOOL BOARD INSULATION SHEET WITH						
			FOSTER AND C						
			LOTH. D)#THERMAL INSULATION FOR SUPPLY AND						
			RETURN AIR DUCT SHALL BE OF 1" THICKNESS						
			FIBER-GLASS BOARD INSULATION OF DENSITY 64						
			KG/CU						
			BIC METER HAVING CANVAS CLOTH WITH						
			ANTI-FUNGUS FOSTER COATING OF RATING 30-60						
			AND 30-90 ONLY. E)#PROPER HOUSEKEEPING						
			MUST MAINTAINED						
			ON DAILY BASIS DURING THE WORK. F)#REMOVED						
			DUCTS, INSULATION SHALL BE SEGREGATED AND						
		1	RETURN TO DEWA SCRAP YARD BY THE						





RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAI PRICE
			CONTRACTOR AS						
			PER DEWA EXISTING QUANTITY, SAFETY &						
			ENVIRONMENTAL PROCEDURE. TECHNICAL						
			SPECIFICATION OF EXISTING SUPPLY AIR DUCTS						
			FOR INSULATION R						
			EPLACEMENT: PHASE-1 SWGR ROOM-10 SR.#DUCT						
			SIZE#DUCT LENGTH#QTY.#REMARKS# 1#700 X 400						
			MM#5000 MM#01#DUCT MEASUREMENT ARE FOR						
			ILLUSTRA						
			TION PURPOSE ONLY. IT IS CONTRACTOR						
			RESPONSIBILITY TO TAKE ACTUAL						
			MEASUREMENTS AND SHALL COVER ALL DUCT						
			QUANTITY AS MENTIONED HEREIN						
			.# 2#500 X 400 MM#6000 MM#01## 3#350 X 350						
			MM#7000 MM#01## 4#300 X 200 MM#12000 MM#01##						
			5#500 X 400 MM#7000 MM#01## 6#700 X 700 MM#4						
			0000MM#01## ROOM NUMBER-1 SR.#DUCT						
			SIZE#DUCT LENGTH#QTY.#REMARKS# 1#1000 X 400						
			MM#15000 MM#01#DUCT MEASUREMENT ARE FOR						
			ILLUSTRATION						
			PURPOSE ONLY. IT IS CONTRACTOR						
			RESPONSIBILITY TO TAKE ACTUAL						
			MEASUREMENTS AND SHALL COVER ALL DUCT						





RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAI PRICE
			QUANTITY AS MENTIONED HEREIN.# 2						
			#700 X 400 MM#8000 MM#01## 3#600 X 400 MM#6000						
			MM#01## 4#400 X 400 MM#3000 MM#01## ROOM						
			NUMBER-E2 SR.#DUCT SIZE#DUCT						
			LENGTH#QTY.#R						
			EMARKS# 1#800 X 300 MM#31000 MM#01#DUCT						
			MEASUREMENT ARE FOR ILLUSTRATION PURPOSE						
			ONLY. IT IS CONTRACTOR RESPONSIBILITY TO						
			TAKE ACTUA						
			L MEASUREMENTS AND SHALL COVER ALL DUCT						
			QUANTITY AS MENTIONED HEREIN.# 2#1000 X 300						
			MM#26000 MM#01## 3#600 X 500 MM#6000 MM#01##						
			4#4						
			00 X 400 MM#6000 MM#01## ROOM NUMBER-E3						
			SR.#DUCT SIZE#DUCT LENGTH#QTY.#REMARKS#						
			1#500 X 200 MM#28000 MM#01#DUCT						
			MEASUREMENT ARE FOR						
			ILLUSTRATION PURPOSE ONLY. IT IS						
			CONTRACTOR RESPONSIBILITY TO TAKE ACTUAL						
			MEASUREMENTS AND SHALL COVER ALL DUCT						
			QUANTITY AS MENTION						
			ED HEREIN.# 2#400 X 400 MM#10000 MM#01## 3#600						
			X 400 MM#18000 MM#01## 4#500 X 200 MM#10000						





RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MM#01## 5#500 X 400 MM#6000 MM#01## 6#400						
			X 400 MM#3000MM#01## H-5 BOILER OPERATOR						
			CONTROL ROOM, CHILLER ROOM & BATTERY						
			ROOM SR.#DUCT SIZE#DUCT						
			LENGTH#QTY.#REMARKS# 1#400 X						
			300 MM#16000 MM#01#DUCT MEASUREMENT ARE						
			FOR ILLUSTRATION PURPOSE ONLY. IT IS						
			CONTRACTOR RESPONSIBILITY TO TAKE ACTUAL						
			MEASUREMENTS						
			AND SHALL COVER ALL DUCT QUANTITY AS						
			MENTIONED HEREIN.# 2#400 X 400 MM#12000						
			MM#01## 3#300 X 200 MM#10000 MM#01## 4#400 X						
			300 MM#100						
			00 MM#01## 2.#GENERAL CONDITIONS:						
			A)#INTERESTED PARTIES MAY VISIT JEBEL ALI						
			POWER STATION E' TO GET ACQUAINTED TO THE						
			ACTUAL SITE C						
			ONDITIONS AND RELATED WORKS. B)#DEWA WILL						
			NOT ACCEPT ANY CLAIMS FOR ANY EXTRA WORK						
			BEYOND THE ISSUE PO ORDERED QUANTITIES.						
			C)#CONTRA						
			CTOR SHALL ABIDE BY DEWA SAFETY AND						
			SECURITY AND REGULATIONS IN-FORCE AT THE						





RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTA PRICE
			POWER STATION. CONTRACTOR SHOULD FOLLOW						
			THE ENVIRONMENT						
			TO DEWA BEFORE ONE WEEK. D)#ALL						
			NECESSARY TOOLS & MEASURING INSTRUMENTS						
			SHALL BE ARRANGED BY THE CONTRACTOR. THE						
			TOOLS SHALL HAVE						
			VALID CALIBRATION CERTIFICATES. E)#THE						
			CONTRACTOR SHALL ABIDE BY DEWA SAFETY AND						
			SECURITY RULES AND REGULATIONS IN-FORCE AT						
			THE POWE						
			R STATION. CONTRACTOR SHOULD FOLLOW THE						
			ENVIRONMENT RULES AND STATED IN DEWA ISO						
			14001. F)#THE WORK SHALL BE CARRIED OUT IN A						
			NEAT,						
			ORDERLY AND SAFE MANNER. G)#THE						
			CONTRACTOR WILL BE HELD RESPONSIBLE FOR						
			ANY DAMAGE TO THE NEARBY DEWA ASSETS						
			DURING JOB EXECUTION. H						
)#THE CONTRACTOR SHALL CARRY OUT ALL THE						
			MECHANICAL AND ELECTRICAL WORKS RELATED						
			TO THE JOB FOR SUCCESSFUL COMPLETION OF						
			THE PROJECT						
			. I)#GATE PASSES APPLICATION TO BE SUBMITTED						





RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			7 DAYS IN ADVANCE BEFORE STARTING THE						
			WORK, ALONG WITH PASSPORT COPY, VISA COPY,						
			ID COP						
			Y, VEHICLE REGISTRATION COPY AND LPO COPY.						
			3.#DOCUMENTS: A)#THE SUPPLIERS SHALL SUBMIT						
			COMPLETES DUCT INSULATION SPECIFICATIONS						
			ALO						
			NG WITH THEIR OFFER. B)#THE SUPPLIERS SHALL						
			SUBMIT A METHOD STATEMENT AND JOB						
			COMPLETION SCHEDULE ALONG WITH THEIR						
			OFFER. 4.#PERIOD						
			OF COMPLETION: A)#THE BIDDER SHALL MENTION						
			THE JOB COMPLETION PERIOD IN THEIR OFFER,						
			THE PERIOD WILL START FROM THE DATE OF						
			DEWA PO						
			CONFIRMATION. 5.#TERMS OF DELIVERY:						
			A)#DELIVERY OF DUCT INSULATION SHALL BE						
			WITHIN 30 DAYS FROM THE DATE OF PURCHASE						
			ORDER. 6.#TE						
			RMS OF PAYMENT: A)#100% OF THE PO VALUE						
			WILL BE PAID WITHIN 30 DAYS AFTER SUCCESSFUL						
			COMPLETION OF JOB AGAINST THE INVOICE						
			CERTIFIED						





RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

L NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAI PRICE
			BY DEWA AUTHORIZED						
			ENGINEER/REPRESENTATIVE. B)#INVOICE SHALL						
			BE ADDRESSED TO DEWA FINANCE DEPARTMENT.						
			C)#FOR FURTHER DETAILS AND SC						
			OPE OF WORK, PROSPECTIVE PARTIES SHALL						
			VISIT 'D' POWER STATION JEBEL ALI, BETWEEN 8						
			AM TO 3 PM ON WORKING DAY. D)#FOR FURTHER						
			TECHNI						
			CAL DETAILS, CONTACT MR. VENKATA SIDAGAM						
			058-8732543/04-8044475 OR MR. MANSOOR AHMED						
			050-3520794 /04-8044160 FOR FURTHER DETAILS. 7						
			.#WARRANTY: A)#THE DUCT INSULATION SHALL BE						
			GUARANTEED FOR PERFORMANCE,						
			WORKMANSHIP AND MANUFACTURING DEFECTS						
			FOR A PERIOD OF ONE YE						
			AR. B)#THE WARRANTY WILL TAKE EFFECT FROM						
			THE DATE OF TAKEOVER AFTER JOB COMPLETION.						
			C)#WHEN A DEFECT IS NOTICED ON THE NEWLY						
			INSTAL						
			L ROOF EXILE FAN DURING THE PERIOD OF						
			WARRANTY, THE CONTRACTOR MUST RECTIFY						
			THE FAULT WITHIN A REASONABLE AMOUNT OF						
			TIME FIXED BY DE						





RFQ NUMBER : 2332300646

DATE : 10.03.2023

REQ No : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WA WITH NO CLAIMS OR COMPENSATION. AFTER						
			REPLACEMENT OF THE FAULTY PART OR						
			RECTIFICATION OF THE FAULT, WARRANTY OF THE						
			CONCERNED PAR						
			T SHALL BE RESTARTED FOR ONE YEARS.						

TOTAL AMOUNT IN WORDS: TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Duct Insulation

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

Page8 of 9





RFQ NUMBER : 2332300646

DATE : 10.03.2023 **REQ No** : 1032300385

REQ TITLE : Duct Insulation 1032300385

DELIVERY LOCATION

CLOSING DATE : 16.03.2023

CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP