

WindOps Copilot - Turbine Report

Turbine ID: WTG-004 | Correlation ID: corr-165bffb42144
Report Generated: 2026-06-26T10:27:46.519329

TURBINE HEALTH STATUS

100.0% Health

Live Sensor Telemetry

Sensor Parameter	Value	Unit
Wind Speed	12.22	m/s
Rotor Speed	16.33	RPM
Blade Temperature	24.23	°C
Generator Temperature	52.73	°C
Vibration	0.08	mm/s
Power Output	2.36	MW
Operational Status	active	

Active Fault Alerts

No active alerts detected. The turbine is operating within nominal thresholds.

Diagnostic Root Cause Analysis

No diagnostic analysis was required (turbine health is nominal).

Operational Action Recommendations

Recommended Action	Description	Risk	Production Loss	Confidence
Maintain Normal Operations	Maintain current pitch, yaw, and generator outputs. Turbine parameters are healthy. No active interventions required.	LOW	none	100%

Note: This report is generated by an autonomous multi-agent system. final actions must be reviewed and authorized by a human operator.