

1. Details of Consumer:

Name:	mehul	Address: surat NR. SATYA SAI HOSPITAL, RAJKOT PIN Code: 333333
Electricity Connection no.	N/A	TAL: surat District: surat
GUVNL Registration no.	R-GJPG24-014138275	State: surat

2. Details of Solar PV cells and Inverter:

No.	Particular	Modules	Inverter
1	Make	WAAREE	SOFAR
2	Capacity Wp	540	4.0 KW
3	No.of Modules Inverter	8	1
4	Total Capacity	4.32 KW	4.0 KW
5	Voltage(voc)		
6	Sr.No	Attached Separate Sheet	Attached Separate Sheet

3. Test Results:

Earth Tester Sr no.- 2100091 Earth Resistance values for all Earth Pits: 1. 0.45Ω 2. 0.42Ω 3. 0.3Ω 4. Ω	Meggars Sr.no: - 21007029 Insulation Resistance: 1. Phase to Phase: 230MΩ 2. Phase to Earth: 250MΩ
The work of aforesaid installation has been completed by us on Date 20/08/2024 and it is to hereby declare that	
a) All PV modules and its supporting structures have enough mechanical strength and it conforms to the Relevant codes/guidelines prescribed in this behalf.	
b) All cables/wires, protective switchgears as well as Earthlings are of adequate ratings/size and they conform to the requirements of Central Electricity Authority (Measures relating to safety and electrical supply), Regulations 2010 as well as the relevant codes/guidelines prescribed in this behalf.	
c) The work of aforesaid Installation has been carried out in conformance with the requirements of Central Electricity Authority (Measures relating to safety and electrical supply), Regulations 2010 and the relevant codes/guidelines prescribed in this behalf. The installation is tested by us and is found safe to be energized.	
Date: 22/08/2024	Date: 22/08/2024
Name of Electrical Supervisor: Patel Jaykumar	Signature of Licensed Electrical Contractor License No.- GJ/RJK/C-03901 Valid up to - 11.2.2029
Permit No.- G/GS-E-010185-BEE-2023	