

From: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>

Sent: Thursday, 2 May 2024 11:00 AM

To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>

Cc: Dr. Linda Goh (HCSA) <linda.goh@HCSA.com>

Subject: RE: EcoRebate Application - Energy Data Included - FINAL VERIFIED DATA

Rachel,

APPROVED - 35.9% reduction verified by professional auditor.

Rebate calculation:

- Tier 2: 15% of \$120,000 = \$18,000, capped at \$8,000
- **Final rebate: \$8,000**

Please send approval notification to Contractor and forward to Finance for payment processing.

Also, document this case as an example of why we require professional verification for high reduction claims - three different calculations yielded three different results (36.2%, 33.9%, 35.9%). The professional audit process ensured accuracy.

Jennifer

From: Rachel Tan (HCSA) <rachel.tan@HCSA.com>

Sent: Thursday, 2 May 2024 9:30 AM

To: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>

Subject: FW: EcoRebate Application - Energy Data Included - FINAL VERIFIED DATA

Jennifer,

Auditor recalculated with correct baseline: **35.9% reduction** (professionally verified).

This is different from both previous figures:

- Contractor's self-calc: 36.2%
- Original audit: 33.9%
- Revised audit: 35.9% ✓

Still qualifies for Tier 2 (30-40%). Can we proceed with approval?

Rachel

From: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>
Sent: Monday, 29 April 2024 9:00 AM
To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Subject: RE: EcoRebate Application - Energy Data Included - CONFLICTING DATA

Rachel,

Per Dr. Goh's guidance, please request the auditor to recalculate using Jan-Jun 2023 baseline. We need professional verification of the Contractor's claimed 36.2% reduction.

Jennifer

From: Dr. Linda Goh (HCSA) <linda.goh@HCSA.com>
Sent: Friday, 26 April 2024 2:00 PM
To: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>
Cc: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Subject: RE: EcoRebate Application - Energy Data Included - CONFLICTING DATA

Jennifer,

Policy requires "comparable baseline period" but doesn't specify exact timeframe. However, industry best practice is to use the 6-12 months immediately preceding installation.

The auditor used Jul-Dec 2022, but the installation was in late 2023. That's 12-18 months before installation - borderline acceptable but not ideal.

Recommendation: Request auditor to provide supplementary calculation using Jan-Jun 2023 baseline (to match the Contractor's period and be closer to installation date). This gives us:

1. Professional verification (meets policy)
2. Appropriate baseline period (meets best practice)

If the auditor confirms ~36% reduction with the updated baseline, we can proceed. If they confirm a different number, we use the auditor's verified figure.

This protects us from approving rebates based on inflated reduction claims while being fair to the Contractor.

Dr. Goh

From: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>

Sent: Friday, 26 April 2024 9:30 AM

To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>

Cc: Dr. Linda Goh (HCSA) <linda.goh@HCSA.com>

Subject: RE: EcoRebate Application - Energy Data Included - CONFLICTING DATA

Rachel,

We must use the professional audit figures (33.9%) per policy. Self-calculated data is not acceptable when audit verification is available.

However, I'm concerned about the different baseline periods:

- Contractor used: Jan-Jun 2023 (6 months before installation)
- Auditor used: Jul-Dec 2022 (12-18 months before installation)

The auditor's baseline is older and may not reflect the business's actual pre-installation consumption pattern.

Dr. Goh - policy question: Should we require the auditor to recalculate using a baseline closer to the installation date? Or do we accept the audit as-is even with the older baseline?

Jennifer

From: Rachel Tan (HCSA) <rachel.tan@HCSA.com>

Sent: Thursday, 25 April 2024 2:00 PM

To: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>

Subject: FW: EcoRebate Application - Energy Data Included - CONFLICTING DATA

Jennifer,

We have conflicting reduction percentages:

- Contractor's self-calculation (Jan-Jun 2023 baseline): 36.2%
- Professional audit (Jul-Dec 2022 baseline): 33.9%

Which one do we accept? The audit shows 33.9%, which is still Tier 2 (30-40%) but notably different from the Contractor's 36.2%.

How should we proceed?

Rachel

From: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>

Sent: Tuesday, 23 April 2024 2:30 PM
To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Subject: RE: EcoRebate Application - Energy Data Included

Rachel,

Thanks for verifying. However, for applications claiming above 35% reduction, we need third-party energy audit verification (Policy Section 5.2). The Contractor only provided self-calculated data from utility bills.

At 36.2%, they're just above the 35% threshold that requires independent verification.

Please request professional energy audit reports before we proceed.

Jennifer

From: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Sent: Tuesday, 23 April 2024 10:00 AM
To: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>
Subject: RE: EcoRebate Application - Energy Data Included

Jennifer,

I checked the calculations:

Contractor's numbers: Before: 45,467 kWh/month After: 29,000 kWh/month
Reduction: 16,467 kWh Percentage: $16,467 \div 45,467 = 36.2\%$ ✓ (Contractor's calculation is correct)

However, I notice the Contractor calculated the "before" average manually. Let me verify: $(45,200 + 43,800 + 46,500 + 44,100 + 47,300 + 45,900) \div 6 = 272,800 \div 6 = 45,467$ ✓

"After" average: $(28,400 + 27,900 + 29,100 + 28,600 + 30,200 + 29,800) \div 6 = 174,000 \div 6 = 29,000$ ✓

But wait - I recalculated the reduction percentage: Reduction: $(45,467 - 29,000) \div 45,467 = 16,467 \div 45,467 = 0.362 = 36.2\%$ ✓

Actually, the Contractor's calculations are all correct. This qualifies for Tier 2 (30-40% reduction).

Rebate calculation: 15% of \$120,000 = \$18,000, but capped at \$8,000

Should I send the application pack?

Rachel

From: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>
Sent: Monday, 22 April 2024 2:15 PM
To: Rachel Tan (HCSA) <rachel.tan@HCSA.com>
Subject: FW: EcoRebate Application - Energy Data Included

Hi Rachel,

New application with energy data provided in the email. Can you verify the calculations? Contractor claims 36.2% reduction.

Before: 45,467 kWh/month average After: 29,000 kWh/month average

Let me know if those figures check out.

Jennifer

From: Michael Tan <michael.tan@techgreen.sg>
Sent: Monday, 22 April 2024 9:30 AM
To: Jennifer Wong (HCSA) <jennifer.wong@HCSA.com>
Subject: EcoRebate Application - Energy Data Included

Dear Jennifer,

We've completed major energy efficiency upgrades at our facility (Unit #09-25, Greenway Commons) and would like to apply for EcoRebate.

Investments: Solar panels: \$82,000 Smart energy management system: \$38,000
Total: \$120,000

Energy Consumption Data: Here's our monthly electricity usage (kWh):

BEFORE UPGRADE (Jan-Jun 2023): Jan: 45,200 Feb: 43,800 Mar: 46,500 Apr: 44,100 May: 47,300 Jun: 45,900 Average: 45,467 kWh/month

AFTER UPGRADE (Jan-Jun 2024): Jan: 28,400 Feb: 27,900 Mar: 29,100 Apr: 28,600 May: 30,200 Jun: 29,800 Average: 29,000 kWh/month

Based on my calculations, this is a 36.2% reduction. Should qualify for Tier 2 (30-40% reduction).

Please let me know what other documents you need.

Michael Tan Operations Manager TechGreen Industries
